







NOTES:

1. INSTALLATION MUST COMPLY WITH NATIONAL AND LOCAL ELECTRICAL REGULATIONS.
2. PLEASE REFER TO THE PRODUCT MANUALS FOR DETAILED INFORMATION.
3. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].
4. NET WEIGHT OF UNIT IS 89.09 Kg [196 LBS].
5. CABLE ENTRY IS TOP OR BOTTOM OF UNIT.
6. FRONT AND REAR SERVICE ACCESS REQUIRED.
7. AIR FLOW AND SERVICE REQUIREMENTS, AS WELL AS MINIMUM CLEARANCE TO FIRE SUPPRESSION SYSTEMS SHOULD BE CONSIDERED WHEN LOCATING THE ENCLOSURE.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider
Electric

TITLE:
NETSHELTER SX 24U
600MM x 1070MM DEEP ENCLOSURE
MAIN MECHANICAL

PROJECT: STD SUBMITTAL DRAWINGS SHEET 1 OF 3

DWG NO: AR3104

DRAWN BY: B ZAHN 07-AUG-09

ENGINEER: K. THOMAS 07-AUG-09


APPROVED BY: B. SHERMAN / S. CURSON / S. SMITH 07-AUG-09

REV. 2


FIRST

ANGLE

PROJECTION



TOP VIEW



SECTION B-B

(VIEW FROM INSIDE CABINET, LOOKING DOWN
SOME MECHANICAL COMPONENTS HAVE BEEN
OMITTED FOR THE PURPOSE OF CLARITY)

NOTES:

1. INSTALLATION MUST COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL CODES.
2. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES]


THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider Electric


TITLE: NETSHELTER SX 24U
600MM x 1070MM DEEP ENCLOSURE
TOP, SECTION VIEWS

PROJECT: STD SUBMITTAL DRAWINGS SHEET 2 OF 3

DWG NO:	AR3104	REV:	2
DRAWN BY:	B ZAHN	07-AUG-09	FIRST ANGLE
ENGINEER:	K.THOMAS	07-AUG-09	PROJECTION
APPROVED BY:	SHERMAN/CURSEN/SINGH	07-AUG-09	



BOTTOM VIEW
(WITH PALLET BRACKETS
(CAN BE USED FOR ANCHORING))



BOTTOM VIEW
(WITH BOLT-DOWN BRACKETS
FOR ANCHORING, SOLD SEPERATELY)

NOTES:

1. INSTALLATION MUST COMPLY WITH ALL APPLICABLE NATIONAL AND LOCAL CODES.
2. ALL DIMENSIONS ARE IN MILLIMETERS [INCHES].

△ 3. ANCHORING CAN BE INSTALLED EITHER INSIDE OR OUTSIDE THE NetShelter WITH ONE AT FRONT AND ONE IN BACK.

△ 4. BOLT-DOWN KIT (SKU# AR7701) IS OPTIONAL AND HAS TO BE ORDERED SEPERATELY.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider Electric

TITLE:
NETSHELTER SX 24U
600MM x 1070MM DEEP ENCLOSURE
MAIN MECHANICAL

PROJECT: STD SUBMITTAL DRAWINGS SHEET 3 OF 3

DWG NO:	AR3104	REV:	3
DRAWN BY:	B ZAHN/S CUNHA	30-NOV-12	FIRST ANGLE
ENGINEER:	K.THOMAS	07-AUG-09	PROJECTION
APPROVED BY:	B.SHERMAN/E.SLOW/C. LARSEN/S. WICH	07-AUG-09	