

Multichannel Marine Seismic Evaluation System

Features

- Four-channel Seismic Acquisition Node
 - CS5374 dual amplifier & $\Delta\Sigma$ modulator (2x)
 - CS5376A quad digital filter (1x)
 - CS4373A $\Delta\Sigma$ test DAC (1x)
 - Precision voltage reference
 - Clock recovery PLL
- On-board Microcontroller
 - SPI™ interface to digital filter
 - USB communication with PC
- PC Evaluation Software
 - Register setup & control
 - FFT frequency analysis
 - Time domain analysis
 - Noise histogram analysis

General Description

The CDB5374 board is used to evaluate the functionality and performance of the Cirrus Logic multichannel marine seismic chip set. Data sheets for the CS5374, CS5376A, and CS4373A devices should be consulted when using the CDB5374 evaluation board.


Screw terminals connect external differential hydrophone sensors to the analog inputs of the measurement channels. An on-board test DAC creates precision differential analog signals for in-circuit performance testing without an external signal source.

The evaluation board includes an 8051-type microcontroller with hardware SPI™ and USB serial interfaces. The microcontroller communicates with the digital filter via SPI and with the PC evaluation software via USB. The PC software controls register and coefficient initialization and performs time domain, histogram, and FFT frequency analysis on captured data.

ORDERING INFORMATION

CDB5374

Evaluation Board



REVISION HISTORY

Revision	Date	Changes
DB1	JAN 2009	Initial release.

Contacting Cirrus Logic Support

For all product questions and inquiries contact a Cirrus Logic Sales Representative. To find the one nearest to you go to www.cirrus.com

IMPORTANT NOTICE

Cirrus Logic, Inc. and its subsidiaries ("Cirrus") believe that the information contained in this document is accurate and reliable. However, the information is subject to change without notice and is provided "AS IS" without warranty of any kind (express or implied). Customers are advised to obtain the latest version of relevant information to verify, before placing orders, that information being relied on is current and complete. All products are sold subject to the terms and conditions of sale supplied at the time of order acknowledgment, including those pertaining to warranty, indemnification, and limitation of liability. No responsibility is assumed by Cirrus for the use of this information, including use of this information as the basis for manufacture or sale of any items, or for infringement of patents or other rights of third parties. This document is the property of Cirrus and by furnishing this information, Cirrus grants no license, express or implied under any patents, mask work rights, copyrights, trademarks, trade secrets or other intellectual property rights. Cirrus owns the copyrights associated with the information contained herein and gives consent for copies to be made of the information only for use within your organization with respect to Cirrus integrated circuits or other products of Cirrus. This consent does not extend to other copying such as copying for general distribution, advertising or promotional purposes, or for creating any work for resale.

CERTAIN APPLICATIONS USING SEMICONDUCTOR PRODUCTS MAY INVOLVE POTENTIAL RISKS OF DEATH, PERSONAL INJURY, OR SEVERE PROPERTY OR ENVIRONMENTAL DAMAGE ("CRITICAL APPLICATIONS"). CIRRUS PRODUCTS ARE NOT DESIGNED, AUTHORIZED OR WARRANTED FOR USE IN PRODUCTS SURGICALLY IMPLANTED INTO THE BODY, AUTOMOTIVE SAFETY OR SECURITY DEVICES, LIFE SUPPORT PRODUCTS OR OTHER CRITICAL APPLICATIONS. INCLUSION OF CIRRUS PRODUCTS IN SUCH APPLICATIONS IS UNDERSTOOD TO BE FULLY AT THE CUSTOMER'S RISK AND CIRRUS DISCLAIMS AND MAKES NO WARRANTY, EXPRESS, STATUTORY OR IMPLIED, INCLUDING THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR PARTICULAR PURPOSE, WITH REGARD TO ANY CIRRUS PRODUCT THAT IS USED IN SUCH A MANNER. IF THE CUSTOMER OR CUSTOMER'S CUSTOMER USES OR PERMITS THE USE OF CIRRUS PRODUCTS IN CRITICAL APPLICATIONS, CUSTOMER AGREES, BY SUCH USE, TO FULLY INDEMNIFY CIRRUS, ITS OFFICERS, DIRECTORS, EMPLOYEES, DISTRIBUTORS AND OTHER AGENTS FROM ANY AND ALL LIABILITY, INCLUDING ATTORNEYS' FEES AND COSTS, THAT MAY RESULT FROM OR ARISE IN CONNECTION WITH THESE USES.

Cirrus Logic, Cirrus, and the Cirrus Logic logo designs are trademarks of Cirrus Logic, Inc. All other brand and product names in this document may be trademarks or service marks of their respective owners.

Windows, Windows XP, Windows 2000, and Windows NT are trademarks or registered trademarks of Microsoft Corporation.

Intel and Pentium are registered trademarks of Intel Corporation.

SPI is a trademark of Motorola, Inc.

I²C (I2C) is a registered trademark of Philips Semiconductor Corporation.

USBXpress is a registered trademark of Silicon Laboratories, Inc.

TABLE OF CONTENTS

REVISION HISTORY	2
1. INITIAL SETUP	5
1.1 Kit Contents	5
1.2 Hardware Setup	5
1.2.1 Default Jumper Settings	6
1.2.2 Default DIP Switch Settings	8
1.3 Software Setup	9
1.3.1 PC Requirements	9
1.3.2 Seismic Evaluation Software Installation	9
1.3.3 USBXpress Driver Installation	9
1.3.4 Launching the Seismic Evaluation Software	10
1.4 Self-testing CDB5374	11
1.4.1 Noise test	11
1.4.2 Distortion Test	12
2. HARDWARE DESCRIPTION	13
2.1 Block Diagram	13
2.2 Analog Hardware	14
2.2.1 Analog Inputs	14
2.2.2 Differential Amplifiers	16
2.2.3 Delta-Sigma Modulators	17
2.2.4 Delta-Sigma Test DAC	18
2.2.5 Voltage Reference	19
2.3 Digital Hardware	20
2.3.1 Digital Filter	20
2.3.2 Interface CPLD	22
2.3.3 Digital Control Signals	24
2.3.4 Microcontroller	24
2.3.5 Phase Locked Loop	26
2.3.6 RS-485 Telemetry	28
2.3.7 UART Connection	29
2.3.8 External Connector	30
2.4 Power Supplies	30
2.4.1 Analog Voltage Regulators	30
2.4.2 Digital Voltage Regulators	31
2.5 PCB Layout	32
2.5.1 Layer Stack	32
2.5.2 Differential Pairs	32
2.5.3 Bypass Capacitors	33
2.5.4 Dual Row Headers	34
3. SOFTWARE DESCRIPTION	35
3.1 Menu Bar	35
3.2 <i>About</i> Panel	36
3.3 <i>Setup</i> Panel	37
3.3.1 USB Port	38
3.3.2 Digital Filter	39
3.3.3 Analog Front End	40
3.3.4 Test Bit Stream	40
3.3.5 Gain/Offset	41
3.3.6 Data Capture	42
3.3.7 External Macros	43
3.4 <i>Analysis</i> Panel	44
3.4.1 Test Select	45

3.4.2 Statistics	46
3.4.3 Plot Enable	46
3.4.4 Cursor	47
3.4.5 Zoom	47
3.4.6 Refresh	47
3.4.7 Harmonics	47
3.4.8 Spot Noise	47
3.4.9 Plot Error	47
3.5 Control Panel	48
3.5.1 DF Registers	49
3.5.2 DF Commands	49
3.5.3 SPI	49
3.5.4 Macros	50
3.5.5 GPIO	50
3.5.6 Customize	51
3.5.7 External Macros	51
4. BILL OF MATERIALS	52
5. LAYER PLOTS	54
6. SCHEMATICS	62

LIST OF FIGURES

Figure 1. CDB5374 Block Diagram	13
Figure 2. RC Filter External Components	16
Figure 3. CPLD Default Signal Assignments	23
Figure 4. Differential Pair Routing	32
Figure 5. Quad Group Routing	33
Figure 6. Bypass Capacitor Placement	33
Figure 7. Dual-row Headers with Shorts	34

LIST OF TABLES

Table 1. Analog Inputs Default Jumper Settings	6
Table 2. VREF, SPI, SYNC, RESET Default Jumper Settings	6
Table 3. Power Supplies Default Jumper Settings	7
Table 4. Clock Inputs Default Jumper Settings	7
Table 5. RS-485 Default Jumper Settings	8
Table 6. DIP Switch Default Settings	8
Table 7. Screw Terminal Input Connectors	14

1. INITIAL SETUP

1.1 Kit Contents

The CDB5374 evaluation kit includes:

- CDB5374 Evaluation Board
- USB Cable (A to B)
- Software Download Information Card

The following are required to operate CDB5374, and are not included:

- Bipolar Power Supply with Banana Jack Outputs (+/-12 V @ 300 mA)
- Banana Jack Cables (4x)
- PC Running Windows 2000 or XP with an Available USB Port
- Internet Access to Download the Evaluation Software

1.2 Hardware Setup

To set up the CDB5374 evaluation board:

- Set all jumpers and DIP switches to their default settings (see next sections).
- With power off, connect the CDB5374 power inputs to the power supply outputs.
 - VA- = -12 V
 - VA+ = +12 V
 - GND = 0 V
 - VD = +12 V
- Connect the USB cable between the CDB5374 USB connector and the PC USB port.
- Proceed to the Software Setup section to install the evaluation software and USB driver.

1.2.1 Default Jumper Settings

J27, J227, J327, J427				
CH1, CH2, CH3, CH4 Analog Input Selections				
DAC_OUT+	1	*	*	2 INA+
DAC_OUT-	3	*	*	4 INA-
DAC_OUT-	5	-----		6 INB-
DAC_OUT+	7	-----		8 INB+
DAC_BUF+	9	-----		10 INA+
DAC_BUF-	11	-----		12 INA-
DAC_BUF-	13	*	*	14 INB-
DAC_BUF+	15	*	*	16 INB+
BNC_IN+	17	*	*	18 INA+
BNC_IN-	19	*	*	20 INA-
BNC_IN-	21	*	*	22 INB-
BNC_IN+	23	*	*	24 INB+

Table 1. Analog Inputs Default Jumper Settings

J519, J19, J20			
Voltage Reference Jumpers			
VREF+	1	-----	2
VREF-	3	-----	4

J43				
SPI Chip Select Input				
SSI	1	-----	2	SSI
EECS	3	*	*	4 SSI

J56				
SYNC Source Selection				
SYNC_IO	1	-----	2	SYNC

J58				
RESET Source Selection				
RST_PB	1	-----	2	
RST_EXT	3	-----	4	

Table 2. VREF, SPI, SYNC, RESET Default Jumper Settings

J10			
VA- Voltage Selection			
-2.5VA	1	-----	2
GND	3	* *	4
EXT_VA-	5	* *	6

J11			
VA+ Voltage Selection			
+2.5VA	1	-----	2
+5VA	3	* *	4
EXT_VA+	5	* *	6

J12			
VD Input Voltage Source			
EXT_VA+	1	* *	2
EXT_VD	3	-----	4

J13			
VCORE Input Voltage Source			
EXT_VA+	1	* *	2
EXT_VD	3	-----	4

J22			
VD Voltage Selection			
+3.3VD	1	-----	2
EXT_VD	3	* *	4

J21			
VCORE Voltage Selection			
+3.3VD	1	-----	2
+2.5VD	3	* *	4
EXT_VD	3	* *	4

Table 3. Power Supplies Default Jumper Settings

J16			
PLL Input Clock Selection			
32.768 MHz	1	-----	2
16.384 MHz	3	* *	4
8.192 MHz	5	* *	6
4.096 MHz	7	* *	8
2.048 MHz	9	* *	10
1.024 MHz	11	* *	12

J17, J18			
CPLD, Microcontroller Input Clock Selections			
32.768 MHz	1	-----	2
16.384 MHz	3	* *	4
8.192 MHz	5	* *	6
4.096 MHz	7	* *	8
2.048 MHz	9	* *	10
1.024 MHz	11	* *	12
CLK_EXT	13	* *	14
	15	* *	16

Table 4. Clock Inputs Default Jumper Settings

J15				
I2C Data				
SDA+	1	*	*	2
SDA-	3	*	*	4
SDA	5	*	*	6
GND	7	*	*	8

J14				
I2C Clock				
SCL+	1	*	*	2
SCL-	3	*	*	4
SCL	5	*	*	6
GND	7	*	*	8

J23				
I2C Clock Driver Enable				
GND	1	-----		2
VD	3	*	*	4

J24				
Clock Source				
CLK+	1	*	*	2
CLK-	3	*	*	4
CLK_I/O	5	*	*	6
GND	7	*	*	8

J25				
Sync Source				
SYNC+	1	*	*	2
SYNC-	3	*	*	4
SYNC_I/O	5	*	*	6
GND	7	*	*	8

J33				
Clock Driver Enable				
GND	1	-----		2
VD	3	*	*	4

J34				
Sync Driver Enable				
GND	1	-----		2
VD	3	*	*	4

Table 5. RS-485 Default Jumper Settings

1.2.2 Default DIP Switch Settings

S5				
* = down, - = up				
BOOT	1	*	-	2
	3	*	-	4
LGND	5	*	-	6
OFST	7	-	*	8

Table 6. DIP Switch Default Settings

1.3 Software Setup

1.3.1 PC Requirements

The PC hardware requirements for the Cirrus Seismic Evaluation system are:

- *Windows XP®*, *Windows 2000™*, *Windows NT®*
- *Intel® Pentium® 600MHz or higher microprocessor*
- *VGA resolution or higher video card*
- *Minimum 64MB RAM*
- *Minimum 40MB free hard drive space*

1.3.2 Seismic Evaluation Software Installation

Important: For reliable USB communication, the USBXpress® driver must be installed after the Seismic Evaluation Software installation but **before** launching the application. The USBXpress driver files are included in a sub-folder as part of the installation.

To install the Cirrus Logic Seismic Evaluation Software:

- Go to the Cirrus Logic Industrial Software web page (<http://www.cirrus.com/industrialsoftware>). Click the link for “*Cirrus Seismic Evaluation GUI*” to get to the download page and then click the link for “*Cirrus Seismic Evaluation GUI Release Vxx*” (xx indicates the version number).
- Read the software license terms and click “*Accept*” to download the “*SeismicEvalGUI_vxx.zip*” file to any directory on the PC.
- Unzip the downloaded file to any directory and a “*Distribution\Volume1*” sub-folder containing the installation application will automatically be created.
- Open the “*Volume1*” sub-folder and run “*setup.exe*”. If the Seismic Evaluation Software has been previously installed, the uninstall wizard will automatically remove the previous version during install.
- Follow the instructions presented by the Cirrus Seismic Evaluation Installation Wizard. The default installation location is “*C:\Program Files\Cirrus Seismic Evaluation*”.

An application note, AN271 - *Cirrus Seismic Evaluation GUI Installation Guide*, is available from the Cirrus Logic web site with step-by-step instructions on installing the Seismic Evaluation Software.

1.3.3 USBXpress Driver Installation

Important: For reliable USB communication, the USBXpress driver must be installed after the Seismic Evaluation Software installation but **before** launching the application. The USBXpress driver files are included in a sub-folder as part of the installation.

The Cirrus Logic Seismic Evaluation Software communicates with CDB5374 via USB using the USBXpress driver from Silicon Laboratories (<http://www.silabs.com>). For convenience, the USBXpress driver files are included as part of the installation package.

To install the USBXpress driver (after installing the Seismic Evaluation Software):

- Connect CDB5374 to the PC through an available USB port and apply power. The PC will detect

CDB5374 as an unknown USB device.

- If prompted for a USB driver, skip to the next step. If not, using Windows Hardware Device Manager go to the properties of the unknown USB API device and select “*Update Driver*”.
- Select “*Install from a list or specific location*”, then select “*Include this location in the search*” and then browse to “*C:\Program Files\Cirrus Seismic Evaluation\Driver*”. The PC will recognize and install the USBXpress device driver.
- After driver installation, cycle power to CDB5374. The PC will automatically detect it and add it as a USBXpress device in the Windows Hardware Device Manager.

An application note, AN271 - *Cirrus Seismic Evaluation GUI Installation Guide*, is available from the Cirrus Logic web site with step-by-step instructions on installing the USBXpress driver.

1.3.4 Launching the Seismic Evaluation Software

Important: For reliable USB communication, the USBXpress driver must be installed after the Seismic Evaluation Software installation but **before** launching the application. The USBXpress driver files are included in a sub-folder as part of the installation.

To launch the Cirrus Seismic Evaluation Software, go to:

- *Start ⇒ Programs ⇒ Cirrus Seismic Evaluation ⇒ Cirrus Seismic Evaluation*

or:

- *C:\Program Files\Cirrus Seismic Evaluation\SeismicGUI.exe*

For the most up-to-date information about the software, please refer to its help file:

- Within the software: *Help ⇒ Contents*

or:

- *C:\Program Files\Cirrus Seismic Evaluation\SEISMICGUI.HLP*

1.4 Self-testing CDB5374

Noise and distortion self-tests can be performed once hardware and software setup are complete.


First, initialize the CDB5374 evaluation system:

- Launch the evaluation software and apply power to CDB5374.
- Click 'OK' on the **About** panel to get to the **Setup** panel.
- On the **Setup** panel, select *Open Target* on the **USB Port** sub-panel.
- When connected, the *Board Name* and *MCU code version* will be displayed.

1.4.1 Noise test

Noise performance of the measurement channel can be tested as follows:

- Set the controls on the **Setup** panel to match the picture:



The screenshot shows the 'Cirrus Seismic Evaluation V2.6' software window with the 'Setup!' menu item selected. The interface is divided into several panels:


- USB PORT:** Includes a 'CLOSE TARGET' button, 'Board Name' (CDB5374 RevA), 'MCU code version' (V1.5), 'Reset Target', and 'Flash MCU' buttons.
- DIGITAL FILTER:** Includes 'Channel Set' (4 Channel), 'Output Rate' (500 SPS), 'Output Filter' (FIR2 Output), 'FIR Coeff' (Linear Phase), 'IIR Coeff' (3Hz@500SPS), 'Filter Clock' (16.384 MHz), 'MCLK Rate' (1.024 MHz), and a 'CONFIGURE' button.
- ANALOG FRONT END:** Includes 'Amp Mux' (TERM), 'Gain' (x1), 'DAC Mode' (PWDN), and 'SW' (Disable All).
- TEST BIT STREAM:** Includes 'DAC Quick Set', 'Mode' (Select Mode), 'Freq' (Select Freq), 'Gain' (Select Gain), 'Interpolation' (0), 'Clock Rate' (0), 'Gain Factor' (0), 'Sync' (Disabled), and 'Loopback' (Disabled). There is an 'ENABLE TBS' button.
- GAIN / OFFSET:** Includes a table for Gain and Offset for CH 1, CH 2, CH 3, and CH 4, all set to 0. It also includes 'USEGR' (Disabled), 'USEOR' (Disabled), 'ORCAL' (Disabled), and 'EXP[4:0]' (0). There are 'READ' and 'WRITE' buttons.
- DATA CAPTURE:** Includes 'Total Samples' (4096), 'Window' (Hodie (7-term)), 'Bandwidth Limit (Hz)' (0), 'Full Scale Code' (5B3A71), 'Full Scale Voltage' (5.00), 'Total Captures' (1), 'Capture Data' (CAPTURE button), 'Remaining Captures' (0), and 'Skip Samples' (100).

At the bottom of the window, there are buttons labeled M1 through M8.

- Once the **Setup** panel is set, select *Configure* on the **Digital Filter** sub-panel.
- After digital filter configuration is complete, click *Capture* to collect a data record.
- Once the data record is collected, the **Analysis** panel is automatically displayed.
- Select *Noise FFT* from the *Test Select* control to display the calculated noise statistics.
- Verify the noise performance (S/N) is 121 dB or better.

1.4.2 Distortion Test

- Set the controls on the **Setup** panel to match the picture:



The screenshot shows the Cirrus Seismic Evaluation V2.6 software interface. The **Setup** panel is active, displaying various configuration options for the digital filter and analog front end. The **Digital Filter** sub-panel is selected, showing settings for Channel Set (4 Channel), Output Rate (500 SPS), Output Filter (FIR2 Output), FIR Coeff (Linear Phase), IIR Coeff (3Hz@500SPS), Filter Clock (16.384 MHz), and MCLK Rate (1.024 MHz). The **Configure** button is highlighted. The **Analog Front End** sub-panel shows Amp Mux (INB), Gain (x1), DAC Mode (OUT only), and SW (Disable All). The **Test Bit Stream** sub-panel shows DAC Quick Set (Sine), Mode (Sine), Freq (31.25 Hz), Gain (0 dB), Interpolation (7), Clock Rate (4), Gain Factor (4B8F2), Sync (Disabled), and Loopback (Disabled). The **Gain / Offset** sub-panel shows Gain and Offset settings for CH 1, CH 2, CH 3, and CH 4, all set to 0. The **Data Capture** sub-panel shows Total Samples (4096), Window (Hodie (7-term)), Bandwidth Limit (Hz) (0), Full Scale Code (5B3A71), Full Scale Voltage (5.00), Total Captures (1), and a **Capture** button. The **Remaining Captures** is 0 and **Skip Samples** is 100. The **File** menu is open, showing options like Setup!, Analysis!, Control!, DataCapture!, and Help.

- Once the **Setup** panel is set, select *Configure* on the **Digital Filter** sub-panel.
- After digital filter configuration is complete, click *Capture* to collect a data record.
- Once the data record is collected, the **Analysis** panel is automatically displayed.
- Select *Signal FFT* from the *Test Select* control to display the calculated signal statistics.
- Verify the distortion performance (S/D) is 108 dB or better.

2. HARDWARE DESCRIPTION

2.1 Block Diagram




Figure 1. CDB5374 Block Diagram

Major blocks of the CDB5374 evaluation board include:

- **CS5374 Dual Amplifier & $\Delta\Sigma$ Modulator (2x)**
- **CS5376A Quad Digital Filter**
- **CS4373A $\Delta\Sigma$ Test DAC**
- **Precision Voltage Reference**
- **Interface CPLD**
- **Microcontroller with USB**
- **Phase Locked Loop**
- **RS-485 Transceivers**
- **Voltage Regulators**

2.2 Analog Hardware

2.2.1 Analog Inputs

2.2.1.1 External Inputs - INA, INB, BNC

External signals into CDB5374 are typically from piezoelectric hydrophones, which are high-impedance sensors optimized to measure pressure in marine applications.

External signals connect to CDB5374 through screw terminals on the left side of the PCB. For each channel (CH1, CH2, CH3, CH4), these screw terminals make connections to two external differential inputs, INA and INB. In addition, GND and GUARD connections are provided for connecting sensor cable shields, if present.

Signal Input	Screw Terminal
CH1 INA	J32
CH1 INB	J41
CH2 INA	J232
CH2 INB	J241
CH3 INA	J332
CH3 INB	J341
CH4 INA	J432
CH4 INB	J441

Table 7. Screw Terminal Input Connectors

2.2.1.2 GUARD Output, GND Connection

The CS5374 hydrophone amplifier provides a GUARD signal output designed to actively drive the cable shield of a high impedance sensor with the common mode voltage of the sensor differential signal. This GUARD output on the cable shield minimizes leakage by minimizing the voltage differential between the sensor signal and the cable shield.

The GUARD signal is output to screw terminals on the left side of the PCB and a separate GND connection screw terminal for each channel is also provided if a ground connection to the sensor cable shield is preferred.

2.2.1.3 Internal Inputs - DAC_OUT, DAC_BUF

The CS4373A test DAC has two high-performance differential test outputs, a precision output (DAC_OUT) and a buffered output (DAC_BUF). These test outputs can be connected to the INA or INB inputs of any channel through the input selection jumpers.

By default, CDB5374 is populated with passive RC filter components on the INA inputs, and no filter components on the INB inputs (though the component footprints are present on the INB inputs). Because the CS4373A precision output will not tolerate significant loading, on CDB5374 the DAC_OUT signal should only jumper to the INB inputs. The CS4373A buffered outputs are less sensitive to the RC filter load and DAC_BUF can be jumper-ed to either the INA or INB inputs.

2.2.1.4 Input Protection

Sensor inputs must have circuitry to protect the analog electronics from voltage spikes as hydrophones can produce large voltage spikes if located near an air gun source.

Discrete switching diodes quickly clamp the analog inputs to the power supply rails when the input voltage spikes. These diodes are reverse biased in normal operation and have low reverse bias leakage and capacitance characteristics to maintain high linearity on the analog inputs.

Specification	Value
Dual Series Switching Diode - ON Semiconductor	BAV99LT1
Surface Mount Package Type	SOT-23
Non-Repetitive Peak Forward Current (1 μ s, 1 ms, 1 s)	2.0 A, 1.0 A, 500 mA
Reverse Bias Leakage (25 C to 85 C)	0.004 μ A - 0.4 μ A
Reverse Bias Capacitance (0 V to 5 V)	1.5 pF - 0.54 pF

2.2.1.5 Input RC Filters

Following the diode clamps is an RC filter network that bandwidth limits the sensor inputs into the amplifiers to “chop the tops off” residual voltage spikes not clamped by the discrete diodes. In addition, all Cirrus Logic component ICs have built in ESD protection diodes guaranteed to 2000 V HBM / 200 V MM (JEDEC standard). The small physical size of these ESD diodes restricts their current capacity to 10 mA.

For marine applications that use the CS3302A amplifier, the inherent capacitance of the piezoelectric sensor is combined with large resistors to create an analog high-pass RC filter to eliminate the low-frequency components of ocean noise.

Marine Differential Filter Specification	Value
Hydrophone Group Capacitance	128 nF \pm 10%
Differential Resistance	412 k Ω + 2 k Ω = 400 Ω
-3 dB Corner @ 6 dB/octave	40 kHz \pm 10%

2.2.1.6 Common Mode Bias

Differential analog signals into the CS3301A/02A amplifiers are required to be biased to the center of the power supply voltage range, which for bipolar supplies is near ground potential. This common mode bias voltage is created by buffering the voltage reference, which is nominally +2.5 V relative to the VA- power supply.

Resistors to create the common mode bias are selected based on the sensor impedance and may need to be modified from the CDB5374 defaults depending on the sensor to be used. Refer to the recommended operating bias conditions for the selected sensor, which are available from the sensor manufacturer.

Specification	Value
Hydrophone Sensor Bias Resistance	18 M Ω 18 M Ω = 9 M Ω

2.2.2 Differential Amplifiers

The CS5374 amplifiers act as a low-noise gain stage for internal or external differential analog signals.

Analog Signals	Description
INA	Sensor analog input
INB	Test DAC analog input
OUT	Analog outputs
GUARD	Amplifier guard output

Digital Signals	Description
MUX[0..1]	Input mux selection (register bits)
GAIN[0..2]	Gain range selection (register bits)
PWDN	Power down mode enable (register bit)

2.2.2.1 GUARD Output

The CDB5374 hydrophone amplifiers are not chopper stabilized (with 1/f noise typically buried below the low-frequency ocean noise) to achieve very high input impedance. To minimize leakage from high-impedance sensors connected to the CS5374 amplifier, a GUARD signal output can actively drive a sensor cable shield with the common mode voltage of the sensor signal.

2.2.2.2 Analog Outputs - OUT

The analog outputs of the CS5374 differential amplifiers are externally split into rough-charge and fine-charge signals for input to the $\Delta\Sigma$ modulators. Analog signal traces out of the CS5374 amplifiers and into the modulators are 4-wire INR+ / INF+ / INF- / INR- quad groups, and are routed with INF+ and INF- as a traditional differential pair and INR+ and INR- as guard traces outside the respective INF+ and INF- traces.




Figure 2. RC Filter External Components

2.2.2.3 Anti-alias RC Filters

The CS5374 $\Delta\Sigma$ modulator is 4th order and high-frequency input signals can cause instability. Simple single-pole anti-alias RC filters are required between the amplifier outputs and the modulator inputs to bandwidth limit analog signals into the modulator.

The amplifier outputs are connected to external 680 Ω series resistors and a differential anti-alias RC filter is created by connecting 20 nF of high-linearity differential capacitance (2x 10 nF C0G) between each half of the rough and fine signals.

2.2.3 Delta-Sigma Modulators

A CS5374 $\Delta\Sigma$ modulator performs the A/D function for a differential analog input signal from the amplifier. The digital output is an oversampled $\Delta\Sigma$ bit streams.

Analog Signals	Description
INR1, INF1	Channel 1 analog rough / fine inputs
INR2, INF2	Channel 2 analog rough / fine inputs
VREF	Voltage reference analog inputs

Digital Signals	Description
MDATA[1..2]	Modulator delta-sigma data outputs
MFLAG[1..2]	Modulator over-range flag outputs
MCLK	Modulator clock input
MSYNC	Modulator synchronization input
PWDN[1..2]	Power down mode enable (register bits)
OFST	Internal offset enable (register bits)

2.2.3.1 Rough-Fine Inputs - INR, INF

The modulator analog inputs are separated into rough and fine signals, each of which has an anti-alias RC filter to limit the signal bandwidth into the modulator inputs.

2.2.3.2 Offset Enable - OFST

The CS5374 $\Delta\Sigma$ modulator requires differential offset to be enabled to eliminate idle tones for a terminated input. OFST is enabled by default in the CS5374 registers.

2.2.4 Delta-Sigma Test DAC

The CS4373A DAC creates differential analog signals for system tests. Multiple test modes are available and their use is described in the CS4373A data sheet.

Analog Signals	Description
OUT	Precision differential analog output
BUF	Buffered differential analog output
CAP	Capacitor connection for internal anti-alias filter
VREF	Voltage reference analog inputs

Digital Signals	Description
TDATA	Delta-sigma test data input
MCLK	Clock input
SYNC	Synchronization input
MODE[0..2]	Test mode selection
ATT[0..2]	Attenuation range selection

2.2.4.1 Precision Output - DAC_OUT

The CS4373A test DAC has a precision output (DAC_OUT) that is routed to the input selection jumpers for each channel. This output is sensitive to loading, and on CDB5374 should only be jumper-ed into the INB inputs which do not have passive RC filter components installed. The input impedance of the INB amplifier inputs are high enough that the precision output can be directly connected to the INB inputs of all channels simultaneously.

2.2.4.2 Buffered Output - DAC_BUF

The CS4373A test DAC has a buffered output (DAC_BUF) that is routed to the input selection jumpers for each channel. This output is less sensitive to loading than the precision outputs, and can be jumper-ed into either the INA or INB inputs without affecting performance. The buffered output can also drive a sensor attached to the input screw terminals, provided the sensor meets the impedance requirements specified in the CS4373A data sheet.

2.2.5 Voltage Reference

A voltage reference on CDB5374 creates a precision voltage from the regulated analog supplies for the modulator and test DAC VREF inputs. Because the voltage reference output is generated relative to the negative analog power supply, VREF+ is near GND potential for bipolar power supplies.

Specification	Value
Precision Reference - Linear Tech	LT1019AIS8-2.5
Surface Mount Package Type	SO-8
Output Voltage Tolerance	+/- 0.05%
Temperature Drift	10 ppm / degC
Quiescent Current	0.65 mA
Output Voltage Noise, 10 Hz - 1 kHz	4 ppm _{RMS}
Ripple Rejection, 10 Hz - 200 Hz	> 100 dB

2.2.5.1 VREF_MOD12, VREF_MOD34, VREF_DAC

The voltage reference output is provided to the CS5374 $\Delta\Sigma$ modulators and the CS4373A test DAC through separate low-pass RC filters. By separately filtering the voltage reference for each device, signal-dependent sampling of VREF by one device is isolated from other devices. Each voltage reference signal is routed as a separate differential pair from the large RC filter capacitor to control the sensitive VREF source-return currents and keep them out of the ground plane. In addition to the RC filter function, the 100 uF filter capacitor provides a large charge well to help settle voltage reference sampling transients.

2.2.5.2 Common Mode Bias

A buffered version of the voltage reference is created as a low-impedance common mode bias source for the analog signal inputs. The bias resistors connected between the buffered voltage reference and each analog signal input half depends on the sensor type and should be modified to match the sensor manufacturer recommendations.

2.3 Digital Hardware

2.3.1 Digital Filter

The CS5376A quad digital filter performs filtering and decimation of four delta-sigma bit streams from the CS5374 modulators. It also creates a delta-sigma bit stream output to create analog test signals in the CS4373A test DAC.

The CS5376A requires several control signal inputs from the external system.

Control Signals	Description
RESETz	Reset input, active low
BOOT	Microcontroller / EEPROM boot mode select
TIMEB	Time Break input, rising edge triggered
CLK	Master clock input, 32.768 MHz
SYNC	Master synchronization input, rising edge triggered

Configuration is completed through the SPI 1 port.

SPI1 Signals	Description
SS1z	Serial chip select input, active low
SCK1	Serial clock input
MISO	Master in / slave out serial data
MOSI	Master out / slave in serial data
SINTz	Serial acknowledge output, active low
SSOz	Serial chip select output (unused on CDB5374)

Data is collected through the SD port.

SD Port Signals	Description
SDTKI	Token input to initiate an SD port transaction
SDRDYz	Data ready acknowledge, active low
SDCLK	Serial clock input
SDDAT	Serial data output
SDTKO	Token output (unused on CDB5374)

Modulator $\Delta\Sigma$ data is input through the modulator interface.

Modulator Signals	Description
MCLK	Modulator clock output
MCLK/2	Modulator clock output, half-speed
MSYNC	Modulator synchronization output
MDATA[1..4]	Modulator delta-sigma data inputs
MFLAG[1..4]	Modulator over-range flag inputs

Test DAC $\Delta\Sigma$ data is generated by the test bit stream generator.

Test Bit Stream Signals	Description
TBSDATA	Test DAC delta-sigma data output
TBSClk	Test DAC clock output (unused on CDB5374)

Amplifier, modulator, and test DAC digital pins are controlled by the GPIO port.

GPIO Signals	Description
GPIO[0..1]:MUX[0..1]	Amplifier input mux selection
GPIO[2..4]:GAIN[0..2]	Amplifier gain / test DAC attenuation
GPIO[5..7]:MODE[0..2]	Test DAC mode selection
GPIO[8]:PWDN	Amplifier / modulator power down
GPIO[9..10]	Available general purpose input/output
GPIO[11]:EECS	Chip select for boot EEPROM

The secondary serial port (SPI 2) and boundary scan JTAG port are also on CDB5374.

SPI2 Signals	Description
SCK2	Serial clock output
SO	Serial data output
SI[1..4]	Serial data inputs

JTAG Signals	Description
TRSTz	JTAG reset (unused on CDB5376)
TMS	JTAG test mode select (unused on CDB5376)
TCK	JTAG test clock input (unused on CDB5376)
TDI	JTAG test data input (unused on CDB5376)
TDO	JTAG test data output (unused on CDB5376)

2.3.1.1 MCLK Conversion to ACLK

The CS5376A digital filter creates the analog sampling clock used by the CS5374 $\Delta\Sigma$ modulators and CS4373A test DAC (MCLK). This clock has strict jitter requirements to guarantee the accuracy of analog-to-digital and digital-to-analog conversion, and so is carefully routed between the digital filter and modulators/test DAC.

2.3.1.2 Configuration - SPI1 Port

Configuration of the CS5376A digital filter is through the SPI 1 port by the on-board 8051 microcontroller, which receives commands from the PC evaluation software via the USB interface. Evaluation software commands can write/read digital filter registers, specify digital filter coefficients and test bit stream data, and start/stop digital filter operation. Alternately, the digital filter can automatically load configuration information from an on-board serial EEPROM.

Configuration of the digital filter is selected by the BOOT signal from dip switch #1 (S5, #1). By default the BOOT signal is set low (S5, #1 - LO) to indicate configuration information is written by the microcontroller. If BOOT is set high (S5, #1 - HI), the digital filter attempts to automatically read configuration information from the serial EEPROM after reset.

2.3.2 Interface CPLD

A Xilinx CPLD is included on CDB5374 (XCR3128XL-10VQ100I) as an interface between the CS5376A digital filter and the microcontroller. By default the CPLD only passes through the interface signals, but can be reprogrammed to disconnect the on-board 8051 microcontroller and connect to another external microcontroller through the spare dual-row headers. Control signals taken off the CDB5374 board to an external microcontroller should pair with a ground return wire to maintain signal integrity.

Free software tools and an inexpensive hardware programmer for the Xilinx CPLD are available from the internet (<http://www.xilinx.com>). The hardware programmer interfaces with the Xilinx JTAG programming port (J39) on CDB5374. Note that early versions of the Xilinx WebPack tools (7.1i SP1 and earlier) have a bug in the JEDEC programming file for the CPLD included on CDB5374, and WebPack version 7.1i SP2 or later is required.

Included below is the default Verilog HDL file used by CDB5374 inside the interface CPLD. Comparing the input and output definitions of this file with the CPLD schematic pinout should demonstrate how signals are selected and passed through from the microcontroller to the CS5374A digital filter. Several signal connections to the CPLD are not defined in the default HDL file, but are routed to the CPLD on CDB5374 for convenience during custom reprogramming.

```

//////////////////////////////////////////////////////////// cdb5376.v
// MODULE:      CDB5376 top module
//
// FILE NAME:    Top module for connecting CS5376 to C8051F320
// VERSION:      1.0
// DATE:         Jan. 8, 2007
// COPYRIGHT:    Cirrus Logic, Inc.
//
// CODE TYPE:    Register Transfer Level
//
// DESCRIPTION:  This module includes assignments for signals between
//               the serial port of Bismarck and the SLAB micro.
//
////////////////////////////////////////////////////////////

module cdb5376 (
    sck_mc,
    mosi_mc,
    ssi_mc,
    sdtki_mc,
    timeb_mc,
    mi so,
    drdy,
    sddat,
    sync_mc,
    sync_pb,
    timeb_pb,
    reset_pb,
    reset_ext,
    timeb_ext,
    sync_ext,

    mi so_mc,
    drdy_mc,
    sck,
    mosi,
    ssi,
    sdtki,
    timeb,
    sdclk,
    sync,
    reset );

////////////////////////////////////////////////////////////
// input signals
////////////////////////////////////////////////////////////

input sck_mc, mosi_mc, ssi_mc;
input sdtki_mc, timeb_mc;
input mi so, drdy, sddat;
input sync_mc, sync_pb, timeb_pb;
input reset_pb, reset_ext;
input timeb_ext, sync_ext;

////////////////////////////////////////////////////////////
//output signals
////////////////////////////////////////////////////////////

output mi so_mc, drdy_mc;
output sck, mosi, ssi;
output sdtki, timeb, sdclk;

////////////////////////////////////////////////////////////
// signal assignments
////////////////////////////////////////////////////////////

assign sck = ssi_mc? 1'bz: sck_mc;
assign sdclk = drdy? 1'bz: sck_mc;
assign mosi = ssi_mc? 1'bz: mosi_mc;
assign ssi = ssi_mc? 1'bz: ssi_mc;
assign sdtki = sdtki_mc;
assign drdy_mc = drdy;
assign mi so_mc = (drdy)? mi so: sddat;

assign timeb = timeb_mc | timeb_pb | timeb_ext;
assign sync = sync_mc | sync_pb | sync_ext;
assign reset = reset_pb & reset_ext;

endmodule

```

Figure 3. CPLD Default Signal Assignments

2.3.3 Digital Control Signals

The reset, synchronization, and timebreak signals to the CS5376A digital filter can be generated by push buttons, received from external inputs or generated by the on-board microcontroller. By default, the push button RESET_PB, SYNC_PB, and TIMEB_PB signals are connected through the interface CPLD to the CS5376A digital filter RESET, SYNC, and TIMEB inputs.

A four-position DIP switch on CDB5374 (S5) sets static digital control signals not normally changed during operation. The BOOT signal (S5, #1) controls how the CS5374A digital filter receives configuration data, either from a microcontroller or serial EEPROM.

2.3.4 Microcontroller

Included on CDB5374 is an 8051-type microcontroller with integrated hardware SPI and USB interfaces. This C8051F320 microcontroller is a product of Silicon Laboratories (<http://www.silabs.com>). Key features of the C8051F320 microcontroller are:

8051 compatibility – uses industry-standard 8051 software development tools

In-circuit debugger – software development on the target hardware

Internal memory – 16k flash ROM and 2k static RAM included on-chip

Multiple serial connections – SPI, USB, I²C, and UART

High performance – 25 MIPS maximum

Low power – 0.6 mA @ 1 MHz w/o USB, 9 mA @ 12 MHz with USB

Small size – 32 pin LQFP package, 9mm x 9mm

Industrial temperature – full performance (including USB) from -40 C to +85 C

Internal temperature sensor – with range violation interrupt capability

Internal timers – four general purpose plus one extended capability

Power on reset – can supply a reset signal to external devices

Analog ADC – 10-bit, 200 kSps SAR with internal voltage reference

Analog comparators – arbitrary high/low voltage compare with interrupt capability

The exact use of these features is controlled by embedded firmware.

C8051F320 has dedicated pins for power and the USB connection, plus 25 general-purpose I/O pins that connect to the various internal resources through a programmable crossbar. Hardware connections on CDB5374 limit how the blocks can operate, so the port mapping of microcontroller resources is detailed below.

Pin #	Pin Name	Assignment	Description
1	P0.1	SDTKI_MC	Token to start CS5376A data transaction
2	P0.0	SYNC_IO	SYNC signal from RS-485
3	GND		Ground
4	D+		USB differential data transceiver
5	D-		USB differential data transceiver
6	VDD		+3.3 V power supply input
7	REGIN		+5 V power supply input (unused on CDB5374)
8	VBUS		USB voltage sense input

Pin #	Pin Name	Assignment	Description
9	/RST	RESETz	Power on reset output, active low
	C2CK		Clock input for debug interface
10	P3.0	GPIO	General purpose I/O
	C2D		Data in/out for debug interface
11	P2.7	AIN-	ADC input
12	P2.6	AIN+	ADC input
13	P2.5	CPLD3_MC	General Purpose I/O
14	P2.4	CPLD2_MC	General Purpose I/O
15	P2.3	CPLD1_MC	General Purpose I/O
16	P2.2	CPLD0_MC	General Purpose I/O

Pin #	Pin Name	Assignment	Description
17	P2.1	TIMEB_MC	Time Break signal to CS5376A
18	P2.0	SYNC_MC	SYNC signal to CS5376A
19	P1.7	BYP_EN	I2C bypass switch control
20	P1.6	SDA_DE	I2C data driver enable
21	P1.5	SCL	I2C clock in/out
22	P1.4	SDA	I2C data in/out
23	P1.3	SSI_MCz	SPI chip select output, active low
24	P1.2	MOSI_MC	SPI master out / slave in

Pin #	Pin Name	Assignment	Assignment
25	P1.1	MISO_MC	SPI master in / slave out
26	P1.0	SCK1_MC	SPI serial clock
27	P0.7		Internal VREF bypass capacitors
28	P0.6	SINT_MCz	Serial acknowledge from CS5376A, active low
29	P0.5	RX	UART receiver
30	P0.4	TX	UART transmitter
31	P0.3	CLOCK_MC	External clock input
32	P0.2	SDRDY_MCz	Data ready acknowledge from CS5376A, active low

Many connections to the C8051F320 microcontroller are inactive by default, but are provided for convenience during custom reprogramming. Listed below are the default active connections to the microcontroller and how they are used.

2.3.4.1 SPI Interface

The microcontroller SPI interface communicates with the CS5376A digital filter to write/read configuration information from the SPI 1 port and collect conversion data from the SD port. Detailed information about interfacing to the digital filter SPI 1 and SD ports can be found in the CS5376A data sheet.

The hardware connection of the microcontroller MISO_MC pin is selected automatically within the interface CPLD depending on the state of the digital filter SDRDYz pin. By default, SDRDYz is high and the CS5376A SPI 1 port MISO pin is connected to the microcontroller MISO_MC pin, but when conversion data becomes available from the CS5376A SD port, SDRDYz goes low and the SDDAT pin is connected instead.

2.3.4.2 USB Interface

The microcontroller USB interface communicates with the PC evaluation software to receive configuration commands and return collected conversion data. The USB interface uses the Silicon Laboratories API and Windows drivers, which are available free from the internet (<http://www.silabs.com>).

2.3.4.3 Reset Source

By default, the C8051F320 microcontroller receives its reset signal from the RESET_PBz push button.

2.3.4.4 Clock Source

By default, the C8051F320 microcontroller uses an internally generated 12 MHz clock for compatibility with USB standards.

2.3.4.5 Timebreak Signal

By default, the C8051F320 microcontroller sends the TIMEB_MC signal to the digital filter for the first collected sample of a data record. Typically, some number of initial samples are skipped during data collection to ensure the CS5374A digital filters are fully settled, and the timebreak signal is automatically set for the first “real” collected sample.

2.3.4.6 C2 Debug Interface

Through the PC evaluation software, the microcontroller default firmware can be automatically flashed to the latest version without connecting an external programmer. To flash custom firmware, software tools and an inexpensive hardware programmer that connects to the C2 Debug Interface on CDB5374 is available for purchase from Silicon Laboratories (DEBUGADPTR1-USB).

2.3.5 Phase Locked Loop

To make synchronous analog measurements throughout a distributed system, a synchronous system clock is required to be provided to each measurement node. For evaluation testing purposes, a BNC clock

input on CDB5374 can receive a lower-frequency system clock and create a synchronous higher-frequency clock using an on-board PLL.

Specification	Value
Input Clock Frequency	1.024, 2.048, 4.096 MHz 8.192, 16.384, 32.768 MHz
Distributed Clock Synchronization	± 240 ns
Maximum Input Clock Jitter, RMS	1 ns
Specification	Value
PLL Output Clock Frequency	32.768 MHz
Maximum Output Jitter, RMS	300 ps
Oscillator Type	VCXO
Detector Architecture	Phase / Frequency

The expected input clock frequency to the BNC clock input is set by the EXT_CLK jumper (J16). If no external clock is supplied to CDB5374, the PLL will free-run at the nominal output frequency.

The PLL on CDB5374 uses a voltage-controlled crystal oscillator (VCXO) to minimize jitter, and has a single-gate phase/frequency detector and clock divider to minimize size and power.

Specification	Value
Oscillator - Citizen 32.768 MHz VCXO	CSX750VBEL32.768MTR
Surface Mount Package Type	Leadless 6-Pin, 5x7 mm
Supply Voltage, Current	3.3 V, 11 mA
Frequency Stability, Pullability	± 50 ppm, ± 90 ppm
Startup Time	4 ms
Specification	Value
Phase Detector - TI LittleLogic XOR	SN74LVC1G86DBVR
Surface Mount Package Type	SOT23-5
Supply Voltage, Current	3.3 V, 10 μ A
Specification	Value
Loop Filter Integrator - Linear Tech Op-Amp	LT1783IS5
Surface Mount Package Type	SOT23-5
Supply Voltage, Current	3.3 V, 375 μ A
Specification	Value
Clock Divider - TI LittleLogic D-Flop	SN74LVC2G74DCTR
Surface Mount Package Type	SSOP8-199
Supply Voltage, Current	3.3 V, 10 μ A

2.3.6 RS-485 Telemetry

By default, CDB5374 communicates with the PC evaluation software through the microcontroller USB port. Additional hardware is designed onto CDB5374 to use the microcontroller I²C® port as a low-level local telemetry, but it is provided for custom programming convenience only and is not directly supported by the CDB5374 PC evaluation software or microcontroller firmware.

Telemetry signals enter CDB5374 through RS-485 transceivers, which are differential current mode transceivers that can reliably drive long distance communication. Data passes through the RS-485 transceivers to the microcontroller I²C interface and the clock and synchronization inputs.

Specification	Value
RS-485 Transceiver - Linear Tech	LTC1480IS8
Surface Mount Package Type	SOIC-8, 5mm x 6mm
Supply Voltage, Quiescent Current	3.3V, 600 μ A
Maximum Data Rate	2.5 Mbps
Transmitter Delay, Receiver Delay	25 - 80 ns, 30 - 200 ns
Transmitter Current, Full Termination (60 Ω)	25 mA
Transmitter Current, Half Termination (120 Ω)	13 mA

2.3.6.1 CLK, SYNC

Clock and synchronization telemetry signals into CDB5374 are received through RS-485 twisted pairs. These signals are required to be distributed through the external system with minimal jitter and timing skew, and so are normally driven through high-speed bus connections.

Specification	Value
Synchronous Inputs, 2 wires each	CLK \pm , SYNC \pm

Specification	Value
Distributed SYNC Signal Synchronization	\pm 240 ns
Distributed Clock Synchronization	\pm 240 ns
Analog Sampling Synchronization Accuracy	\pm 480 ns

Synchronization of the measurement channel is critical to ensure simultaneous analog sampling across a network. Several options are available for connecting a SYNC signal through the RS-485 telemetry to the digital filter.

A direct connection is made when the SYNC_IO signal is received over the dedicated RS-485 twisted pair and sent directly to the digital filter SYNC pin through jumper J56. The incoming SYNC_IO signal must be synchronized to the network at the transmitter since no local timing adjustment is available.

A microcontroller hardware connection is made when the SYNC_IO signal is received over the dedicated RS-485 twisted pair and detected by a microcontroller interrupt. The microcontroller can then use an internal counter to re-time the SYNC_MC signal output to the digital filter SYNC input as required.

A microcontroller software connection is made when the SYNC_MC signal output is created by the microcontroller on command from the system telemetry. The microcontroller can use an internal counter to re-time the SYNC_MC signal output to the digital filter SYNC input as required.

2.3.6.2 I²C - SCL, SDA, Bypass

The I²C® telemetry connections to CDB5374 transmit and receive through RS-485 twisted pairs. Because signals passing through the transceivers are actively buffered, full I²C bus arbitration and error detection cannot be used (i.e. high-impedance NACK).

The I²C inputs and outputs can be externally wired to create either a daisy chain or a bus-type network, depending how the telemetry system is to be implemented. Analog switches included on CDB5374 can bypass the I²C signals to create a bus network from a daisy chain network following address assignment.

Specification	Value
I2C Inputs, 2 wires each	SCL±, SDA±
I2C Outputs, 2 wires each	BYP_SCL±, BYP_SDA±
I2C Bypass Switch Control	BYP_EN

When CDB5374 is used in a distributed measurement network, each node must have a unique address. This address is used to transmit individual configuration commands and tag the source of returned conversion data. Address assignment can be either dynamic or static, depending how the telemetry system is to be implemented.

Dynamic address assignment uses daisy-chained I²C connections to assign an address to each measurement node. Once a node receives an address, it enables the I²C bypass switches to the next node so it can be assigned an address.

Static address assignment has a serial number assigned to each node during manufacturing. When placed in the network, the location is recorded and a master list of serial numbers vs. location is maintained. Alternately, a location-dependent serial number can be assigned during installation.

2.3.7 UART Connection

A UART connection on CDB5374 provides a low-speed standardized connection for telemetry solutions not using I²C. UART connections are provided for custom programming convenience only and are not directly supported by the CDB5374 PC evaluation software or microcontroller firmware.

Specification	Value
UART Connections, 2 wires each	TX/GND, RX/GND

2.3.8 External Connector

Power supplies and telemetry signals route to a 20-pin double row connector with 0.1" spacing (J26). This header provides a compact standardized connection to the CDB5374 external signals.

Pins	Name	Signal
1, 2	CLK+, CLK-	Clock Input
3, 4	SYNC+, SYNC-	Synchronization Input
5, 6	SCL+, SCL-	I2C Clock
7, 8	SDA+, SDA-	I2C Data
9, 10	BYP_SDA+, BYP_SDA-	I2C Data Bypass
11, 12	BYP_SCL+, BYP_SCL-	I2C Clock Bypass
13, 14	TX, GND	UART transmit
15, 16	RX, GND	UART receive
17, 18	EXT_VA-, GND	Negative Power Supply
19, 20	EXT_VA+, GND	Positive Power Supply

2.4 Power Supplies

Power is supplied to CDB5374 through banana jacks (J6, J7, J8, J9) or through the external connector (J26). The banana jacks make separate connections to the EXT_VA-, EXT_VA+, GND, and EXT_VD power supply nets, which connect to the analog and digital linear voltage regulator inputs. The external connector makes separate connections only to the EXT_VA-, GND, and EXT_VA+ power supply inputs and it is required to jumper EXT_VA+ to EXT_VD when powering CDB5374 from the external connector.

The EXT_VA-, EXT_VA+ and EXT_VD power supply inputs have zener protection diodes that limit the maximum input voltages to +13 V or -13 V with respect to ground. Each input also has 100 uF bulk capacitance for bypassing and to help settle transients and another 0.01 uF capacitor to bypass high-frequency noise.

2.4.1 Analog Voltage Regulators

Linear voltage regulators create the positive and negative analog power supply voltages to the analog components on CDB5374. These regulate the EXT_VA+ and EXT_VA- power supply inputs to create the VA+ and VA- analog power supplies.

Specification	Value
Positive Analog Power Supply	+2.5 V, +5 V
Low Noise Micropower Regulator - Linear Tech	LT1763CS8
Surface Mount Package Type	SO-8
Load Regulation, -40 C to +85 C	+/- 25 mV
Quiescent Current, Current @ 100 mA Load	40 μ A, 2 mA
Output Voltage Noise, 10 Hz - 100 kHz	20 μ V _{RMS}
Ripple Rejection, DC - 200 Hz	> 50 dB

Specification	Value
Negative Analog Supply, -2.5VA	-2.5 V
Low Noise Micropower Regulator - Linear Tech	LT1964ES5-BYP
Surface Mount Package Type	SOT-23
Load Regulation, -40 C to +85 C	+/- 30 mV
Quiescent Current, Current @ 100 mA Load	30 μ A, 1.3 mA
Output Voltage Noise, 10 Hz - 100 kHz	20 μ V _{RMS}
Ripple Rejection, DC - 200 Hz	> 45 dB

The VA+ and VA- power supplies to the analog components on CDB5374 can be jumper-ed to use regulated bipolar power supplies (+2.5 V, -2.5 V) or unregulated direct connections (EXT_VA+, EXT_VA-). When using direct connections to EXT_VA+ and EXT_VA-, extreme care must be taken not to exceed the maximum specified power supply voltages of the analog components on CDB5374. It is recommended to always use the regulated bipolar analog power supplies for optimal performance.

The VA+ and VA- power supply nets to the analog components on CDB5374 include reverse-biased Schottky diodes to ground to protect against reverse voltages that could latch-up the CMOS analog components. Also included on VA+ and VA- are 100 μ F bulk capacitors for bypassing and to help settle transients plus individual 0.1 μ F bypass capacitors local to the analog power supply pins of each device.

2.4.2 Digital Voltage Regulators

Linear voltage regulators create the positive digital power supply voltages on CDB5374. Jumper options select which external power supply input voltage, EXT_VD or EXT_VA+, is supplied to the digital voltage regulators to create the VD and VCORE power supplies.

Specification	Value
Positive Digital Power Supply	+2.5 V, +3.3 V
Low Noise Micropower Regulator - Linear Tech	LT1763CS8
Surface Mount Package Type	SO-8
Load Regulation, -40 C to +85 C	+/- 25 mV
Quiescent Current, Current @ 100 mA Load	40 μ A, 2 mA
Output Voltage Noise, 10 Hz - 100 kHz	20 μ V _{RMS}
Ripple Rejection, DC - 200 Hz	> 50 dB

The VD and VCORE power supplies on CDB5374 can be jumper-ed to use regulated +3.3 V or +2.5 V power supplies or an unregulated direct connection to EXT_VD. Extreme care must be taken when using a direct connection to EXT_VD not to exceed the maximum specified power supply voltages of the digital components on CDB5374.

Even though the Cirrus Logic components on CDB5374 will tolerate up to 5 V from the direct EXT_VD power supply, other components are specified for +3.3 V operation only and so it is recommended to use only the regulated +3.3 V jumper setting for VD.

The VD and VCORE power supplies on CDB5374 include reverse-biased Schottky diodes to ground to protect against reverse voltages that could latch-up the CMOS components. Also included on VD and VCORE are 100 μ F bulk capacitors for bypassing and to help settle transients plus individual 0.1 μ F bypass capacitors local to the digital power supply pins of each device.

2.5 PCB Layout

2.5.1 Layer Stack

CDB5374 layers 1 and 2 are dedicated as analog routing layers. All critical analog signal routes are on these two layers. Some CPLD and microcontroller digital routes are also included on these layers away from the analog signal routes.

CDB5374 layer 3 is dedicated for power supply routing. Each power supply net includes at least 100 μ F bulk capacitance as a charge well for settling transient current loads.

CDB5374 layer 4 is a solid ground plane without splits or routing. A solid ground plane provides the best return path for bypassed noise to leave the system. No separate analog ground is required since analog signals on CDB5374 are differentially routed.

CDB5374 layers 5 and 6 are dedicated as digital routing layers.

2.5.2 Differential Pairs

Analog signal routes on CDB5374 are differential with dedicated + and - traces. All source and return analog signal currents are constrained to the differential pair route and do not return through the ground plane. Differential traces are routed together with a minimal gap between them so that noise events affect them equally and are rejected as common mode noise.




Figure 4. Differential Pair Routing

Analog signal connections into the CS5374 amplifiers are 2-wire IN+ and IN- differential pairs, and are routed as such. Analog signal connections out of the amplifiers and into the modulators are externally sep-

arated into 4-wire INR+, INF+, INF-, INR- quad groups, and are routed with INF+ and INF- as a traditional differential pair and INR+ and INR- as guard traces outside the respective INF+ and INF- traces.




Figure 5. Quad Group Routing

2.5.3 Bypass Capacitors

Each device power supply pin includes 0.1 μF bypass capacitors placed as close as possible to the pin on the back side of the PCB. Each power supply net includes at least 100 μF bulk capacitance as a charge well for transient current loads.




Figure 6. Bypass Capacitor Placement

2.5.4 Dual Row Headers

To simplify signal tracing on CDB5374, all device pins connect to dual-row headers. These dual-row headers are not populated during board manufacture, but the empty PCB footprint exists on the boards and can be used as test points.




Figure 7. Dual-row Headers with Shorts

The dual-row header pins are shorted on the bottom side of the PCB to pass signals through to the rest of the board. These shorted traces between the dual-row pins can be carefully cut to isolate the device signals from the rest of the PCB to permit wiring changes to the existing route. To restore the previous connection, install a jumper to short across the dual-row pins.

Signals taken off the PCB should not be wired directly from the dual-row header pins, as there is no clean path for the signal return current. Instead, install a connector into the prototyping area and wire the signal and a ground connection to it. Pairing the signal with a ground return before taking it off the PCB will improve signal integrity.

3. SOFTWARE DESCRIPTION


3.1 Menu Bar



The menu bar is always present at the top of the software panels and provides typical *File* and *Help* pull-down menus. The menu bar also selects the currently displayed panel.

Control	Description
File	
Load Data Set	Loads a data set from disk.
Save Data Set	Saves the current data set to disk.
Copy Panel to Clipboard	Copies a bitmap of the current panel to the clipboard.
Print Analysis Screen	Prints the full Analysis panel, including statistics fields.
Print Analysis Graph	Prints only the graph from the Analysis panel.
High Resolution Printing	Prints using the higher resolution of the printer.
Low Resolution Printing	Prints using the standard resolution of the screen.
Quit	Exits the application software.
Setup!	Displays the Setup Panel.
Analysis!	Displays the Analysis Panel.
Control!	Displays the Control Panel.
DataCapture!	Displays the Setup Panel and starts Data Capture.
Help	
Contents	Find help by topic.
Search for help on	Find help by keywords.
About	Displays the About Panel.


3.2 About Panel



The **About** panel displays copyright information for the Cirrus Seismic Evaluation software.

Click **OK** to exit this panel. Select **Help** ⇒ **About** from the menu bar to display this panel.

3.3 Setup Panel



Cirrus Seismic Evaluation V2.6

File Setup! Analysis! Control! DataCapture! Help

USB PORT

CLOSE TARGET

Board Name
CDB5374 RevA

MCU code version
V1.5

Reset Target

Flash MCU

DIGITAL FILTER

Channel Set: 4 Channel

Output Rate: 500 SPS

Output Filter: FIR2 Output

FIR Coeff: Linear Phase

IIR Coeff: 3Hz@500SPS

Filter Clock: 16.384 MHz

MCLK Rate: 1.024 MHz

CONFIGURE

ANALOG FRONT END

Amp Mux: TERM

DAC Mode: PWDN

Gain: x1

SW: Disable All

TEST BIT STREAM

DAC Quick Set

Mode: Select Mode

Freq: Select Freq

Gain: Select Gain

Interpolation: 0

Clock Rate: 0

Gain Factor: 0

Sync: Disabled

Loopback: Disabled

ENABLE TBS

GAIN / OFFSET

	Gain	Offset	
CH 1	0	0	USEGR: Disabled
CH 2	0	0	USEOR: Disabled
CH 3	0	0	ORCAL: Disabled
CH 4	0	0	EXP[4:0]: 0

READ WRITE

DATA CAPTURE

4096 Total Samples

Hodie (7-term) Window

0 Bandwidth Limit (Hz)

5B3A71 Full Scale Code

5.00 Full Scale Voltage

1 Total Captures

Capture Data

CAPTURE

Remaining Captures: 0

Skip Samples: 100

M1 M2 M3 M4 M5 M6 M7 M8

The **Setup** panel initializes the evaluation system to perform data acquisition. It consists of the following sub-panels and controls.

- **USB Port**
- **Digital Filter**
- **Analog Front End**
- **Test Bit Stream**
- **Gain/Offset**
- **Data Capture**
- **External Macros**

3.3.1 USB Port

The **USB Port** sub-panel sets up the USB communication interface between the PC and the target board.

Control	Description
Open Target	Open USB communication to the target board and read the board name and microcontroller firmware version. When communication is established, the name of this control changes to ' <i>Close Target</i> ' and Setup , Analysis and Control panel access becomes available in the menu bar.
Close Target	Disconnects the previously established USB connection. On disconnection, this control changes to ' <i>Open Target</i> ' and the Setup , Analysis and Control panel access becomes unavailable in the menu bar. The evaluation software constantly monitors the USB connection status and automatically disconnects if the target board is turned off or the USB cable is unplugged.
Board Name	Displays the type of target board currently connected.
MCU code version	Displays the version number of the microcontroller code on the connected target board.
Reset Target	Sends a software reset command to the microcontroller.
Flash MCU	Programs the microcontroller code on the target board using the .thx file found in the "C:\Program Files\Cirrus Seismic Evaluation" directory. This feature permits reprogramming of the microcontroller (without using a hardware programmer) when a new version of the MCU code becomes available.

3.3.2 Digital Filter

The **Digital Filter** sub-panel sets up the digital filter configuration options.

By default the **Digital Filter** sub-panel configures the system to use on-chip coefficients and test bit stream data. The on-chip data can be overwritten by loading custom coefficients and test bit stream data from the **Customize** sub-panel on the **Control** panel.

Any changes made under this sub-panel will not be applied to the target board until the **Configure** button is pushed. The **Configure** button writes the new configuration to the target board and then enables the data **Capture** button.

Control	Description
Channel Set	Selects the number of channels that are enabled in the digital filter. For the CS5376A digital filter, from 1 to 4 channels can be enabled.
Output Rate	Selects the output word rate of the digital filter. Output word rates from 4000 SPS to 1 SPS (0.25 mS to 1 S) are available.
Output Filter	Selects the output filter stage from the digital filter. Sinc output, FIR1 output, FIR2 output, IIR 1st order output, IIR 2nd order output, or IIR 3rd order output can be selected. FIR2 output provides full decimation of the modulator data.
FIR Coeff	Selects the on-chip FIR coefficient set to use in the digital filter. Linear phase or minimum phase FIR coefficients can be selected.
IIR Coeff	Selects the on-chip IIR coefficient set to use in the digital filter. Coefficient sets producing a 3 Hz high-pass corner at 2000 SPS, 1000 SPS, 500 SPS, 333 SPS, and 250 SPS can be selected.
Filter Clock	Sets the digital filter internal clock rate. Lower internal clock rates can save power when using slow output word rates.
MCLK Rate	Sets the analog sample clock rate. The CS5374 modulators and CS4373A test DAC typically run with MCLK set to 2.048 MHz.
Configure	Writes all information from the Setup panel to the digital filter. The data Capture button becomes available once the configuration information is written to the target board.

3.3.3 Analog Front End

The **Analog Front End** sub-panel configures the amplifier, modulator, and test DAC pin options. Pin options are controlled through the GPIO outputs of the digital filter.

Any changes made under this sub-panel will not be applied to the target board until the *Configure* button is pushed. The *Configure* button writes the new configuration to the target board and then enables the data *Capture* button.

Control	Description
Amp Mux	Selects the input source for the CS5374 amplifiers. An internal termination, external INA inputs or external INB inputs can be selected.
DAC Mode	Selects the operational mode of the CS4373A test DAC. The test DAC operational modes are AC dual output (OUT&BUF), AC precision output (OUT only), AC buffered output (BUF only), DC common mode output (DC Common), DC differential output (DC Diff), or AC common mode output (AC Common). The test DAC can also be powered down (PWDN) when not in use to save power.
Gain	Sets the amplifier gain range and test DAC attenuation. Amplifier gain and DAC attenuation settings of 1x, 2x, 4x, 8x, 16x, 32x, or 64x can be selected and are controlled together.
Sw	Disabled for CDB5374.

3.3.4 Test Bit Stream

The **Test Bit Stream** sub-panel configures test bit stream (TBS) generator parameters. The digital filter data sheet describes TBS operation and options.

The *DAC Quick Set* controls automatically set the *Interpolation*, *Clock Rate*, and *Gain Factor* controls based on the selected *Mode*, *Freq*, and *Gain*. Additional configurations can be programmed by writing the *Interpolation*, *Clock Rate*, and *Gain Factor* controls manually.

Any changes made under this sub-panel will not be applied to the target board until the *Configure* button is pushed. The *Configure* button writes the new configuration to the target board and then enables the data *Capture* button.

Control	Description
DAC Quick Set	Automatically sets test bit stream options. <i>Mode</i> selects sine or impulse output mode, <i>Freq</i> selects the test signal frequency for sine mode, and <i>Gain</i> selects the test signal amplitude in dB.
Interpolation	Manual control for the data interpolation factor of the test bit stream generator.
Clock Rate	Manual control for the output clock and data rate of the test bit stream generator.
Gain Factor	Manual control to set the test bit stream signal amplitude.
Sync	Enables test bit stream synchronization by the MSYNC signal.
Loopback	Enables digital loopback from the test bit stream generator output to the digital filter input.

3.3.5 Gain/Offset

The **Gain / Offset** sub-panel controls the digital filter GAIN and OFFSET registers for each channel.

The OFFSET and GAIN registers can be manually written with any 24-bit 2's complement value from 0x800000 to 0x7FFFFFFF. The USEGR, USEOR, ORCAL, and EXP[4:0] values enable gain correction, offset correction, and offset calibration in the digital filter.

The offset calibration routine built into the digital filter is enabled by writing the ORCAL and EXP[4:0] bits. The EXP[4:0] value can range from 0x00 to 0x18 and represents an exponential shift of the calibration feedback, as described in the digital filter data sheet. Offset calibration results are automatically written to the OFFSET registers and remain there, even after offset calibration is disabled.

Control	Description
Gain	Displays the digital filter GAIN1 to GAIN4 registers.
Offset	Displays the digital filter OFFSET1 to OFFSET4 registers.
Read	Reads values from the GAIN and OFFSET registers.
Write	Writes values to the GAIN and OFFSET registers.
USEGR	Enables gain correction. When enabled, output samples are gained down by the value in the GAIN register. (Output = GAIN / 0x7FFFFFFF).
USEOR	Enables offset correction. When enabled, output samples are offset by the value in the OFFSET register. (Output = Sample - OFFSET).
ORCAL	Enables offset calibration using the exponent value from the EXP[4:0] control. Results are automatically written to the OFFSET registers as they are calculated.
EXP[4:0]	Sets the exponential value used by offset calibration.

3.3.6 Data Capture

The **Data Capture** sub-panel collects samples from the target board and sets analysis parameters.

When the **Capture** button is pressed, the requested number of samples are collected from the target board through the USB port and are split among the enabled channels. A four-channel system, for example, will collect (Total Samples / 4) samples per channel. The maximum number of samples that can be collected is 1,048,576 (1M). The number of samples per channel should be a power of two for the analysis FFT routines to work properly.

After data is collected, analysis is performed using the selected parameters and the results are displayed on the **Analysis** panel. The selected analysis *window*, *bandwidth limit*, *full scale code*, and *full scale voltage* parameters can be modified for the data set currently in memory and the analysis re-run by pressing the **REFRESH** button on the **Analysis** Panel.

Control	Description
Total Samples	Sets the total number of samples to be collected. Multichannel acquisitions split the requested number of samples among the channels. A maximum of 1,048,576 (1M) samples can be collected.
Window	Selects the type of analysis windowing function to be applied to the collected data set. Used to ensure proper analysis of discontinuous data sets.
Bandwidth Limit (Hz)	Sets the frequency range over which to perform analysis, used to exclude higher-frequency components. Default value of zero performs analysis for the full Nyquist frequency range.
Full Scale Code	Defines the maximum positive full-scale 24-bit code from the digital filter. Used during FFT noise analysis to set the 0 dB reference level.
Full Scale Voltage	Defines the maximum peak-to-peak input voltage for the nV/ $\sqrt{\text{Hz}}$ Spot Noise analysis.
Total Captures	Sets the number of data sets to be collected and averaged together in the FFT magnitude domain. The maximum number of data sets that can be averaged is 100.
Capture	Starts data collection from the target board through the USB port. After data collection, analysis is run using parameters from this sub-panel.
Remaining Captures	Indicates how many more data captures are remaining to complete the requested number of <i>Total Captures</i> . A zero value means that the current data capture is the last one.
Skip Samples	Sets the total number of samples to be skipped prior to data collection. A maximum of 64K samples can be skipped

3.3.7 External Macros

Macros are generated within the **Macros** sub-panel on the **Control** panel. Once a macro has been built it can either be saved with a unique macro name to be run within the **Macros** sub-panel, or saved as an external macro and be associated with one of the *External Macro* buttons.

A macro is saved as an *External Macro* by saving it in the `./macros/` subdirectory using the name '*m1.mac*', '*m2.mac*', etc. Depending on the selected name the macro will be associated with the corresponding *External Macro* button *M1*, *M2*, etc.


- *M1* = `./macros/m1.mac`
- *M2* = `./macros/m2.mac`
- etc.

External Macro buttons can be re-named on the panel by right clicking on them. The button name will change, but the macro associated with that button is always saved as '*m1.mac*', '*m2.mac*', etc., in the `./macros/` subdirectory. The *External Macro* button names are stored in the file '*Mnames.txt*', also in the `./macros/` subdirectory.

External Macros allow up to eight macros to be accessed quickly without having to load them into the **Macros** sub-panel on the **Control** panel. These *External Macros* operate independently of the **Macros** sub-panel and are not affected by operations within it, except when a macro is saved to the `./macros/` subdirectory to replace a currently existing *External Macro*.

Control	Description
<i>M1 - M8</i>	Runs the <i>External Macro</i> associated with that button.

3.4 Analysis Panel



The **Analysis** panel is used to display the analysis results on collected data. It consists of the following controls.

- **Test Select**
- **Statistics**
- **Plot Enable**
- **Cursor**
- **Zoom**
- **Refresh**
- **Harmonics**
- **Spot Noise**
- **Plot Error**

3.4.1 Test Select

The *Test Select* control sets the type of analysis to be run on the collected data set.

Control	Description
<i>Time Domain</i>	Runs a min / max calculation on the collected data set and then plots sample data value vs. sample number.
<i>Histogram</i>	Runs a histogram calculation on the collected data set and then plots sample occurrence vs. sample value. Only valid for noise data since sine wave data varies over too many codes to plot as a histogram.
<i>Signal FFT</i>	Runs an FFT on the collected data set and then plots frequency magnitude vs. frequency. Statistics are calculated using the largest frequency bin as a full-scale signal reference.
<i>Noise FFT</i>	Runs an FFT on the collected data set and then plots frequency magnitude vs. frequency. Statistics are calculated using a simulated full-scale signal as a full-scale signal reference.

3.4.2 Statistics

The *Statistics* control displays calculated statistics for the selected analysis channel. For multichannel data captures, only one channel of calculated statistics are displayed at a time and is selected using the *Statistics* channel control.

Errors that affect statistical calculations will cause the *Plot Error* control to appear. Information about errors on specific channels can be accessed by enabling the plot of the channel using the *Plot Enable* control and then accessing the *Plot Error* controls.

Control	Description
Time Domain	
Max	Maximum code of collected data set.
Min	Minimum code of collected data set.
Histogram	
Max	Maximum code of collected data set.
Min	Minimum code of collected data set.
Mean	Mean of collected data set.
Std Dev	Standard Deviation of collected data set.
Variance	Variance of collected data set.
Signal FFT	
S/N	Signal to Noise of calculated FFT.
S/PN	Signal to Peak Noise of calculated FFT.
S/D	Signal to Distortion of calculated FFT.
S/N+D	Signal to Noise plus Distortion of calculated FFT.
# of bins	Number of Bins covering the Nyquist frequency.
Noise FFT	
S/N	Signal to Noise of calculated FFT.
S/PN	Signal to Peak Noise of calculated FFT.
Spot Noise dB	Spot Noise in dB/Hz of calculated FFT.
Spot Noise nV	Spot Noise in nV/ $\sqrt{\text{Hz}}$ of calculated FFT.
# of bins	Number of Bins covering the Nyquist frequency.

3.4.3 Plot Enable

The *Plot Enable* control selects which channels are plotted for the current analysis. Multichannel plots are overlay plots with the highest number channel displayed as the top most plot. Only channels enabled by the *Plot Enable* control will report analysis error codes. Information about error codes can be accessed through the *Plot Error* controls.

3.4.4 *Cursor*

The *Cursor* control is used to identify a point on the graph using the mouse and then display its plot values. When any point within the plot area of the graph is clicked, the *Cursor* will snap to the closest plotted point and the plot values for that point display below the graph.

When using the *Zoom* function, the *Cursor* is used to select the corners of the area to zoom.

3.4.5 *Zoom*

The *ZOOM* function allows an area on the graph to be expanded. To use the zoom function, click the *ZOOM* button and select the box corners of the area on the graph to expand. The graph will then expand to show the details of this area, and the plot axes will be re-scaled. While zoomed, you can zoom in farther by repeating the process.

To restore the graph to its original scale, click the *RESTORE* button that appears while zoomed. If multiple zooms have been initiated, the *RESTORE* button will return to the previously viewed plot scale. Repeated *RESTORE* will eventually return to the original plot scale. From within multiple zooms the original scale can be directly restored by clicking the *REFRESH* button.

3.4.6 *Refresh*

The *REFRESH* button will clear and re-plot the current data set. *Refresh* can be used to apply new analysis parameters from the **Data Capture** sub-panel, or to restore a *ZOOM* graph to its default plot scale.

3.4.7 *Harmonics*

The *HARMONICS* control is only visible during a Signal FFT analysis and highlights the fundamental and harmonic bins used to calculate the Signal FFT statistics. *HARMONICS* highlighting helps to understand the source of any Signal FFT plot errors.

3.4.8 *Spot Noise*

The *Spot Noise* control (labeled *dB* or *nV*) is only visible during a Noise FFT analysis and selects the units used for plotting the graph, either dB/Hz or $\text{nV}/\sqrt{\text{Hz}}$. The dB/Hz plot applies the *Full Scale Code* value from the **Data Capture** sub-panel on the **Setup** panel to determine the 0 dB point of the dB axis. The $\text{nV}/\sqrt{\text{Hz}}$ plot applies the *Full Scale Voltage* value from the **Data Capture** sub-panel on the **Setup** panel to determine the absolute scaling of the nV axis.


3.4.9 *Plot Error*

The *PLOT ERROR* control provides information about errors that occurred during an analysis. Analysis errors are only reported if the channel that has the error is currently plotted.

An analysis error stores an error code in the numerical display box of the *PLOT ERROR* control. If more than one error occurs, all error codes are stored and the last error code is displayed. Any of the accumulated error codes can be displayed by clicking on the numerical box and selecting it.

Once an error code is displayed in the numerical box, a description can be displayed by clicking the *PLOT ERROR* button. This causes a dialog box to display showing the error number, the error channel, and a text error message.

3.5 Control Panel



The screenshot shows the 'Cirrus Seismic Evaluation V2.6' software window. It features a menu bar with 'File', 'Setup!', 'Analysis!', 'Control!', 'DataCapture!', and 'Help'. The main interface is divided into several panels:

- DF REGISTERS:** Includes an 'Address' dropdown set to '0x20 FILTCFG', a 'Data' input set to '240', and 'READ' and 'WRITE' buttons.
- DF COMMANDS:** Includes a 'Command' dropdown set to 'RD_DFREG', a 'SEND' button, and fields for 'Write Data' (Data 1: 20, Data 2: 0) and 'Read Data' (Data 1: 240, Data 2: 0).
- SPI 1:** Includes a 'Start Address' dropdown set to '0x03 SPI1CMD', and buttons for 'WRITE 1 WORD', 'READ 1 WORD', 'WRITE 3 WORDS', and 'READ 3 WORDS'. It also has 'Data Word 1', 'Data Word 2', and 'Data Word 3' inputs, all set to '0'.
- MACRO 1:** A table listing commands and their values:

CMD	W	0x01	WR_COEF	0x000000
CMD	W	0x02	WR_TBS	0x000000
DF	W	0x00	CONFIG	0x070431
DF	W	0x20	FILT_CFG	0x000240
CMD	W	0x03	FILT_STRT	0x000000

 Below the table are 'Write/Read' buttons, a 'Register' dropdown set to '0x08 FILT_STRT', a 'Data' input set to '0', and buttons for 'CLEAR', 'LOAD', 'SAVE', 'INSERT', 'DELETE', 'MACRO1', 'MACRO2', 'MACRO3', 'MACRO4', and 'RUN'.
- GPIO:** A table of GPIO pins with 'DIR', 'PULL', and 'DATA' columns. Pins include MUX0, MUX1, GAIN0, GAIN1, GAIN2, MODE0, MODE1, MODE2, PWDN, SW0, SW1, and SW2. Below the table are 'READ' and 'WRITE' buttons.
- CUSTOMIZE:** Includes buttons for 'LOAD FIR COEF', 'LOAD IIR COEF', 'LOAD TBS DATA', 'START FILTER', 'STOP FILTER', 'WRITE EEPROM', and 'VERIFY EEPROM'.

At the bottom of the window are eight buttons labeled M1 through M8.

The **Control** panel is used to write and read register settings and to send commands to the digital filter. It consists of the following sub-panels and controls.

- **DF Registers**
- **DF Commands**
- **SPI1**
- **Macros**
- **GPIO**
- **Customize**
- **External Macros**

3.5.1 DF Registers

The **DF Registers** sub-panel writes and reads registers within the digital filter. Digital filter registers control operation of the digital filter and the included hardware peripherals, as described in the digital filter data sheet.

Control	Description
Address	Selects a digital filter register.
Data	Contains the data written to or read from the register.
Read	Initiates a register read.
Write	Initiates a register write.

3.5.2 DF Commands

The **DF Commands** sub-panel sends commands to the digital filter. The digital filter commands and their required parameters are described in the digital filter data sheet.

Not all commands require write data values, and not all commands will return read data values. Some commands require formatted data files for uploading custom coefficients or test bit stream data example formatted data files are included in the SPI sub-directory of the software installation.

Control	Description
Command	Selects the command to be written to the digital filter.
Write Data 1	Contains the SPI1DAT1 data to be written to the digital filter.
Write Data 2	Contains the SPI1DAT2 data to be written to the digital filter.
Read Data 1	Contains the SPI1DAT1 data read from the digital filter.
Read Data 2	Contains the SPI1DAT2 data read from the digital filter.
Send	Initiates the digital filter command.

3.5.3 SPI

The **SPI** sub-panel writes and reads registers in the digital filter SPI register space. They can be used to check the SPI serial port status bits or to manually write commands to the digital filter.

Control	Description
Start Address	Selects the address to begin the SPI transaction.
Data Word 1	Contains the first data word written to or read from the SPI registers.
Data Word 2	Contains the second data word written to or read from the SPI registers.
Data Word 3	Contains the third data word written to or read from the SPI registers.
Read 1 Word	Initiates a 1 word SPI read transaction.
Read 3 Words	Initiates a 3 word SPI read transaction.
Write 1 Word	Initiates a 1 word SPI write transaction.
Write 3 Words	Initiates a 3 word SPI write transaction.

3.5.4 Macros

The **Macros** sub-panel is designed to write a large number of registers with a single command. This allows the target evaluation system to be quickly set into a specific state for testing.

The **Register** control gives access to both digital filter registers and SPI1 registers. These registers can be written with data from the **Data** control, or data can be read and output to a text window. The **Register** control can also select special commands to be executed, with the **Data** control used to define a parameter value for the special command, if necessary.

Control	Description
Write / Read	Selects the type of operation to be performed by the inserted macro command.
Register	Selects the target register for the inserted macro command. Also selects special commands that can be performed.
Data	Sets the register data value for the inserted macro command. Also sets the parameter value for special commands.
Clear	Clears the currently displayed macro.
Load	Loads a previously saved macro.
Save	Saves the currently displayed macro. Macros can be saved with unique names or can be saved as <i>External Macros</i> .
Insert	Inserts a macro command at the selected macro line. The macro command is built from the <i>Write/Read</i> , <i>Register</i> , and <i>Data</i> controls.
Delete	Deletes the macro command at the selected macro line.
Macro1 - Macro4	Selects which of the four working macros is displayed.
Run	Runs the currently displayed working macro.

3.5.5 GPIO

The **GPIO** sub-panel controls the digital filter GPIO pin configurations. GPIO pins have dedicated functions on the target board, but can be used in any manner for custom designs.

Control	Description
Direction	Sets the selected GPIO pin as an output (*) or input ().
Pull Up	Turns the pull up resistor for the selected GPIO pin on (*) or off ().
Data	Sets the selected output GPIO pin to a high (*) or low () level.
Write	Initiates a write to GPIO registers. The <i>Direction</i> , <i>Pull Up</i> and <i>Data</i> controls are read to determine the register values to be written.
Read	Initiates a read from GPIO registers. The <i>Direction</i> , <i>Pull Up</i> and <i>Data</i> controls are updated based on the register values that are read.

3.5.6 Customize

The **Customize** sub-panel sends commands to upload custom FIR and IIR filter coefficients, upload custom test bit stream data, start the digital filter, stop the digital filter, and write/read custom EEPROM configuration files to the on-board boot EEPROM. Example data files are included in a sub-directory of the software installation.

Control	Description
Load FIR Coef	Write a set of FIR coefficients into the digital filter from a file.
Load IIR Coef	Write a set of IIR coefficients into the digital filter from a file.
Load TBS Data	Write a set of test bit stream data into the digital filter from a file.
Start Filter	Enables the digital filter by sending the <i>Start Filter</i> command.
Stop Filter	Disables the digital filter by sending the <i>Stop Filter</i> command.
Write EEPROM	Writes an EEPROM boot configuration file to the EEPROM memory.
Verify EEPROM	Verifies EEPROM memory against an EEPROM boot configuration file.

3.5.7 External Macros

Macros are generated within the **Macros** sub-panel on the **Control** panel. Once a macro has been built it can either be saved with a unique macro name to be run within the **Macros** sub-panel, or saved as an external macro and be associated with one of the *External Macro* buttons.

A macro is saved as an *External Macro* by saving it in the `./macros/` subdirectory using the name '*m1.mac*', '*m2.mac*', etc. Depending on the selected name the macro will be associated with the corresponding *External Macro* button *M1*, *M2*, etc.

- *M1* = `./macros/m1.mac`
- *M2* = `./macros/m2.mac`
- etc.

External Macro buttons can be re-named on the panel by right clicking on them. The button name will change, but the macro associated with that button is always saved as '*m1.mac*', '*m2.mac*', etc., in the `./macros/` subdirectory. The *External Macro* button names are stored in the file '*Mnames.txt*', also in the `./macros/` subdirectory.

External Macros allow up to eight macros to be accessed quickly without having to load them into the **Macros** sub-panel on the **Control** panel. These *External Macros* operate independently of the **Macros** sub-panel and are not affected by operations within it, except when a macro is saved to the `./macros/` subdirectory to replace a currently existing *External Macro*.

Control	Description
M1 - M8	Runs the <i>External Macro</i> associated with that button.

4. BILL OF MATERIALS

BILL OF MATERIAL (Page 1 of 2)

CIRRUS LOGIC
CDB5374-Z Rev_A.bom

Item	Cirrus P/N	Rev	Description	Qty	Reference Designator	MFG	MFG P/N	Notes
1	001-04345-Z1	A	CAP 0.1uF ±10% 50V X7R NPb 0805	63	C1 C2 C11 C12 C13 C15 C16 C17 C24 C25 C26 C27 C30 C31 C32 C33 C34 C36 C37 C38 C39 C40 C41 C43 C44 C48 C49 C51 C52 C54 C55 C57 C60 C61 C62 C66 C67 C68 C69 C71 C72 C73 C74 C75 C76 C77 C78 C79 C80 C81 C82 C83 C88 C89 C90 C98 C99 C100 C101 C506 C509 C513 C516	KEMET	C0805C104K5RAC	
2	001-04076-Z1	A	CAP 0.01uF ±10% 50V NPb X7R 0805	8	C3 C4 C5 C9 C10 C14 C22 C23	KEMET	C0805C103K5RAC	
3	004-00102-Z1	A	CAP 100uF ±10% 16V TANT NPb CASE D	11	G6 C7 C8 C18 C19 C20 C21 C28 C29 C35 C520	KEMET	T49TD107K016AT	
4	001-06603-Z1	A	CAP 0.01uF ±5% 25V COG NPb 1206	19	C42 C45 C63 C64 C65 C70 C84 C85 C86 C87 C91 C92 C93 C94 C95 C96 C97 C507 C510	KEMET	C1206C103J3GAC	
5	000-00009-Z1	A	NO POP CAP NPb 1206	0	C46 C50 C53 C56 C58 C246 C250 C253 C256 C258 C348 C350 C353 C356 C358 C446 C450 C453 C456 C458	NO POP	NP-CAP-1206	DO NOT POPULATE
6	004-00088-Z1	A	CAP 4.7uF ±10% 10V NPb TANT CASE A	1	C59	KEMET	T49IA475K010AT	
7	070-00004-Z1	A	DIODE SCHOTTKY BARR 30V 0.2A NPb AXL	4	D1 D2 D3 D4	PHILIPS	BAT85	
8	070-00024-Z1	A	DIODE SWT 70V 215mA NPb SOT-23	16	D5 D6 D7 D8 D205 D206 D207 D208 D305 D306 D307 D308 D405 D406 D407 D408	ON SEMICONDUCTOR	BAV99LT1G	
9	070-00055-Z1	A	DIODE ARRAY 5V (TVS) ESD NPb SOT143	1	D9	LITTELFUSE	SP0503BAHTG	
10	165-00004-Z1	A	LED SUP RED 1.7V 1mA 1.6MCD NPb SMD	1	D10	CHICAGO MINIATURE	CMD28-21SRC/TR8/T1	
11	115-00061-Z1	A	HDR 12x2 ML 1" CTR 062 S GLD NPb	0	J1 J5 J30 J36 J37 J42 J64 J65	SAMTEC	TSW-112-07-G-D	DO NOT POPULATE
12	110-00028-Z1	A	CON BNC-PCB RCPT NPb RA	1	J4	KINGS	KC-79-237 M06	
13	130-00007-Z1	A	JACK BAN SOLDER TERM NYL INS GRN NPb	1	J6	JOHNSON COMPONENTS	108-0904-001	REQUIRES BINDING POST HOOK UP WIRE. L 1.500 X 0.250T X 0.250T TYPE E 24/19 BLU SQUIRES ELEC. INC.
14	130-00009-Z1	A	JACK BAN SOLDER TERM NYL INS YLW NPb	1	J7	JOHNSON COMPONENTS	108-0907-001	REQUIRES BINDING POST HOOK UP WIRE. L 1.500 X 0.250T X 0.250T TYPE E 24/19 BLU SQUIRES ELEC. INC.
15	130-00014-Z1	A	JACK BAN SOLDER TERM NYL INS BLK NPb	1	J8	JOHNSON COMPONENTS	108-0903-001	REQUIRES BINDING POST HOOK UP WIRE. L 1.500 X 0.250T X 0.250T TYPE E 24/19 BLU SQUIRES ELEC. INC.
16	130-00006-Z1	A	JACK BAN SOLDER TERM NYN INS RED NPb	1	J9	JOHNSON COMPONENTS	108-0902-001	REQUIRES BINDING POST HOOK UP WIRE. L 1.500 X 0.250T X 0.250T TYPE E 24/19 BLU SQUIRES ELEC. INC.
17	115-00016-Z1	A	HDR 3x2 ML 1" CTR 062 S GLD NPb	3	J10 J11 J21	SAMTEC	TSW-103-07-G-D	
18	115-00013-Z1	A	HDR 2x2 ML 1" CTR 062BD S GLD NPb	13	J12 J13 J19 J20 J22 J23 J28 J33 J34 J43 J58 J66 J69	SAMTEC	TSW-102-07-G-D	
19	115-00012-Z1	A	HDR 4x2 ML 1" CTR S GLD NPb	4	J14 J15 J24 J25	SAMTEC	TSW-104-07-G-D	
20	115-00030-Z1	A	HDR 6x2 ML 1" CTR 062 S GLD NPb	1	J16	SAMTEC	TSW-106-07-G-D	
21	115-00029-Z1	A	HDR 8x2 ML 1" 062BD ST GLD NPb TH	6	J17 J18 J27 J27 J327 J427	SAMTEC	TSW-108-07-G-D	
22	115-00011-Z1	A	HDR 10x2 ML 1" 062BD ST GLD NPb TH	1	J26	SAMTEC	TSW-110-07-G-D	
23	115-00023-Z1	A	HDR 14x2 ML 1" CTR 062 S GLD NPb	0	J29 J35	SAMTEC	TSW-114-07-G-D	DO NOT POPULATE
24	110-00055-Z1	A	CON TERM BLCK 4 POS 5mm NPb BLU TH	8	J32 J41 J232 J241 J332 J341 J432 J441	OST	ED 100/40S	
25	115-00176-Z1	A	HDR 7x2 ML 2MM 062BD S GLD TH NPb	1	J39	MOLEX	87758-1416	
26	110-00041-Z1	A	CON RA USB BLK NPb TH	1	J47	AMP	292304-1	
27	110-00056-Z1	A	CON TERM BLOCK 2POS 5mm NPb BLU TH	3	J50 J59 J63	ON-SHORE TECHNOLOGY	ED 100/2DS	
28	115-00014-Z1	A	HDR 2x1 ML 1" 062BD ST GLD NPb TH	1	J56	SAMTEC	TSW-102-07-G-S	
29	115-00003-Z1	A	HDR 5x2 ML 1" CTR S GLD NPb	1	J60	SAMTEC	TSW-105-07-G-D	
30	080-00004-Z1	A	WIRE JUMPER 2P 0.1" BRASS NPb TH	8	JP1 JP2 JP3 JP4 JP5 JP6 JP7 JP8	COMPONENTS CORPORATION	TP-101-10	
31	304-00001-Z1	A	SPCR STANDOFF 4-40 THR .875L AL NPb	8	MH1 MH2 MH3 MH4 MH5 MH6 MH7 MH8	KEYSTONE	1809	REQUIRES 4-40- PAN HEAD SCREW
32	020-00788-Z1	A	RES 10 OHM 1/10W ±1% NPb 0603 FILM	13	R1 R5 R11 R13 R14 R15 R16 R24 R25 R26 R68 R514 R519	DALE	CRCW060310R0FKEA	
33	020-01244-Z1	A	RES 100k OHM 1/10W ±1% NPb 0603	7	R2 R42 R46 R53 R57 R59 R60	DALE	CRCW0603100KFKEA	


BILL OF MATERIAL (Page 2 of 2)
CIRRUS LOGIC
CDB5374-Z Rev. A.bom


Item	Cirrus P/N	Rev	Description	Qty	Reference Designator	MFG	MFG P/N	Notes
34	020-00934-Z1	A	RES 200 OHM 1/10W ±1% NPb 0603 FILM	10	R3 R17 R39 R40 R41 R55 R63 R69 R70 R71	DALE	CRCW0603200RFKEA	
35	020-01130-Z1	A	RES 10k OHM 1/10W ±1% NPb 0603 FILM	16	R4 R6 R7 R8 R18 R20 R47 R51 R54 R56 R73 R74 R75 R501 R511 R515	DALE	CRCW060310K0FKEA	
36	020-01074-Z1	A	RES 3.32k OHM 1/10W ±1% NPb 0603	2	R9 R58	DALE	CRCW06033K32FKEA	
37	020-01128-Z1	A	RES 9.53k OHM 1/10W ±1% NPb 0603	3	R10 R12 R21	DALE	CRCW06039K53FKEA	
38	020-01104-Z1	A	RES 5.9k OHM 1/10W ±1% NPb 0603 FILM	1	R19	DALE	CRCW06035K90FKEA	
39	000-00001-Z1	A	NO POP RES NPb 0805	0	R22 R23 R32 R33 R43 R52 R243 R252 R343 R352 R443 R452	NO POP	NP-RES-0805	DO NOT POPULATE
40	020-06288-Z1	A	RES 680 OHM 1/10W ±1% NPb 0603 FILM	16	R27 R28 R29 R30 R72 R76 R77 R78 R79 R80 R81 R82 R83 R84 R85 R86	DALE	CRCW0603680RFKEA	
41	021-01391-Z1	A	RES 18M OHM 1/8W ±5% NPb 0805	8	R31 R38 R231 R238 R331 R338 R431 R438	PANASONIC	ERJ6GEYK186V	
42	020-00673-Z1	A	RES 0 OHM 1/10W ±5% NPb 0603 FILM	25	R34 R36 R44 R45 R48 R49 R62 R234 R236 R244 R245 R248 R249 R334 R336 R344 R345 R348 R349 R434 R436 R444 R445 R448 R449	DALE	CRCW06030000Z5EA	
43	020-01048-Z1	A	RES 2k OHM 1/10W ±1% NPb 0603 FILM	8	R35 R37 R235 R237 R335 R337 R435 R437	DALE	CRCW06032K00FKEA	
44	020-06253-Z1	A	RES 412k OHM 1/4W ±1% NPb 1206	4	R50 R87 R88 R89	DALE	CRCW1206412KFKEA	
45	000-00002-Z1	A	NO POP RES NPb 0603	0	R61	NO POP	NP-RES-0603	DO NOT POPULATE
46	020-01016-Z1	A	RES 1k OHM 1/10W ±1% NPb 0603 FILM	4	R64 R65 R66 R67	DALE	CRCW06031K00FKEA	
47	120-00002-Z1	A	SWT SPST 130G 0/1 5mm TACT ESD NPb	3	S2 S3 S4	CBK	PTS6451L50	INSTALL AFTER WASH PROCESS
48	120-00011-Z1	A	SWT 4 POS DIP RAISED NPb SPST	1	S5	GRAYHILL	76S804T	INSTALL AFTER WASH PROCESS
49	060-00195-Z1	A	IC LOW V DUL SPST ANA SW NPb MSP8	2	U1 U2	VISHAY	DG2003DQ-T1-E3	ALTERNATE is DG2037DQ-T1-E3
50	060-00063-Z1	A	IC LNR V REG 200mA ADJ NPb SOT23-5	1	U3	LINEAR TECH	LT1964ES5-BYP#PBF	
51	061-00062-Z1	A	IC LOG SGL D-FF CLR PREST NPb SSOP8	5	U4 U9 U10 U15 U16	TEXAS INSTRUMENTS	SN74VLC2G74DCTRE4	
52	061-00062-Z1	A	IC LNR V REG LNOIS 500mA NPb S08-150	4	U5 U6 U7 U8	LINEAR TECH	LT1763CS8#PBF	
53	065-00178-Z1	E	IC CRUS LOW V AMP DC-1KHz NPb SOIC8	1	U11	CIRRUS LOGIC	CS3011-IS2/E	
54	060-00162-Z1	A	IC 3.3V U LWR PWR RS485 XCVR NPb SOIC8	4	U12 U13 U17 U18	LINEAR TECH	LTC1480IS8#PBF	
55	060-00236-Z1	A	IC LNR PRC VREF 2.5V TC10 NPb S08-150	1	U14	LINEAR TECH	LT1019AUS8-2.5#PBF	ALTERNATE is LT1019IS8-2.5#PBF
56	065-00287-Z1	A0	IC CRUS DL HIPER AMP MOD NPb QFN48	2	U19 U21	CIRRUS LOGIC	CS5374-INZ/A0	
57	065-00173-Z1	D	IC CRUS TEST DAC SSOP28 NPb	1	U20	CIRRUS LOGIC	CS4373A-ISZ/D	
58	065-00056-Z1	A	IC CRUS LPWR MCH FLTR NPb TOFP64	1	U22	CIRRUS LOGIC	CS5376A-IOZ/A	
59	060-00067-Z1	A	IC LNR DL CMOS SW DBNCR NPb SOT23-6	2	U23 U26	MAXIM	MAX6817EUT+T	
60	061-00064-Z1	A	IC LOG HEX INVERTER NPb S014-150	1	U24	TEXAS INSTRUMENTS	SN74LV04ADE4	
61	062-00022-Z1	A	IC PGM EEPROM 8Kx8 SPISER NPb SOIC8	1	U25	ATMEL	AT25640AN-10SU-2.7	
62	062-00056-Z1	A	IC PGM 128 MCROCLL CPLD NPb VOFP100	1	U27	XILINX	XCR3128XL-10VQG100I	
63	062-00079-Z1	A	IC PGM USB 16kB FLAS MCU NPb LOFP32	1	U28	SILICON	C8051F20-GQ	PROGRAM AT TEST
64	061-00061-Z1	A	IC LOG ZIN XOR NPb SOT23-5	1	U505	LABORATORIES INC	SN74LVC1G86DBVR	
65	060-00176-Z1	A	IC 1.25MHz R2R OPAMP NPb SOT23-5	1	U507	TEXAS INSTRUMENTS	LT1783IS5#TRMPBF	
66	060-00003-Z1	A	WIRE BPOST 1.5X25 24/19 GA BLU NPb	4	XJ6 XJ7 XJ8 XJ9	SQUIRES	L-1.5X.25TX.25T TYPE E	WIRES FOR BINDING POSTS
67	300-00025-Z1	A	SCREW 4-40X5/16" PH MACH SS NPb	8	XMH1 XMH2 XMH3 XMH4 XMH5 XMH6 XMH7 XMH8	BUILDING FASTENERS	PMSSS 440 0031 PH	SCREWS FOR STANDOFFS
68	102-00017-Z1	A	OSC 32 768MHz 50ppm 3.3V VCL NPb SM	1	Y1	CITIZEN	GSX750/KB32.768M-UT	
69	070-00005-Z1	A	DIODE TR 13V 600W NPb AXL	3	Z1 Z2 Z3	LITTLE FUSE	P8KE13A	
70	240-00355-Z1	A	PCB CDB5374	1		CIRRUS LOGIC	240-00355-Z1	
71	603-00355-Z1	A	ASSY DWG CDB5374	REF		CIRRUS LOGIC	603-00355-Z1	
72	600-00355-Z1	A	SCHEM CDB5374	REF		CIRRUS LOGIC	600-00355-Z1	
73	115-00003-Z1	A	HDR 5x2 ML 1"CTR S GLD NPb	0	J31 J40 J503 J525 J526	SAMTEC	TSW-105-07-G-D	DO NOT POPULATE
74	115-00029-Z1	A	HDR 8x2 ML 1" 062BD ST GLD NPb TH	0	J38 J48 J49 J51	SAMTEC	TSW-105-07-G-D	DO NOT POPULATE
75	115-00121-Z1	A	HDR 10x2 ML 1" 062BD ST GLD NPb TH	0	J44 J46 J52 J53 J54 J55 J61 J62	SAMTEC	TSW-104-07-G-D	DO NOT POPULATE
76	115-00112-Z1	A	HDR 4x2 ML 1"CTR S GLD NPb	0	J45	SAMTEC	TSW-104-07-G-D	DO NOT POPULATE
77	115-00113-Z1	A	HDR 2x2 ML 1"CTR .062BD S GLD NPb	0	J57	SAMTEC	TSW-102-07-G-D	DO NOT POPULATE
78	115-00030-Z1	A	HDR 6x2 ML 1"CTR 062 S GLD NPb	0	J502 J541 J545	SAMTEC	TSW-106-07-G-D	DO NOT POPULATE

PCB 240-00355-Z1 Rev A

CIRRUS LOGIC

SILKSCREEN TOP






PCB 240-00355-Z1 Rev A

CIRRUS LOGIC


TOP SIDE ANALOG




PCB 240-00355-Z1 Rev A

CIRRUS LOGIC

LAYER2 ANALOG






PCB 240-00355-Z1 Rev A


CIRRUS LOGIC

LAYER4 GND



CIRRUS LOGIC PCB 240-00355-Z1 Rev A

LAYER5 DIGITAL




PCB 240-00322-Z1 Rev A

PCB 240-00355-Z1 Rev A


CIRRUS LOGIC


BOTTOM SIDE




SILKSCREEN BOTTOM


6. SCHEMATICS






PART #	600-00355-Z1	REV	A
SHEET TITLE:	CH.1 ANALOG INPUTS		
DATE:	09/17/2008	SHEET	2 OF 17





PART #	600-00355-Z1	REV	A
SHEET TITLE:	CH.3 ANALOG INPUTS		
DATE:	09/17/2008	SHEET	4 OF 17










CAP: anti-dias capacitor
BUF: buffered analog output
OUT: precision analog output
VREF: voltage reference input


MODE: operational mode select
ATT: attenuator selection
TDATA: DAC data input
MCLK: analog master clock input
SYNC: DAC sync input

PART #	600-00355-Z1	REV	A
SHEET TITLE: TEST DAC			
DATE:	09/17/2008	SIZE	B 8 17



PART #	600-00355-Z1	REV A
SHEET TITLE: VOLTAGE REFERENCE		
DATE:	09/17/2008	SHEET 9 OF 17






PART #	600-00355-Z1	REV A
SHEET TITLE:	SWITCHES & PUSHBUTTONS	
DATE:	09/17/2008	SIZE B
	SHEET	11 of 17













Mouser Electronics

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

[Cirrus Logic:](#)

[CDB5374](#)