



POWER SUPPLY

- 100-240V Wide Range Input
- NEC Class 2 Compliant
- Adjustable Output Voltage
- Efficiency up to 77.2%
- Compact Design, Width only 22.5mm
- Full Output Power Between -10°C and +60°C
- Large International Approval Package
- 3 Year Warranty

1. GENERAL DESCRIPTION

A compact size, light weight, simple mounting onto the DIN-rail and the utilization of only quality components are what makes the MiniLine power supplies so easy to use and install within seconds.


A rugged electrical and mechanical design as well as a high immunity against electrical disturbances on the mains provides reliable output power. This offers superior protection for equipment which is connected to the public mains network or is exposed to a critical industrial environment.

The MiniLine series offers output voltages from 5 to 56Vdc and a power rating from 15W to 100W.

The supplementary MiniLine decoupling diode module MLY02.100 allows building of redundant systems or to protect against back-feed voltages.

ML15

Related products



2. SHORT-FORM DATA

Output voltage	DC 5V	
Adjustment range	5-5.5V	
Output current	3A	
Output power	15W	
Output ripple	< 50mVpp	20Hz to 20MHz
Input voltage	AC 100-240V	Wide Range Input
Mains frequency	50-60Hz	±6%
AC Input current	typ. 0.28 / 0.17A	At 120 / 230Vac
Power factor	typ. 0.51 / 0.44	At 120 / 230Vac
AC Inrush current	16 / 31A	Typ. peak value at 120 / 230Vac 40°C and cold start
DC Input	85-375Vdc	
Efficiency	typ. 76.8 / 77.2%	At 120 / 230Vac
Losses	typ. 4.6 / 4.5W	At 120 / 230Vac
Temperature range	-10°C to +70°C	Operational
Derating	0.4W/°C	+60 to +70°C
Hold-up time	typ. 45 / 186ms	At 120 / 230Vac
Dimensions	22.5x75x91mm	WxHxD

3. ORDER NUMBERS

Power supply **ML15.051** Standard unit

4. MARKINGS



INDEX PAGE

1. General Description	1
2. Short-form Data	1
3. Order Numbers	1
4. Markings	1
5. AC-Input	3
6. Input Inrush Current Surge	4
7. Hold-up Time	4
8. DC-Input	5
9. Output	6
10. Efficiency and Power Losses	7
11. Functional Diagram	8
12. Reliability	8
13. Front Side and User Elements	9
14. Terminals and Wiring	9
15. EMC	10
16. Environment	11
17. Protection Features	11
18. Safety	12
19. Dielectric Strength	12

INDEX PAGE



20. Approvals	13
21. Fulfilled Standards	13
22. Used Substances	13
23. Physical Dimensions and Weight	14
24. Installation and Operation Instructions	14
25. Application Notes	15
25.1. Peak Current Capability	15
25.2. Back-feeding Loads	15
25.3. Inductive and Capacitive Loads	15
25.4. Series Operation	16
25.5. Parallel Use to Increase Output Power ..	16
25.6. Parallel Use for Redundancy	17
25.7. External Input Protection	17
25.8. Functional Earth Terminal	17
25.9. Operation on Two Phases	18
25.10. Use in a Tightly Sealed Enclosure	18
25.11. Mounting Orientations	19

INTENDED USE

The power supply shall only be installed and put into operation by qualified personnel.

This power supply is designed for installation in an enclosure and is intended for the general use, such as in industrial control, office, communication, and instrumentation equipment. Do not use this device in aircraft, trains and nuclear equipment, where malfunctioning of the power supply may cause severe personal injury or threaten human life.

TERMINOLOGY AND ABBREVIATIONS

PE and  symbol	PE is the abbreviation for P rotective E arth and has the same meaning as the symbol  .
Earth, Ground	This document uses the term "earth" which is the same as the U.S. term "ground".
T.b.d.	To be defined, value or description will follow later.
AC 230V	A figure displayed with the AC or DC before the value represents a nominal voltage with standard tolerances (usually $\pm 15\%$) included. E.g.: DC 12V describes a 12V battery regardless whether it is charged (13.7V) or discharged (10V). As long as not otherwise stated, AC 100V and AC 230V parameters are valid at 50Hz and AC 120V parameters are valid at 60Hz mains frequency.
230Vac	A figure with the unit (Vac) at the end is a momentary figure without any additional tolerances included.

DISCLAIMER

The information presented in this document is believed to be accurate and reliable and may change without notice.

The housing is patent by PULS (US patent No US D442,923S)

No part of this document may be reproduced or utilized in any form without permission in writing from the publisher.

5. AC-INPUT

AC input	nom.	AC 100-240V	Wide-range input, TN-, TT-, IT-Mains, see Fig. 5-1
AC input range		85-264Vac 264-300Vac	Continuous operation < 0.5s
Input frequency	nom.	50 – 60Hz	±6%
Turn-on voltage	typ.	59Vac	Steady-state value, see Fig. 5-1
Shut-down voltage	typ.	54Vac	Steady-state value, see Fig. 5-1

		AC 100V	AC 120V	AC 230V	
Input current (rms)	typ.	0.34A	0.28A	0.17A	At 5V, 3A see Fig. 5-3
Power factor *)	typ.	0.52	0.51	0.44	At 5V, 3A see Fig. 5-1
Crest factor **)	typ.	3.45	3.53	3.94	At 5V, 3A
Start-up delay	typ.	630ms	630ms	630ms	See Fig. 5-2
Rise time	typ.	10ms	10ms	10ms	At 5V, 3A, see Fig. 5-2
Turn-on overshoot	max.	100mV	100mV	100mV	See Fig. 5-2

*) The power factor is the ratio of the true (or real) power to the apparent power in an AC circuit.

**) The crest factor is the mathematical ratio of the peak value to RMS value of the input current waveform.

Fig. 5-1 Input voltage range




Fig. 5-2 Turn-on behavior, definitions




Fig. 5-3 Input current vs. output load





Fig. 5-4 Power Factor vs. output load




6. INPUT INRUSH CURRENT SURGE

A NTC limits the input inrush current after turn-on of the input voltage. The inrush current is input voltage and ambient temperature dependent.


		AC 100V	AC 120V	AC 230V	
Inrush current	max.	13A _{peak}	16A _{peak}	31A _{peak}	40°C ambient, cold start
	typ.	11A _{peak}	13A _{peak}	26A _{peak}	40°C ambient, cold start
Inrush energy	typ.	0.1A ² s	0.1A ² s	0.4A ² s	40°C ambient, cold start

Fig. 6-1 Input inrush current, typical behavior



Input: 230Vac
Output: 5V, 3A
Ambient: 25°C
Upper curve: Input current 5A / DIV
Lower curve: Input voltage 500V / DIV
Time scale: 10ms / DIV

Fig. 6-2 Input inrush current, zoom into the first peak



Input: 230Vac
Output: 5V, 3A
Ambient: 25°C
Input current curve: 5A / DIV, 500µs / DIV
I_{peak} 23A
The charging current into EMI suppression capacitors is disregarded in the first microseconds after switch-on.

7. HOLD-UP TIME

		AC 100V	AC 120V	AC 230V	
Hold-up Time	typ.	61ms	93ms	355ms	5V, 1.5A, see Fig. 7-1
	typ.	29.5ms	45ms	191ms	5V, 3A, see Fig. 7-1

Fig. 7-1 Hold-up time vs. input voltage





Fig. 7-2 Shut-down behavior, definitions



Note: At no load, the hold-up time can be up to several seconds. The green DC-ok lamp is also on during this time.


8. DC-INPUT

DC input	nom.	DC 110-290V	-25%/+30%
DC input range	min.	85-375Vdc	Continuous operation
DC input current	typ.	0.16A / 0.057A	110Vdc / 300Vdc, at 5V and 3A output load
Turn-on voltage	typ.	80Vdc	Steady state value
Shut-down voltage	typ.	60Vdc	Steady state value

Instructions for DC use:

- Use a battery or similar DC source.
- Connect +pole to L and – pole to N.
- In case the – pole of the battery is not connected to earth, use an appropriate fuse to protect the N terminal.

Fig. 8-1 Wiring for DC Input



9. OUTPUT

Output voltage	nom.	5V	
Adjustment range	min.	5.0-5.5V	Guaranteed
	max.	6V	At clockwise end position of potentiometer
Factory setting		5.1V	±0.2%, at full load, cold unit
Line regulation	max.	10mV	85 to 264Vac
Load regulation	max.	100mV	Static value, 0A → 3A → 0A
Ripple and noise voltage	max.	50mVpp	20Hz to 20MHz, 50Ohm
Output capacitance	typ.	4800μF	
Output current	nom.	3A	See Fig. 9-1 for typical values
Output power	nom.	15W	
Short-circuit current	min.	Hiccup mode	See Fig. 9-2
	max.	Hiccup mode	See Fig. 9-2

Fig. 9-1 Output voltage vs. output current, typ.





Fig. 9-2 Hiccup mode, Output current at shorted output, 230V typ.



Peak current capability (up to several ms)

The power supply can deliver a peak current which is higher than the specified short term current. This helps to start current demanding loads or to safely operate subsequent circuit breakers.

The extra current is supplied by the output capacitors inside the power supply. During this event, the capacitors will be discharged and cause a voltage dip on the output. Detailed curves can be found in chapter 25.1

Peak current voltage dips	typ.	from 5V to 2.4V	At 6A for 50ms, resistive load
	typ.	from 5V to 1.0V	At 15A for 2ms, resistive load
	typ.	from 5V to 0.8V	At 15A for 5ms, resistive load

10. EFFICIENCY AND POWER LOSSES

		AC 100V	AC 120V	AC 230V	
Efficiency	typ.	75.8%	76.8%	77.2%	5V, 3A (full load)
Power losses	typ.	0.2W	0.3W	0.6W	At no load
	typ.	2.3W	2.3W	2.4W	5V, 1.5A (half load)
	typ.	4.9W	4.6W	4.5W	5V, 3A (full load)

Fig. 10-1 Efficiency vs. output current at 5V




Fig. 10-2 Losses vs. output current at 5V




Fig. 10-3 Efficiency vs. input voltage at 5V and 3A






Fig. 10-4 Losses vs. input voltage at 5V and 3A



11. FUNCTIONAL DIAGRAM

Fig. 11-1 Functional diagram



12. RELIABILITY

These units are extremely reliable and use only the highest quality materials. The number of critical components such as electrolytic capacitors has been reduced.

		AC 100V	AC 120V	AC 230V	
Lifetime expectancy	min.	66 000h	70 000h	93 000h	40°C, 5V, 3A
	min.	> 15 years	> 15 years	> 15 years	40°C, 5V, 1.5A
	min.	> 15 years	> 15 years	> 15 years	25°C, 5V, 3A
MTBF SN 29500, IEC 61709		2 479 000h	2 838 000h	2 686 000h	40°C, 5V, 3A
		4 066 000h	4 654 000h	4 405 000h	25°C, 5V, 3A
MTBF MIL HDBK 217F		1 175 000h	1 251 000h	1 145 000h	40°C, 5V, 3A, Ground Benign GB40
		1 575 000h	1 676 000h	1 534 000h	25°C, 5V, 3A, Ground Benign GB25

The **Lifetime expectancy** shown in the table indicates the operating hours (service life) and is determined by the lifetime expectancy of the built-in electrolytic capacitors.

Lifetime expectancy is specified in operational hours. Lifetime expectancy is calculated according to the capacitor's manufacturer specification. The prediction model allows a calculation of up to 15 years from date of shipment.

MTBF stands for **Mean Time Between Failure**, which is calculated according to statistical device failures, and indicates reliability of a device. It is the statistical representation of the likelihood of a unit to fail and does not necessarily represent the life of a product.

13. FRONT SIDE AND USER ELEMENTS

Fig. 13-1 Front side



A Output Terminals

Screw terminals

Dual terminals for the negative pole allows an easy earthing of the output voltage

+ Positive output

- Negative (return) output

B Input Terminals

Screw terminals

L Neutral input

N Line (hot) input



EMI ground

Ground this terminal to minimize high-frequency emissions.

For safety reasons, connecting to ground is not required.

C DC-ON LED (green)

On when the voltage is > 2V

D Output voltage potentiometer

Turn to set the output voltage. Factory setting is 5.1V.

14. TERMINALS AND WIRING

All terminals are easy to access when mounted on the panel. Input and output terminals are separated from each other (input below, output above) to help in error-free wiring.

Type	Screw terminals
Solid wire	0.5-6mm ²
Stranded wire	0.5-4mm ²
American wire gauge	20-10 AWG
Ferrules	Allowed, but not required
Recommended tightening torque	1Nm, 9lb.in
Screwdriver	3.5mm slotted or Pozidrive No 2
Wire stripping length	7mm / 0.275inch

Instructions:

- Use appropriate copper cables that are designed for an operating temperatures of 60°C (for ambient up to 45°C) and 75°C (for ambient up to 60°C), minimum.
- Ferrules are allowed, but not required.
- Follow local and national installation codes and regulations!
- Ensure that all strands of a stranded wire enter the terminal connection!
- In order to fulfill GL requirements, unused terminal spaces must be closed.

15. EMC

The CE mark indicates conformance with EMC directive 89/336/EC, 93/68/EC, and 2004/108/EC and the low-voltage directive (LVD) 73/23/EC, 93/68/EC, 2006/95/EC. A detailed EMC Report is available on request.

All results and investigation were performed with functional earth wire.

EMC Immunity	EN 61000-6-2, EN 61000-6-1	Generic standards		
Electrostatic discharge	EN 61000-4-2	Contact discharge	8kV	Criterion A
		Air discharge	8kV	Criterion A
Electromagnetic RF field	EN 61000-4-3	80MHz-2.7GHz	10V/m	Criterion A
Fast transients (Burst)	EN 61000-4-4	Input lines	4kV	Criterion A
		Output lines	2kV	Criterion A
Surge voltage on input	EN 61000-4-5	L → N	2kV	Criterion A
		N / L → PE	4kV	Criterion A
Surge voltage on output	EN 61000-4-5	+ → -	500V	Criterion A
		+ / - → PE	500V	Criterion A
Conducted disturbance	EN 61000-4-6	0,15-80MHz	10V	Criterion A
Mains voltage dips	EN 61000-4-11	0% of 100Vac	0Vac, 20ms	Criterion A
		40% of 100Vac	40Vac, 200ms	Criterion C
		70% of 100Vac	70Vac, 500ms	Criterion A
		0% of 200Vac	0Vac, 20ms	Criterion A
		40% of 200Vac	80Vac, 200ms	Criterion A
		70% of 200Vac	140Vac, 500ms	Criterion A
Voltage interruptions	EN 61000-4-11		0Vac, 5000ms	Criterion C
Input voltage swells	PULS internal standard		300Vac, 500ms	Criterion A
Powerful transients	VDE 0160	Over entire load range	750V, 1.3ms	Criterion A

Criteria:

A: Power supply shows normal operation behavior within the defined limits.

C: Temporary loss of function is possible. Power supply might shut-down and restarts by itself. No damages or hazards to the power supply will occur.

EMC Emission	EN 61000-6-3, EN 61000-6-4	Generic standards		
Conducted emission	EN 55011, EN 55022, FCC Part 15, CISPR 11, CISPR 22 EN 55022	Class B, input lines		
		Class B, output lines		
Radiated emission	EN 55011, EN 55022	Class B		
Harmonic input current	EN 61000-3-2	Not applicable (below 75W input power)		
Voltage fluctuations, flicker	EN 61000-3-3	Fulfilled		

This device complies with FCC Part 15 rules.


Operation is subjected to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

Switching frequency constant, typ. 65kHz

16. ENVIRONMENT


Operational temperature	-10°C to +70°C (14°F to 158°F)	Reduce output power acc. to Fig. 16-1
Output de-rating	0.4W/°C	60-70°C (140°F to 158°F), see Fig. 16-1
Storage temperature	-40 to +85°C (-40°F to 185°F)	Storage and transportation
Humidity	5 to 95% r.H.	IEC 60068-2-30 Do not energize while condensation is present
Vibration sinusoidal	2-17.8Hz: ±1.6mm; 17.8-500Hz: 2g 2 hours / axis	IEC 60068-2-6
Shock	15g 6ms, 10g 11ms 3 bumps / direction, 18 bumps in total	IEC 60068-2-27
Altitude	0 to 6000m (0 to 20000ft)	Reduce output power or ambient temperature above 2000m sea level. Above 2000m (6500ft), see Fig. 16-2
Output de-rating (for altitude)	1W/1000m or 5°C/1000m	
Over-voltage category	III II	EN 50178, IEC 62103, up to 2000m Altitudes from 2000m to 6000m
Degree of pollution	2	EN 50178, IEC 62103, non conductive

Fig. 16-1 Output power vs. ambient temperature



The ambient temperature is defined 2cm below the unit.

Fig. 16-2 Output power vs. altitude



17. PROTECTION FEATURES

Output protection	Electronically protected against overload, no-load and short-circuits	
Output over-voltage protection	Typ. 8.7V, max. 9.6V	In case of an internal power supply fault, a redundant circuit limits the maximum output voltage. In such a case, the output shuts down and stays down until the input voltage is turned off and on again
Output over-current protection	Electronically limited	See Fig. 9-1
Degree of protection	IP 20	EN/IEC 60529
Penetration protection	> 2.5mm in diameter	E.g. screws, small parts
Over-temperature protection	Not included	
Input transient protection	MOV	Metal Oxide Varistor
Internal input fuse	T3.15A H.B.C.	Not user replaceable

Note: In case of a over-voltage, overload, no-load or short-circuit event, an audible noise may be heard.

18. SAFETY


Input / output separation	SELV PELV double or reinforced insulation	IEC/EN 60950-1 EN 60204-1, EN 50178, IEC 60364-4-41, IEC 62103
Class of protection	II	
Isolation resistance	> 5MΩ	Input to output, 500Vdc
Touch current (leakage current)	typ. 0.17mA ¹⁾ / 9μA ²⁾ typ. 0.25mA ¹⁾ / 11μA ²⁾ typ. 0.39mA ¹⁾ / 16μA ²⁾ < 0.21mA ¹⁾ / 10μA ²⁾ < 0.30mA ¹⁾ / 12μA ²⁾ < 0.55mA ¹⁾ / 18μA ²⁾	100Vac, 50Hz, TN mains 120Vac, 60Hz, TN mains 230Vac, 50Hz, TN mains 110Vac, 50Hz, TN mains 132Vac, 60Hz, TN mains 264Vac, 50Hz, TN mains

1) Functional earth terminal connected to Protective earth

2) Functional earth terminal not connected

19. DIELECTRIC STRENGTH

Fig. 19-1 Dielectric strength



		A	B	C
Type test	60s	2500Vac	3000Vac	500Vac
Factory test	5s	2500Vac	2500Vac	500Vac
Field test	5s	2000Vac	2000Vac	500Vac

Type tests and factory tests:

Conducted by the manufacturer. Do not repeat test in field!






Rules for field test:

Use appropriate test equipment which applies the voltage with a slow ramp! Connect L and N together as well as all output poles.

The output voltage is floating and has no ohmic connection to ground.

To fulfill the PELV requirements according to EN60204-1 § 6.4.1, it is recommended that either the + pole, the – pole or any other part of the output circuit should be connected to the protective earth system. This helps to avoid situations in which a load starts unexpectedly or can not be switched off when an unnoticed earth faults occur.

20. APPROVALS

IEC 60950-1	IECEE CB SCHEME	CB Scheme, Information Technology Equipment
UL 508		LISTED E198865 Industrial Control Equipment
UL 60950-1		RECOGNIZED E137006 recognized for the use in U.S.A. (UL 60950-1) and Canada (C22.2 No. 60950). Information Technology Equipment, Level 3
NEC Class 2		According to NEC (National Electrical Code) Article 725-41 (4). Listed as Limited Power Source (LPS) in the UL 60950-1 UL report.
Class I Div 2		RECOGNIZED E246877 Hazardous Location Class I Div 2 T4 Groups A,B,C and D ANSI/ISA-12.12.01 (UL 1604) The unit is suitable for use in Class I Division 2 Groups A, B, C, D locations. Substitution of components may impair suitability for Class I Division 2 environment. Do not disconnect equipment unless power has been switched off. Wiring must be in accordance with Class I, Division 2 wiring methods of the National Electrical Code, NFPA 70, and in accordance with other local or national codes.
CSA		CSA approval for Canada CAN/CSA C22.2 No 107-1; CAN/ CSA 60950-1-03; UL60950-1
Marine		GL (Germanischer Lloyd) classified and ABS (American Bureau for Shipping) PDA for marine and offshore applications. Environmental category: C, EMC2

21. FULFILLED STANDARDS

EN 61558-2-17	Safety of Power Transformers
EN/IEC 60204-1	Safety of Electrical Equipment of Machines
EN/IEC 61131-2	Programmable Controllers
EN 50178, IEC 62103	Electronic Equipment in Power Installations

22. USED SUBSTANCES

Electrolytic capacitors included in this unit do not use electrolytes such as Quaternary Ammonium Salt Systems.

The unit conforms to the RoHS directive 2002/96/EC

Plastic housings and other molded plastic materials are free of halogens, wires and cables are not PVC insulated.

The materials used in our production process do not include the following toxic chemicals:
Polychlorinated Biphenyl (PCB), Pentachlorophenol (PCP), Polychlorinated naphthalene (PCN), Polybrominated Biphenyl (PBB), Polybrominated Biphenyl Oxide (PBO), Polybrominated Diphenyl Ether (PBDE), Polychlorinated Diphenyl Ether (PCDE), Polybrominated Diphenyl Oxide (PBDO), Cadmium, Asbestos, Mercury, Silica

23. PHYSICAL DIMENSIONS AND WEIGHT

Weight	130g / 0.29lb
DIN-Rail	Use 35mm DIN-rails according to EN 60715 or EN 50022 with a height of 7.5 or 15mm. The DIN-rail height must be added to the depth (91mm) to calculate the total required installation depth.
Electronic files with mechanical data can be downloaded at www.pulspower.com	

Fig. 23-1 Front view





Fig. 23-2 Side view



24. INSTALLATION AND OPERATION INSTRUCTIONS

Mounting:

Output terminal must be located on top and input terminal on the bottom. For other orientations see chapter 25.11. An appropriate electrical and fire end-product enclosure should be considered in the end use application.

Cooling:

Convection cooled, no forced cooling required. Do not cover ventilation grill (e.g. cable conduits) by more than 30%!

Installation clearances:

25mm on top and bottom.

Risk of electrical shock, fire, personal injury or death!

Turn power off before working on the power supply. Protect against inadvertent re-powering.

Make sure the wiring is correct by following all local and national codes.

Do not open, modify or repair the unit.

Use caution to prevent any foreign objects from entering into the housing.

Do not use in wet locations or in areas where moisture or condensation can be expected.

Service parts:

The unit does not contain any service parts. The tripping of an internal fuse is caused by an internal fault. If damage or malfunctioning should occur during operation, immediately turn power off and send unit to the factory for inspection!

25. APPLICATION NOTES


25.1. PEAK CURRENT CAPABILITY

Solenoids, contactors and pneumatic modules often have a steady state (sealed) coil and a pick-up coil. The inrush current demand of the pick-up coil is several times higher than the steady state current and usually exceeds the nominal output current. The same situation applies, when starting a capacitive load.

Branch circuits are often protected with circuit breakers or fuses. In case of a short or an overload in the branch circuit, the protective device (fuse, circuit breaker) needs a certain amount of over-current to trip or to blow. The peak current capability ensures the safe operation of subsequent circuit breakers.


Assuming the input voltage is turned on before such an event, the built-in large sized output capacitors inside the power supply can deliver extra current. Discharging this capacitor causes a voltage dip on the output. The following two examples show typical voltage dips:

Fig. 25-1 Peak load 6A for 50ms, typ.



Peak load 6A (resistive) for 50ms
Output voltage dips from 5V to 2.4V.

Fig. 25-2 Peak load 15A for 5ms, typ.



Peak load 15A (resistive) for 5ms
Output voltage dips from 5V to 0.8V.

25.2. BACK-FEEDING LOADS

Loads such as decelerating motors and inductors can feed voltage back to the power supply. This feature is also called return voltage immunity or resistance against Back- E.M.F. (Electro Magnetic Force).

The maximum allowed feed back voltage is 6.3Vdc. The absorbing energy can be calculated according to the built-in large sized output capacitor which is specified in chapter 9.

This power supply is resistant and does not show malfunctioning when a load feeds back voltage to the power supply. It does not matter, whether the power supply is on or off. However, please note that the output voltage can dip to zero for approximately 200ms if the back-feed voltage is removed.


25.3. INDUCTIVE AND CAPACITIVE LOADS

The unit is designed to supply unlimited inductive loads. The max. capacitive load depend on the steady state output current. At 3A output current, the output capacity should not be larger than 10 000µF at 1.5A output not larger than 25 000µF. In case of larger capacitors, the unit can show start-up attempts or start-up problems.

25.4. SERIES OPERATION

The power supply can be put in series to increase the output voltage.

Fig. 25-3 Schematic for series operation



Instructions for use in series:


- It is possible to connect as many units in series as needed, providing the sum of the output voltage does not exceed 150Vdc.
- Voltages with a potential above 60Vdc are not SELV any more and can be dangerous. Such voltages must be installed with a protection against touching.
- For serial operation use power supplies of the same type.
- Earthing of the output is required when the sum of the output voltage is above 60Vdc.

Note: Avoid return voltage (e.g. from a decelerating motor or battery) which is applied to the output terminals.

25.5. PARALLEL USE TO INCREASE OUTPUT POWER

Several power supplies can be paralleled to increase the output power. The ML15.051 has no feature included which balances the load current between the power supplies. Usually the power supply with the higher adjusted output voltage draws current until it goes into current limitation. This means no harm to this power supply as long as the ambient temperature stays below 50°C.

Fig. 25-4 Schematic for parallel operation



Instructions for parallel use:

- Use only power supplies from the same series (ML-Series).
- Adjust the output voltages of all power supplies to approximately the same value ($\pm 50\text{mV}$).
- A fuse (or diode) on the output is only required if more than three units are connected in parallel.
- Ensure that the ambient temperature of the power supply does not exceed 50°C.

25.6. PARALLEL USE FOR REDUNDANCY

Power supplies can be paralleled for redundancy to gain a higher system reliability. Redundant systems require a certain amount of extra power to support the load in case one power supply unit fails. The simplest way is to put two MiniLine power supplies in parallel. This is called a 1+1 redundancy. In case one power supply unit fails, the other one is automatically able to support the load current without any interruption. Redundant systems for a higher power demand are usually built in a N+1 method. E.g. Five power supplies, each rated for 3A are paralleled to build a 12A redundant system. If one unit fails, the 12A can still be drawn.

25.7. EXTERNAL INPUT PROTECTION

The unit is tested and approved for branch circuits up to 15A (UL) or 16A (IEC). External protection is only required if the supplying branch has an ampacity greater than this. In some countries local regulations might apply so check local codes and requirements.

If an external protective device is utilized, a minimum value is required to avoid undesired tripping of the fuse.

		B-Characteristic	C-Characteristic
Ampacity	max.	15A (UL), 16A (IEC)	15A (UL), 16A (IEC)
	min.	10A	6A

25.8. FUNCTIONAL EARTH TERMINAL

From a safety standpoint, the unit is designed according to the requirements for Protection Class 2 which does not require an earth connection. However, connecting the Functional Earth terminal can be beneficial to gain a high EMI immunity.

Symmetrical spikes or fast transients on the input side can be conducted directly to earth by the built-in filter capacitors. The magnitude of such spikes or fast transients on the output side caused by the input are much smaller compared to not connecting the FE terminal to ground.

Therefore, we recommend to connect the FE terminal to ground.

Fig. 25-5 Functional earth terminal connected to earth





Fig. 25-6 Functional earth terminal not connected to earth




25.9. OPERATION ON TWO PHASES

The power supply can be used on two phases of a three-phase-system

Instructions for two phase operation:

- A phase to phase connection is allowed as long as the supplying voltage is below $240V^{+10\%}$.
- Use a fuse or a circuit breaker to protect the N input. The N input is internally not protected and is in this case connected to a hot wire. Appropriate fuses or circuit breakers are specified in section 25.7 "External Input Protection".

Fig. 25-7 Schematic for two phase operation



25.10. USE IN A TIGHTLY SEALED ENCLOSURE

When the power supply is installed in a tightly sealed enclosure, the temperature inside the enclosure will be higher than the outside. The inside temperature defines the ambient temperature for the power supply.

Results from such an installation:

Power supply is placed in the middle of the box, no other heat producing equipment inside the box

Enclosure: Rittal Type IP66 Box PK 9510 100, plastic, 130x130x75mm
Input: 230Vac

Load:	5V, <u>3A</u> ; load is placed outside the box
Temperature inside the box:	38.2°C (in the middle of the right side of the power supply with a distance of 1cm)
Temperature outside the box:	26.0°C
Temperature rise:	12.2K
Load:	5V, <u>2.4A</u> ; (=80%) load is placed outside the box
Temperature inside the box:	35.3°C (in the middle of the right side of the power supply with a distance of 1cm)
Temperature outside the box:	25.6°C
Temperature rise:	9.7K

25.11. MOUNTING ORIENTATIONS

Mounting orientations other than input terminals on the bottom and output on the top requires a reduction in continuous output power or a limitation in the maximum allowed ambient temperature. The amount of reduction influences the lifetime expectancy of the power supply. Therefore, two different derating curves for continuous operation can be found below:

Curve A1 Recommended output power.

Curve A2 Max allowed output power (results approx. in half the lifetime expectancy of A1).

Fig. 25-8

Mounting Orientation A
Standard Orientation




Fig. 25-9

Mounting Orientation B
(Upside down)




Fig. 25-10

Mounting Orientation C
(Table-top mounting)




Fig. 25-11

Mounting Orientation D
(Horizontal cw)




Fig. 25-12

Mounting Orientation E
(Horizontal ccw)

