



# Intelligent Temperature Monitor and Dual PWM Fan Controller

## ADM1031

### FEATURES

**Optimized for Pentium® III: Allows Reduced Guardbanding Software and Automatic Fan Speed Control**

**Automatic Fan Speed Control Allows Control Independent of CPU Intervention after Initial Setup**

**Control Loop Minimizes Acoustic Noise and Battery Consumption**

**Remote Temperature Measurement Accurate to 1°C Using Remote Diode (Two Channels)**

**0.125°C Resolution on External Temperature Channels**

**Local Temperature Sensor with 0.25°C Resolution**

**Pulsewidth Modulation Fan Control (PWM) for Two Fans**

**Programmable PWM Frequency**

**Programmable PWM Duty Cycle**

**Tach Fan Speed Measurement (Two Channels)**

**Analog Input To Measure Fan Speed of 2-Wire Fans (Using Sense Resistor)**

**2-Wire System Management Bus (SMBus) with ARA Support**

**Overtemperature  $\overline{\text{THERM}}$  Output Pin for CPU Throttling**

**Programmable  $\overline{\text{INT}}$  Output Pin**

**Configurable Offsets for Temperature Channels**

**3 V to 5.5 V Supply Range**

**Shutdown Mode to Minimize Power Consumption**

**Limit Comparison of All Monitored Values**

### APPLICATIONS


**Notebook PCs, Network Servers and Personal Computers**

**Telecommunications Equipment**

### PRODUCT DESCRIPTION

The ADM1031 is an ACPI-compliant three-channel digital thermometer and under/over temperature alarm, for use in personal computers and thermal management systems. Optimized for the Pentium III, the higher 1°C accuracy offered allows systems designers to safely reduce temperature guardbanding and increase system performance. Two Pulsewidth Modulated (PWM) Fan Control outputs control the speed of two cooling fans by varying output duty cycle. Duty cycle values between 33%–100% allow smooth control of the fans. The speed of each fan can be monitored via TACH inputs. The TACH inputs may be reprogrammed as analog inputs, allowing fan speeds for 2-wire fans to be measured via sense resistors. The device will also detect a stalled fan. A dedicated Fan Speed Control Loop provides control even without the intervention of CPU software. It also ensures that if the CPU or system locks up, each fan can still be controlled based on temperature measurements, and the fan speed adjusted to correct any changes in system temperature. Fan speed may also be controlled using existing ACPI software. Two inputs (four pins) are dedicated to remote temperature-sensing diodes with an accuracy of  $\pm 1^\circ\text{C}$ , and an on-chip temperature sensor allows ambient temperature to be monitored. The device has a programmable  $\overline{\text{INT}}$  output to indicate error conditions. There is a dedicated  $\overline{\text{FAN\_FAULT}}$  output to signal fan failure. The  $\overline{\text{THERM}}$  pin is a fail-safe output for overtemperature conditions that can be used to throttle a CPU clock.

### FUNCTIONAL BLOCK DIAGRAM



\*Patents pending.

### REV. A

Information furnished by Analog Devices is believed to be accurate and reliable. However, no responsibility is assumed by Analog Devices for its use, nor for any infringements of patents or other rights of third parties that may result from its use. No license is granted by implication or otherwise under any patent or patent rights of Analog Devices. Trademarks and registered trademarks are the property of their respective companies.

One Technology Way, P.O. Box 9106, Norwood, MA 02062-9106, U.S.A.  
Tel: 781/329-4700 [www.analog.com](http://www.analog.com)  
Fax: 781/326-8703 © 2003 Analog Devices, Inc. All rights reserved.

# ADM1031—SPECIFICATIONS<sup>1</sup> ( $T_A = T_{MIN}$ to $T_{MAX}$ , $V_{CC} = V_{MIN}$ to $V_{MAX}$ , unless otherwise noted.)

| Parameter                                                        | Min | Typ   | Max   | Unit | Test Conditions/Comments                                                                                                             |
|------------------------------------------------------------------|-----|-------|-------|------|--------------------------------------------------------------------------------------------------------------------------------------|
| POWER SUPPLY                                                     |     |       |       |      |                                                                                                                                      |
| Supply Voltage, V <sub>CC</sub>                                  | 3.0 | 3.30  | 5.5   | V    | Interface Inactive, ADC Active<br>Standby Mode                                                                                       |
| Supply Current, I <sub>CC</sub>                                  |     | 1.4   | 3     | mA   |                                                                                                                                      |
|                                                                  |     | 32    | 50    | μA   |                                                                                                                                      |
| TEMPERATURE-TO-DIGITAL CONVERTER                                 |     |       |       |      |                                                                                                                                      |
| Local Sensor Accuracy                                            |     | ±1    | ±3    | °C   | 60°C ≤ T <sub>D</sub> ≤ 100°C<br>60°C ≤ T <sub>D</sub> ≤ 100°C                                                                       |
| Resolution                                                       |     | 0.25  |       | °C   |                                                                                                                                      |
| Remote Diode1 Sensor Accuracy                                    |     | ±0.5  | ±1    | °C   |                                                                                                                                      |
| Remote Diode2 Sensor Accuracy                                    |     | ±0.5  | ±1.75 | °C   |                                                                                                                                      |
| Resolution                                                       |     | 0.125 |       | °C   |                                                                                                                                      |
| Remote Sensor Source Current                                     |     | 180   |       | μA   | High Level                                                                                                                           |
|                                                                  |     | 11    |       | μA   | Low Level                                                                                                                            |
| OPEN-DRAIN DIGITAL OUTPUTS<br>(THERM, INT, FAN_FAULT, PWM_OUT)   |     |       |       |      |                                                                                                                                      |
| Output Low Voltage, V <sub>OL</sub>                              |     |       | 0.4   | V    | I <sub>OUT</sub> = −6.0 mA; V <sub>CC</sub> = 3 V<br>V <sub>OUT</sub> = V <sub>CC</sub> ; V <sub>CC</sub> = 3 V                      |
| High-Level Output Leakage Current, I <sub>OH</sub>               |     | 0.1   | 1     | μA   |                                                                                                                                      |
| OPEN-DRAIN SERIAL DATA BUS OUTPUT (SDA)                          |     |       |       |      |                                                                                                                                      |
| Output Low Voltage, V <sub>OL</sub>                              |     |       | 0.4   | V    | I <sub>OUT</sub> = −6.0 mA; V <sub>CC</sub> = 3 V<br>V <sub>OUT</sub> = V <sub>CC</sub>                                              |
| High-Level Output Leakage Current, I <sub>OH</sub>               |     | 0.1   | 1     | μA   |                                                                                                                                      |
| SERIAL BUS DIGITAL INPUTS (SCL, SDA)                             |     |       |       |      |                                                                                                                                      |
| Input High Voltage, V <sub>IH</sub>                              | 2.1 |       |       | V    |                                                                                                                                      |
| Input Low Voltage, V <sub>IL</sub>                               |     |       | 0.8   | V    |                                                                                                                                      |
| Hysteresis                                                       |     | 500   |       | mV   |                                                                                                                                      |
| DIGITAL INPUT LOGIC LEVELS <sup>2</sup><br>(ADD, THERM, TACH1/2) |     |       |       |      |                                                                                                                                      |
| Input High Voltage, V <sub>IH</sub>                              | 2.1 |       |       | V    |                                                                                                                                      |
| Input Low Voltage, V <sub>IL</sub>                               |     |       | 0.8   | V    |                                                                                                                                      |
| DIGITAL INPUT LEAKAGE CURRENT                                    |     |       |       |      |                                                                                                                                      |
| Input High Current, I <sub>IH</sub>                              | −1  |       |       | μA   | V <sub>IN</sub> = V <sub>CC</sub><br>V <sub>IN</sub> = 0                                                                             |
| Input Low Current, I <sub>IL</sub>                               |     |       | 1     | μA   |                                                                                                                                      |
| Input Capacitance, C <sub>IN</sub>                               |     | 5     |       | pF   |                                                                                                                                      |
| FAN RPM-TO-DIGITAL CONVERTER                                     |     |       |       |      |                                                                                                                                      |
| Accuracy                                                         |     |       | ±6    | %    | 60°C ≤ T <sub>A</sub> ≤ 100°C                                                                                                        |
| Full-Scale Count                                                 |     |       | 255   |      |                                                                                                                                      |
| TACH Nominal Input RPM                                           |     | 4400  |       | RPM  | Divisor N = 1, Fan Count = 153<br>Divisor N = 2, Fan Count = 153<br>Divisor N = 4, Fan Count = 153<br>Divisor N = 8, Fan Count = 153 |
|                                                                  |     | 2200  |       | RPM  |                                                                                                                                      |
|                                                                  |     | 1100  |       | RPM  |                                                                                                                                      |
|                                                                  |     | 550   |       | RPM  |                                                                                                                                      |
| Conversion Cycle Time                                            |     | 637   |       | ms   |                                                                                                                                      |
| SERIAL BUS TIMING <sup>3</sup>                                   |     |       |       |      |                                                                                                                                      |
| Clock Frequency, f <sub>SCLK</sub>                               | 10  |       | 100   | kHz  | See Figure 1                                                                                                                         |
| Glitch Immunity, t <sub>SW</sub>                                 |     | 50    |       | ns   | See Figure 1                                                                                                                         |
| Bus Free Time, t <sub>BUF</sub>                                  | 4.7 |       |       | μs   | See Figure 1                                                                                                                         |
| Start Setup Time, t <sub>SU;STA</sub>                            | 4.7 |       |       | μs   | See Figure 1                                                                                                                         |
| Start Hold Time, t <sub>HD;STA</sub>                             | 4   |       |       | μs   | See Figure 1                                                                                                                         |
| Stop Condition Setup Time t <sub>SU;STO</sub>                    | 4   |       |       | μs   | See Figure 1                                                                                                                         |
| SCL Low Time, t <sub>LOW</sub>                                   | 1.3 |       |       | μs   | See Figure 1                                                                                                                         |
| SCL High Time, t <sub>HIGH</sub>                                 | 4   |       | 50    | μs   | See Figure 1                                                                                                                         |
| SCL, SDA Rise Time, t <sub>R</sub>                               |     |       | 1000  | ns   | See Figure 1                                                                                                                         |
| SCL, SDA Fall Time, t <sub>F</sub>                               |     |       | 300   | ns   | See Figure 1                                                                                                                         |
| Data Setup Time, t <sub>SU;DAT</sub>                             | 250 |       |       | ns   | See Figure 1                                                                                                                         |
| Data Hold Time, t <sub>HD;DAT</sub>                              | 300 |       |       | ns   | See Figure 1                                                                                                                         |

## NOTES

<sup>1</sup>Typicals are at  $T_A = 25^{\circ}\text{C}$  and represent most likely parametric norm. Shutdown current typ is measured with  $V_{CC} = 3.3$  V.

<sup>2</sup>ADD is a three-state input that may be pulled high, low or left open-circuit.

<sup>3</sup>Timing specifications are tested at logic levels of  $V_{IL} = 0.8$  V for a falling edge and  $V_{IH} = 2.2$  V for a rising edge.

Specifications subject to change without notice.

## ABSOLUTE MAXIMUM RATINGS\*

|                                             |                  |
|---------------------------------------------|------------------|
| Positive Supply Voltage ( $V_{CC}$ )        | 6.5 V            |
| Voltage on Any Input or Output Pin          | -0.3 V to +6.5 V |
| Input Current at Any Pin                    | $\pm 5$ mA       |
| Package Input Current                       | $\pm 20$ mA      |
| Maximum Junction Temperature ( $T_{JMAX}$ ) | 150°C            |
| Storage Temperature Range                   | -65°C to +150°C  |
| Lead Temperature, Soldering                 |                  |
| Vapor Phase 60 sec                          | 215°C            |
| Infrared 15 sec                             | 200°C            |
| ESD Rating All Pins                         | 2000 V           |

\*Stresses above those listed under Absolute Maximum Ratings may cause permanent damage to the device. This is a stress rating only; functional operation of the device at these or any other conditions above those indicated in the operational section of this specification is not implied. Exposure to absolute maximum rating conditions for extended periods may affect device reliability.

## ORDERING GUIDE

| Model      | Temperature Range | Package Description | Package Option |
|------------|-------------------|---------------------|----------------|
| ADM1031ARQ | 0°C to 100°C      | 16-Lead QSOP        | RQ-16          |

## THERMAL CHARACTERISTICS

16-Lead QSOP Package

$$\theta_{JA} = 105^{\circ}\text{C/W}, \theta_{JC} = 39^{\circ}\text{C/W}$$




Figure 1. Diagram for Serial Bus Timing

## CAUTION


ESD (electrostatic discharge) sensitive device. Electrostatic charges as high as 4000 V readily accumulate on the human body and test equipment and can discharge without detection. Although the ADM1031 features proprietary ESD protection circuitry, permanent damage may occur on devices subjected to high energy electrostatic discharges. Therefore, proper ESD precautions are recommended to avoid performance degradation or loss of functionality.




## PIN FUNCTION DESCRIPTIONS

| Pin No. | Mnemonic        | Description                                                                                                                                                                                                                                                                                                                                              |
|---------|-----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1       | PWM_OUT1        | Digital Output (Open-Drain). Pulsewidth modulated output to control fan speed. Requires pull-up resistor (10 k $\Omega$ typical).                                                                                                                                                                                                                        |
| 2       | TACH1/AIN1      | Digital/Analog Input. Fan tachometer input to measure FAN1 fan speed. May be reprogrammed as an analog input to measure speed of a 2-wire fan via a sense resistor (2 $\Omega$ typical).                                                                                                                                                                 |
| 3       | PWM_OUT2        | Digital Output (Open-Drain). Pulsewidth Modulated output to control FAN2 fan speed. Requires pull-up resistor (10 k $\Omega$ typical).                                                                                                                                                                                                                   |
| 4       | TACH2/AIN2      | Digital/Analog Input. Fan tachometer input to measure FAN2 fan speed. May be reprogrammed as an analog input to measure speed of a 2-wire fan via a sense resistor (2 $\Omega$ typical).                                                                                                                                                                 |
| 5       | GND             | System Ground.                                                                                                                                                                                                                                                                                                                                           |
| 6       | V <sub>CC</sub> | Power. Can be powered by 3.3 V Standby power if monitoring in low power states is required.                                                                                                                                                                                                                                                              |
| 7       | THERM           | Digital I/O (Open-Drain). An active low thermal overload output that indicates a violation of a temperature set point (overtemperature). Also acts as an input to provide external fan control. When this pin is pulled low by an external signal, a status bit is set, and the fan speed is set to full-on. Requires pull-up resistor (10 k $\Omega$ ). |
| 8       | FAN_FAULT       | Digital Output (Open-Drain). Can be used to signal a fan fault. Drives second fan to full speed if one fan fails. Requires pull-up resistor (typically 10 k $\Omega$ ).                                                                                                                                                                                  |
| 9       | D1–             | Analog Input. Connected to cathode of first remote temperature-sensing diode. The temperature-sensing element is either a Pentium III substrate transistor or a general-purpose 2N3904.                                                                                                                                                                  |
| 10      | D1+             | Analog Input. Connected to anode of first remote temperature-sensing diode.                                                                                                                                                                                                                                                                              |
| 11      | D2–             | Analog Input. Connected to cathode of second remote temperature-sensing diode.                                                                                                                                                                                                                                                                           |
| 12      | D2+             | Analog Input. Connected to anode of second remote temperature-sensing diode.                                                                                                                                                                                                                                                                             |
| 13      | ADD             | Three-State Logic Input. Sets two lower bits of device SMBus address.                                                                                                                                                                                                                                                                                    |
| 14      | INT (SMBALERT)  | Digital Output (Open-Drain). Can be programmed as an interrupt (SMBus ALERT) output for temperature/fan speed interrupts. Requires pull-up resistor (10 k $\Omega$ typical).                                                                                                                                                                             |
| 15      | SDA             | Digital I/O. Serial Bus Bidirectional Data. Open-drain output. Requires pull-up resistor (2.2 k $\Omega$ typical).                                                                                                                                                                                                                                       |
| 16      | SCL             | Digital Input. Serial Bus Clock. Requires pull-up resistor (2.2 k $\Omega$ typical).                                                                                                                                                                                                                                                                     |


## PIN CONFIGURATION




# Typical Performance Characteristics—ADM1031




TPC 1. Temperature Error vs. PCB Track Resistance




TPC 4. Pentium III Temperature Measurement vs. ADM1031 Reading




TPC 2. Temperature Error vs. Power Supply Noise Frequency




TPC 5. Temperature Error vs. Capacitance between D+ and D-




TPC 3. Temperature Error vs. Common-Mode Noise Frequency




TPC 6. Standby Current vs. Clock Frequency




TPC 7. Temperature Error vs. Differential-Mode Noise Frequency




TPC 10. Remote Temperature Sensor Error




TPC 8. Standby Supply Current vs. Supply Voltage



TPC 11. Supply Current vs. Supply Voltage



TPC 9. Local Sensor Temperature Error



TPC 12. Response to Thermal Shock

## GENERAL DESCRIPTION

The ADM1031 is a temperature monitor and dual PWM fan controller for microprocessor-based systems. The device communicates with the system via a serial System Management Bus. The serial bus controller has a hardwired address pin for device selection (Pin 13), a serial data line for reading and writing addresses and data (Pin 15), and an input line for the serial clock (Pin 16). All control and programming functions of the ADM1031 are performed over the serial bus. The device also supports Alert Response Address (ARA).

## INTERNAL REGISTERS OF THE ADM1031

A brief description of the ADM1031's principal internal registers is given below. More detailed information on the function of each register is given in Table XII to Table XXIX.

### Configuration Register

Provides control and configuration of various functions on the device.

### Address Pointer Register

This register contains the address that selects one of the other internal registers. When writing to the ADM1031, the first byte of data is always a register address, which is written to the Address Pointer Register.

### Status Registers

These registers provide status of each limit comparison.

### Value and Limit Registers

The results of temperature and fan speed measurements are stored in these registers, along with their limit values.

### Fan Speed Config Register

This register is used to program the PWM duty cycle for each fan.

### Offset Registers

Allows the temperature channel readings to be offset by a 5-bit two's complement value written to these registers. These values will automatically be added to the temperature values (or subtracted from if negative). This allows the systems designer to optimize the system if required, by adding or subtracting up to 15°C from a temperature reading.

### Fan Characteristics Registers

These registers are used to select the spin-up time, PWM frequency, and speed range for the fans used.

### THERM Limit Registers

These registers contain the temperature values at which  $\overline{\text{THERM}}$  will be asserted.

### $T_{\text{MIN}}/T_{\text{RANGE}}$ Registers

These registers are read/write registers that hold the minimum temperature value below which the fan will not run when the device is in Automatic Fan Speed Control Mode. These registers also hold the temperature range value that defines the range over which auto fan control will be provided, and hence determines the temperature at which the fan will run at full speed.

## SERIAL BUS INTERFACE

Control of the ADM1031 is carried out via the SMBus. The ADM1031 is connected to this bus as a slave device, under the control of a master device, e.g., the 810 chipset.

The ADM1031 has a 7-bit serial bus address. When the device is powered up, it will do so with a default serial bus address. The five MSBs of the address are set to 01011, the two LSBs are determined by the logical state of Pin 13 (ADD). This is a

three-state input that can be grounded, connected to  $V_{\text{CC}}$ , or left open-circuit to give three different addresses. The state of the ADD pin is only sampled at power-up, so changing ADD with power on will have no effect until the device is powered off, then on again.

**Table I. ADD Pin Truth Table**

| ADD Pin         | A1 | A0 |
|-----------------|----|----|
| GND             | 0  | 0  |
| No Connect      | 1  | 0  |
| $V_{\text{CC}}$ | 0  | 1  |

If ADD is left open-circuit, the default address will be 0101110.

The facility to make hardwired changes at the ADD pin allows the user to avoid conflicts with other devices sharing the same serial bus; for example, if more than one ADM1031 is used in a system.

The serial bus protocol operates as follows:

1. The master initiates data transfer by establishing a START condition, defined as a high-to-low transition on the serial data line SDA while the serial clock line SCL remains high. This indicates that an address/data stream will follow. All slave peripherals connected to the serial bus respond to the START condition, and shift in the next 8 bits, consisting of a 7-bit address (MSB first) plus an  $R/\overline{W}$  bit that determines the direction of the data transfer, i.e., whether data will be written to or read from the slave device.  
The peripheral whose address corresponds to the transmitted address responds by pulling the data line low during the low period before the ninth clock pulse, known as the Acknowledge Bit. All other devices on the bus now remain idle while the selected device waits for data to be read from or written to it. If the  $R/\overline{W}$  bit is a 0, the master will write to the slave device. If the  $R/\overline{W}$  bit is a 1, the master will read from the slave device.
2. Data is sent over the serial bus in sequences of nine clock pulses, eight bits of data followed by an Acknowledge Bit from the slave device. Transitions on the data line must occur during the low period of the clock signal and remain stable during the high period, as a low-to-high transition when the clock is high may be interpreted as a STOP signal. The number of data bytes that can be transmitted over the serial bus in a single READ or WRITE operation is limited only by what the master and slave devices can handle.
3. When all data bytes have been read or written, stop conditions are established. In WRITE mode, the master will pull the data line high during the tenth clock pulse to assert a STOP condition. In READ mode, the master device will override the acknowledge bit by pulling the data line high during the low period before the ninth clock pulse. This is known as No Acknowledge. The master will then take the data line low during the low period before the tenth clock pulse, then high during the tenth clock pulse to assert a STOP condition.

Any number of bytes of data may be transferred over the serial bus in one operation, but it is not possible to mix read and write in one operation, because the type of operation is determined at the beginning and cannot subsequently be changed without starting a new operation.

# ADM1031

In the case of the ADM1031, write operations contain either one or two bytes, and read operations contain one byte, and perform the following functions.

To write data to one of the device data registers or read data from it, the Address Pointer Register must be set so that the correct data register is addressed; data can then be written into that register or read from it. The first byte of a write operation always contains an address that is stored in the Address Pointer Register. If data is to be written to the device, the write operation contains a second data byte that is written to the register selected by the address pointer register.

This is illustrated in Figure 2a. The device address is sent over the bus followed by  $R/\overline{W}$  set to 0. This is followed by two data bytes. The first data byte is the address of the internal data register to be written to, which is stored in the Address Pointer Register. The second data byte is the data to be written to the internal data register.

When reading data from a register there are two possibilities:

1. If the ADM1031's Address Pointer Register value is unknown or not the desired value, it is first necessary to set it to the correct value before data can be read from the desired data register. This is done by performing a write to the ADM1031

as before, but only the data byte containing the register address is sent, as data is not to be written to the register. This is shown in Figure 2b.

A read operation is then performed consisting of the serial bus address,  $R/\overline{W}$  bit set to 1, followed by the data byte read from the data register. This is shown in Figure 2c.

2. If the Address Pointer Register is known to be already at the desired address, data can be read from the corresponding data register without first writing to the Address Pointer Register, so Figure 2b can be omitted.

## NOTES

1. Although it is possible to read a data byte from a data register without first writing to the Address Pointer Register, if the Address Pointer Register is already at the correct value, it is not possible to write data to a register without writing to the Address Pointer Register, because the first data byte of a write is always written to the Address Pointer Register.
2. In Figures 2a to 2c, the serial bus address is shown as the default value 01011(A1)(A0), where A1 and A0 are set by the three-state ADD pin.
3. The ADM1031 also supports the Read Byte protocol, as described in the System Management Bus specification.




Figure 2a. Writing a Register Address to the Address Pointer Register, then Writing Data to the Selected Register




Figure 2b. Writing to the Address Pointer Register Only




Figure 2c. Reading Data from a Previously Selected Register

## ALERT RESPONSE ADDRESS

Alert Response Address (ARA) is a feature of SMBus devices that allows an interrupting device to identify itself to the host when multiple devices exist on the same bus.

The  $\overline{\text{INT}}$  output can be used as an interrupt output or can be used as an  $\overline{\text{SMBALERT}}$ . One or more  $\overline{\text{INT}}$  outputs can be connected to a common  $\overline{\text{SMBALERT}}$  line connected to the master. If a device's  $\overline{\text{INT}}$  line goes low, the following procedure occurs:

1.  $\overline{\text{SMBALERT}}$  pulled low.
2. Master initiates a read operation and sends the Alert Response Address (ARA = 0001 100). This is a general call address that must not be used as a specific device address.
3. The device whose  $\overline{\text{INT}}$  output is low responds to the Alert Response Address, and the master reads its device address. The address of the device is now known and can be interrogated in the usual way.
4. If more than one device's  $\overline{\text{INT}}$  output is low, the one with the lowest device address will have priority, in accordance with normal SMBus arbitration.
5. Once the ADM1031 has responded to the Alert Response Address, it will reset its  $\overline{\text{INT}}$  output; however, if the error condition that caused the interrupt persists,  $\overline{\text{INT}}$  will be reasserted on the next monitoring cycle.

## TEMPERATURE MEASUREMENT SYSTEM

### Internal Temperature Measurement

The ADM1031 contains an on-chip bandgap temperature sensor. The on-chip ADC performs conversions on the output of this sensor and outputs the temperature data in 10-bit two's complement format. The resolution of the local temperature sensor is 0.25°C. The format of the temperature data is shown in Table II.

### External Temperature Measurement

The ADM1031 can measure the temperatures of two external diode sensors or diode-connected transistors, connected to Pins 9 and 10 and Pins 11 and 12.

These pins are dedicated temperature input channels. The function of Pin 7 is as a  $\overline{\text{THERM}}$  input/output and is used to flag overtemperature conditions.

The forward voltage of a diode or diode-connected transistor, operated at a constant current, exhibits a negative temperature coefficient of about  $-2 \text{ mV}/^\circ\text{C}$ . Unfortunately, the absolute value of  $V_{\text{BE}}$ , varies from device to device, and individual calibration is required to null this out, so the technique is unsuitable for mass production.

The technique used in the ADM1031 is to measure the change in  $V_{\text{BE}}$  when the device is operated at two different currents.

This is given by:

$$\Delta V_{\text{BE}} = \frac{KT}{q} \times \ln(N)$$

where:

$K$  is Boltzmann's constant.

$q$  is charge on the carrier.

$T$  is absolute temperature in Kelvins.

$N$  is ratio of the two currents.

Figure 3 shows the input signal conditioning used to measure the output of an external temperature sensor. This figure shows the external sensor as a substrate transistor, provided for temperature monitoring on some microprocessors, but it could equally well be a discrete transistor.




Figure 3. Signal Conditioning

If a discrete transistor is used, the collector will not be grounded, and should be linked to the base. If a PNP transistor is used, the base is connected to the D- input and the emitter to the D+ input. If an NPN transistor is used, the emitter is connected to the D- input and the base to the D+ input.

One LSB of the ADC corresponds to 0.125°C, so the ADM1031 can theoretically measure temperatures from  $-127^\circ\text{C}$  to  $+127.75^\circ\text{C}$ , although  $-127^\circ\text{C}$  is outside the operating range for the device. The extended temperature resolution data format is shown in Tables III and IV.

Table II. Temperature Data Format (Local Temperature and Remote Temperature High Bytes)

| Temperature (°C) | Digital Output |
|------------------|----------------|
| -128°C           | 1000 0000      |
| -125°C           | 1000 0011      |
| -100°C           | 1001 1100      |
| -75°C            | 1011 0101      |
| -50°C            | 1100 1110      |
| -25°C            | 1110 0111      |
| -1°C             | 1111 1111      |
| 0°C              | 0000 0000      |
| +1°C             | 0000 0001      |
| +10°C            | 0000 1010      |
| +25°C            | 0001 1001      |
| +50°C            | 0011 0010      |
| +75°C            | 0100 1011      |
| +100°C           | 0110 0100      |
| +125°C           | 0111 1101      |
| +127°C           | 0111 1111      |

# ADM1031

**Table III. Remote Sensor Extended Temperature Resolution**

| Extended Resolution (°C) | Remote Temperature Low Bits |
|--------------------------|-----------------------------|
| 0.000                    | 000                         |
| 0.125                    | 001                         |
| 0.250                    | 010                         |
| 0.375                    | 011                         |
| 0.500                    | 100                         |
| 0.625                    | 101                         |
| 0.750                    | 110                         |
| 0.875                    | 111                         |

The extended temperature resolution for the local and remote channels is stored in the Extended Temperature Resolution Register (Register 0x06), and is outlined in Table XVIII.

**Table IV. Local Sensor Extended Temperature Resolution**

| Extended Resolution (°C) | Local Temperature Low Bits |
|--------------------------|----------------------------|
| 0.00                     | 00                         |
| 0.25                     | 01                         |
| 0.50                     | 10                         |
| 0.75                     | 11                         |

To prevent ground noise interfering with the measurement, the more negative terminal of the sensor is not referenced to ground, but biased above ground by an internal diode at the D– input. If the sensor is used in a very noisy environment, a capacitor of value up to 1000 pF may be placed between the D+ and D– inputs to filter the noise.

To measure  $\Delta V_{BE}$ , the sensor is switched between operating currents of I and  $N \times I$ . The resulting waveform is passed through a 65 kHz low-pass filter to remove noise, then to a chopper-stabilized amplifier that performs the functions of amplification and rectification of the waveform to produce a dc voltage proportional to  $\Delta V_{BE}$ . This voltage is measured by the ADC to give a temperature output in 11-bit two's complement format. To further reduce the effects of noise, digital filtering is performed by averaging the results of 16 measurement cycles. An external temperature measurement nominally takes 9.6 ms.

## LAYOUT CONSIDERATIONS

Digital boards can be electrically noisy environments and care must be taken to protect the analog inputs from noise, particularly when measuring the very small voltages from a remote diode sensor. The following precautions should be taken:

1. Place the ADM1031 as close as possible to the remote sensing diode. Provided that the worst noise sources such as clock generators, data/address buses, and CRTs are avoided, this distance can be 4 to 8 inches.
2. Route the D+ and D– tracks close together, in parallel, with grounded guard tracks on each side. Provide a ground plane under the tracks if possible.
3. Use wide tracks to minimize inductance and reduce noise pick-up. 10 mil track minimum width and spacing is recommended.



**Figure 4. Arrangement of Signal Tracks**

4. Try to minimize the number of copper/solder joints, which can cause thermocouple effects. Where copper/solder joints are used, make sure that they are in both the D+ and D– path and at the same temperature.

Thermocouple effects should not be a major problem as 1°C corresponds to about 200  $\mu$ V, and thermocouple voltages are about 3  $\mu$ V/°C of temperature difference. Unless there are two thermocouples with a big temperature differential between them, thermocouple voltages should be much less than 200  $\mu$ V.

5. Place a 0.1  $\mu$ F bypass capacitor close to the ADM1031.
6. If the distance to the remote sensor is more than 8 inches, the use of twisted pair cable is recommended. This will work up to about 6 to 12 feet.
7. For really long distances (up to 100 feet) use shielded twisted pair such as Belden #8451 microphone cable. Connect the twisted pair to D+ and D– and the shield to GND close to the ADM1031. Leave the remote end of the shield unconnected to avoid ground loops.

Because the measurement technique uses switched current sources, excessive cable and/or filter capacitance can affect the measurement. When using long cables, the filter capacitor C1 may be reduced or removed. In any case the total shunt capacitance should not exceed 1000 pF.

Cable resistance can also introduce errors. 1  $\Omega$  series resistance introduces about 0.5°C error.

## ADDRESSING THE DEVICE

ADD (Pin 13) is a three-state input. It is sampled, on power-up to set the lowest two bits of the serial bus address. Up to three addresses are available to the systems designer via this address pin. This reduces the likelihood of conflicts with other devices attached to the System Management Bus.

## THE ADM1031 INTERRUPT SYSTEM

The ADM1031 has two interrupt outputs,  $\overline{\text{INT}}$  and  $\overline{\text{THERM}}$ . These have different functions.  $\overline{\text{INT}}$  responds to violations of software programmed temperature limits and is maskable (described in more detail later).

$\overline{\text{THERM}}$  is intended as a “fail-safe” interrupt output that cannot be masked. If the temperature is below the low temperature limit, the  $\overline{\text{INT}}$  pin will be asserted low to indicate an out-of-limit condition. If the temperature exceeds the high temperature limit, the  $\overline{\text{INT}}$  pin will also be asserted low. A third limit; THERM limit, may be programmed into the device to set the temperature limit above which the overtemperature  $\overline{\text{THERM}}$  pin will be

asserted low. The behavior of the high limit and  $\overline{\text{THERM}}$  limit is as follows:

1. Whenever the temperature measured exceeds the high temperature limit, the  $\overline{\text{INT}}$  pin is asserted low.
2. If the temperature exceeds the  $\overline{\text{THERM}}$  limit, the  $\overline{\text{THERM}}$  output asserts low. This can be used to throttle the CPU clock. If the  $\overline{\text{THERM}}$ -to-Fan Enable bit (Bit 7 of  $\overline{\text{THERM}}$  behavior/revision register) is cleared to 0, the fans will not run full-speed. The  $\overline{\text{THERM}}$  limit may be programmed at a lower temperature than the high temperature limit. This allows the system to run in silent mode, where the CPU can be throttled while the cooling fan is off. If the temperature continues to increase, and exceeds the high temperature limit, an  $\overline{\text{INT}}$  is generated. Software may then decide whether the fan should run to cool the CPU. This allows the system to run in SILENT MODE.
3. If the  $\overline{\text{THERM}}$ -to-Fan Enable bit is set to 1, the fan will run full-speed whenever  $\overline{\text{THERM}}$  is asserted low. In this case, both throttling and active cooling take place. If the high temperature limit is programmed to a lower value than the  $\overline{\text{THERM}}$  limit, exceeding the high temperature limit will assert  $\overline{\text{INT}}$  low. Software could change the speed of the fan depending on temperature readings. If the temperature continues to increase and exceeds the  $\overline{\text{THERM}}$  limit,  $\overline{\text{THERM}}$  asserts low to throttle the CPU and the fan runs full-speed. This allows the system to run in PERFORMANCE MODE, where active cooling takes place and the CPU is only throttled at high temperature.

Using the high temperature limit and the  $\overline{\text{THERM}}$  limit in this way allows the user to gain maximum performance from the system by only slowing it down, should it be at a critical temperature.

Although the ADM1031 does not have a dedicated Interrupt Mask Register, clearing the appropriate enable bits in Configuration Register 2 will clear the appropriate interrupts and mask out future interrupts on that channel. Disabling interrupt bits will prevent out-of-limit conditions from generating an interrupt or setting a bit in the Status Registers.

### USING $\overline{\text{THERM}}$ AS AN INPUT

The  $\overline{\text{THERM}}$  pin is an open-drain input/output pin. When used as an output, it signals overtemperature conditions. When asserted low as an output, the fan will be driven full-speed if the  $\overline{\text{THERM}}$ -to-Fan Enable bit is set to 1 (Bit 7 of Register 0x3F). When  $\overline{\text{THERM}}$  is pulled low as an input, the  $\overline{\text{THERM}}$  bit (Bit 7) of Status Register 2 is set to 1, and the fans are driven full-speed. Note that the  $\overline{\text{THERM}}$ -to-Fan Enable bit has no effect whenever  $\overline{\text{THERM}}$  is used as an input. If  $\overline{\text{THERM}}$  is pulled low as an input, and the  $\overline{\text{THERM}}$ -to-Fan Enable bit = 0, the fans will still be driven full-speed. The  $\overline{\text{THERM}}$ -to-Fan Enable bit only affects the behavior of  $\overline{\text{THERM}}$  when used as an output.

### STATUS REGISTERS

All out-of-limit conditions are flagged by status bits in Status Registers 1 and 2 (0x02, 0x03). Bits 0 and 1 (Alarm Speed, Fan Fault) of Status Register 1, once set, may be cleared by reading Status Register 1. Once the Alarm Speed bit is cleared, this bit will not be reasserted on the next monitoring cycle even if the condition still persists. This bit may be reasserted only if the

fan is no longer at Alarm Speed. Bit 1 (Fan Fault) is set whenever a fan tach failure is detected.

Once cleared, it will reassert on subsequent fan tach failures.

Bits 2 and 3 of Status Registers 1, 2 are the Remote 1, 2 Temperature High and Low status bits. Exceeding the high or low temperature limits for the external channel sets these status bits. Reading the status register clears these bits. However, these bits will be reasserted if the out-of-limit condition still exists on the next monitoring cycle. Bits 6 and 7 are the Local Temperature High and Low status bits. These behave exactly the same as the Remote Temperature High and Low status bits. Bit 4 of Status Register 1 indicates that the Remote Temperature  $\overline{\text{THERM}}$  limit has been exceeded. This bit gets cleared on a read of Status Register 1 (see Figure 5). Bit 5 indicates a Remote Diode Error. This bit will be a 1 if a short or open is detected on the Remote Temperature channel on power-up. If this bit is set to 1 on power-up, it cannot be cleared. Bit 6 of Status Register 2 (0x03) indicates that the Local  $\overline{\text{THERM}}$  limit has been exceeded. This bit is cleared on a read of Status Register 2. Bit 7 indicates that  $\overline{\text{THERM}}$  has been pulled low as an input. This bit can also be cleared on a read of Status Register 2.




Figure 5. Operation of  $\overline{\text{THERM}}$  and  $\overline{\text{INT}}$  Signals

Figure 5 shows the interaction between  $\overline{\text{INT}}$  and  $\overline{\text{THERM}}$ . Once a critical temperature  $\overline{\text{THERM}}$  limit is exceeded, both  $\overline{\text{INT}}$  and  $\overline{\text{THERM}}$  assert low. Reading the Status Registers clears the interrupt and the  $\overline{\text{INT}}$  pin goes high. However, the  $\overline{\text{THERM}}$  pin remains asserted until the measured temperature falls 5°C below the exceeded  $\overline{\text{THERM}}$  limit. This feature can be used to CPU throttle or drive a fan full speed for maximum cooling. Note, that the  $\overline{\text{INT}}$  pin for that interrupt source is not rearmed until the temperature has fallen below the  $\overline{\text{THERM}}$  limit -5°C. This prevents unnecessary interrupts from tying up valuable CPU resources.

### MODES OF OPERATION

The ADM1031 has four different modes of operation. These modes determine the behavior of the system.

1. Automatic Fan Speed Control Mode.
2. Filtered Automatic Fan Speed Control Mode.
3. PWM Duty Cycle Select Mode (directly sets fan speed under software control).
4. RPM Feedback Mode.

# ADM1031

## AUTOMATIC FAN SPEED CONTROL

The ADM1031 has a local temperature channel and two remote temperature channels, which may be connected to an on-chip diode-connected transistor on a CPU. These three temperature channels may be used as the basis for an automatic fan speed control loop to drive fans using Pulsewidth Modulation (PWM).

## HOW DOES THE CONTROL LOOP WORK?

The Automatic Fan Speed Control Loop is shown in Figure 6.




Figure 6. Automatic Fan Speed Control

In order for the fan speed control loop to work, certain loop parameters need to be programmed into the device.

1.  $T_{MIN}$ . The temperature at which the fan should switch on and run at minimum speed. The fan will only turn on once the temperature being measured rises above the  $T_{MIN}$  value programmed. The fan will spin up for a predetermined time (default = 2 secs). See Fan Spin-Up section for more details.
2.  $T_{RANGE}$ . The temperature range over which the ADM1031 will automatically adjust the fan speed. As the temperature increases beyond  $T_{MIN}$ , the PWM\_OUT duty cycle will be increased accordingly. The  $T_{RANGE}$  parameter actually defines the fan speed versus temperature slope of the control loop.
3.  $T_{MAX}$ . The temperature at which the fan will be at its maximum speed. At this temperature, the PWM duty cycle driving the fan will be 100%.  $T_{MAX}$  is given by  $T_{MIN} + T_{RANGE}$ . Since this parameter is the sum of the  $T_{MIN}$  and  $T_{RANGE}$  parameters, it does *not* need to be programmed into a register on-chip.
4. A hysteresis value of 5°C is included in the control loop to prevent the fan continuously switching on and off if the temperature is close to  $T_{MIN}$ . The fan will continue to run until such time as the temperature drops 5°C below  $T_{MIN}$ .

Figure 7 shows the different control slopes determined by the  $T_{RANGE}$  value chosen, and programmed into the ADM1031.  $T_{MIN}$  was set to 0°C to start all slopes from the same point. It can be seen how changing the  $T_{RANGE}$  value affects the PWM duty cycle versus temperature slope.




Figure 7. PWM Duty Cycle vs. Temperature Slopes ( $T_{RANGE}$ )

Figure 8 shows how, for a given  $T_{RANGE}$ , changing the  $T_{MIN}$  value affects the loop. Increasing the  $T_{MIN}$  value will increase the  $T_{MAX}$  (temperature at which the fan runs full speed) value, since  $T_{MAX} = T_{MIN} + T_{RANGE}$ . Note, however, that the PWM Duty Cycle vs Temperature slope remains exactly the same. Changing the  $T_{MIN}$  value merely shifts the control slope. The  $T_{MIN}$  may be changed in increments of 4°C.




Figure 8. Effect of Increasing  $T_{MIN}$  Value on Control Loop

## FAN SPIN-UP

As was previously mentioned, once the temperature being measured exceeds the  $T_{MIN}$  value programmed, the fan will turn on at minimum speed (default = 33% duty cycle). However, the problem with fans being driven by PWM is that 33% duty cycle is not enough to reliably start the fan spinning. The solution is to spin the fan up for a predetermined time, and once the fan has spun up, its running speed may be reduced in line with the temperature being measured.

The ADM1031 allows fan spin-up times between 200 ms and 8 seconds. Bits <2:0> of Fan Characteristics Registers 1 and 2 (Register 0x20, 0x21) program the fan spin-up times.

**Table V. Fan Spin-Up Times**

| Bits 2:0 | Spin-Up Time<br>(Fan Characteristics Registers 1, 2) |
|----------|------------------------------------------------------|
| 000      | 200 ms                                               |
| 001      | 400 ms                                               |
| 010      | 600 ms                                               |
| 011      | 800 ms                                               |
| 100      | 1 sec                                                |
| 101      | 2 secs (Default)                                     |
| 110      | 4 secs                                               |
| 111      | 8 secs                                               |

Once the Automatic Fan Speed Control Loop parameters have been chosen, the ADM1031 device may be programmed. The ADM1031 is placed into Automatic Fan Speed Control Mode by setting Bit 7 of Configuration Register 1 (Register 0x00). The device powers up in Automatic Fan Speed Control Mode by default. The control mode offers further flexibility in that the user can decide which temperature channel/channels control each fan.


**Table VI. Auto Mode Fan Behavior**

| Bits 6, 5 | Control Operation (Config Register 1)                                                    |
|-----------|------------------------------------------------------------------------------------------|
| 00        | Remote Temp 1 Controls Fan 1. Remote Temp 2 Controls Fan 2.                              |
| 01        | Remote Temp 1 Controls Fans 1 and 2.                                                     |
| 10        | Remote Temp 2 Controls Fans 1 and 2.                                                     |
| 11        | Maximum Speed Calculated by Local and Remote Temperature Channels Controls Fans 1 and 2. |


When Bits 5 and 6 of Config Register 1 are both set to 1, it offers increased flexibility. The local and remote temperature channels can have independently programmed control loops with different control parameters. Whichever control loop calculates the fastest fan speed based on the temperature being measured, drives the fans.

Figure 9 shows how the fan's PWM duty cycle is determined by two independent control loops. This is the type of Auto Mode Fan Behavior seen when Bits 5 and 6 of Config Register 1 are set to 11. Figure 9a shows the control loop for the Local Temperature channel. Its  $T_{MIN}$  value has been programmed to 20°C, and its  $T_{RANGE}$  value is 40°C. The local temperature's  $T_{MAX}$  will thus be 60°C. Figure 9b shows the control loop for the Remote Temperature channel. Its  $T_{MIN}$  value has been set to 0°C, while its  $T_{RANGE} = 80^\circ\text{C}$ . Therefore, the Remote Temperature's  $T_{MAX}$  value will be 80°C. Consider if both temperature channels measure 40°C. Both control loops will calculate a PWM duty cycle of 66%. Therefore, the fan will be driven at 66% duty cycle.

If both temperature channels measure 20°C, the local channel will calculate 33% PWM duty cycle, while the Remote 1 channel will calculate 50% PWM duty cycle. Thus, the fans will be driven at 50% PWM duty cycle. Consider the local temperature measuring 60°C while the Remote 1 temperature is measuring 70°C. The PWM duty cycle calculated by the local temperature control loop will be 100% (since the temperature =  $T_{MAX}$ ). The PWM duty cycle calculated by the Remote 1 temperature control loop at 70°C will be approximately 90%. So the fan will run full-speed (100% duty cycle). Remember, that the fan speed will be based on the fastest speed calculated, and is not necessarily based on the highest temperature measured. Depending on the control loop parameters programmed, a lower temperature on one channel, may actually calculate a faster speed, than a higher temperature on the other channel.



a.



b.

**Figure 9. Max Speed Calculated by Local and Remote Temperature Control Loops Drives Fan**

## PROGRAMMING THE AUTOMATIC FAN SPEED CONTROL LOOP

1. Program a value for  $T_{MIN}$ .
2. Program a value for the slope  $T_{RANGE}$ .
3.  $T_{MAX} = T_{MIN} + T_{RANGE}$ .
4. Program a value for Fan Spin-up Time.
5. Program the desired Automatic Fan Speed Control Mode Behavior, i.e., which temperature channel controls the fan.
6. Select Automatic Fan Speed Control Mode by setting Bit 7 of Configuration Register 1.

## OTHER CONTROL LOOP PARAMETERS

Having programmed all the above loop parameters, are there any other parameters to worry about?

$T_{MIN}$  was defined as the temperature at which the fan switched on and ran at minimum speed. This minimum speed is 33% duty cycle by default. If the minimum PWM duty cycle is programmed to 33%, the fan control loops will operate as previously described.

It should be noted however, that changing the minimum PWM duty cycle affects the control loop behavior.

Slope 1 of Figure 10 shows  $T_{MIN}$  set to 0°C and the  $T_{RANGE}$  chosen is 40°C. In this case, the fan's PWM duty cycle will vary over the range 33% to 100%. The fan will run full-speed at 40°C. If the minimum PWM duty cycle at which the fan runs at  $T_{MIN}$  is changed, its effect can be seen on Slopes 2 and 3. Take Case 2, where the minimum PWM duty cycle is reprogrammed from 33% (default) to 53%.




Figure 10. Effect of Changing Minimum Duty Cycle on Control Loop with Fixed  $T_{MIN}$  and  $T_{RANGE}$  Values

The fan will actually reach full speed at a much lower temperature; 28°C. Case 3 shows that when the minimum PWM duty cycle was increased to 73%, the temperature at which the fan ran full speed was 16°C. So the effect of increasing the minimum PWM duty cycle, with a fixed  $T_{MIN}$  and fixed  $T_{RANGE}$ , is that the fan will actually reach full speed ( $T_{MAX}$ ) at a lower temperature than  $T_{MIN} + T_{RANGE}$ . How can  $T_{MAX}$  be calculated?

In Automatic Fan Speed Control Mode, the register that holds the minimum PWM duty cycle at  $T_{MIN}$ , is the Fan Speed Config Register (Register 0x22). Table VII shows the relationship between the decimal values written to the Fan Speed Config Register and PWM duty cycle obtained.

Table VII. Programming PWM Duty Cycle

| Decimal Value | PWM Duty Cycle |
|---------------|----------------|
| 00            | 0%             |
| 01            | 7%             |
| 02            | 14%            |
| 03            | 20%            |
| 04            | 27%            |
| 05            | 33% (Default)  |
| 06            | 40%            |
| 07            | 47%            |
| 08            | 53%            |
| 09            | 60%            |
| 10 (0x0A)     | 67%            |
| 11 (0x0B)     | 73%            |
| 12 (0x0C)     | 80%            |
| 13 (0x0D)     | 87%            |
| 14 (0x0E)     | 93%            |
| 15 (0x0F)     | 100%           |

The temperature at which the fan will run full-speed (100% duty cycle) is given by:

$$T_{MAX} = T_{MIN} + ((Max\ DC - Min\ DC) \times T_{RANGE}/10)$$

where,

$T_{MAX}$  = Temperature at which fan runs full-speed.

$T_{MIN}$  = Temperature at which fan will turn on.

Max DC = Maximum Duty Cycle (100%) = 15 decimal.

Min DC = Duty Cycle at  $T_{MIN}$ , programmed in to Fan Speed Config Register (default = 33% = 5 decimal).

$T_{RANGE}$  = PWM Duty Cycle versus Temperature Slope.

### Example 1

$T_{MIN}$  = 0°C,  $T_{RANGE}$  = 40°C

Min DC = 53% = 8 Decimal (Table VII)

Calculate  $T_{MAX}$ .

$$T_{MAX} = T_{MIN} + ((Max\ DC - Min\ DC) \times T_{RANGE}/10)$$

$$T_{MAX} = 0 + ((100\% \text{ DC} - 53\% \text{ DC}) \times 40/10)$$

$$T_{MAX} = 0 + ((15 - 8) \times 4) = 28$$

**$T_{MAX}$  = 28°C** (As seen on Slope 2 of Figure 10)

### Example 2

$T_{MIN}$  = 0°C,  $T_{RANGE}$  = 40°C

Min DC = 73% = 11 Decimal (Table VII)

Calculate  $T_{MAX}$ .

$$T_{MAX} = T_{MIN} + ((Max\ DC - Min\ DC) \times T_{RANGE}/10)$$

$$T_{MAX} = 0 + ((100\% \text{ DC} - 73\% \text{ DC}) \times 40/10)$$

$$T_{MAX} = 0 + ((15 - 11) \times 4) = 16$$

**$T_{MAX}$  = 16°C** (As seen on Slope 3 of Figure 10)

### Example 3

$T_{MIN}$  = 0°C,  $T_{RANGE}$  = 40°C

Min DC = 33% = 5 Decimal (Table VII)

Calculate  $T_{MAX}$ .

$$T_{MAX} = T_{MIN} + ((Max\ DC - Min\ DC) \times T_{RANGE}/10)$$

$$T_{MAX} = 0 + ((100\% \text{ DC} - 33\% \text{ DC}) \times 40/10)$$

$$T_{MAX} = 0 + ((15 - 5) \times 4) = 40$$

**$T_{MAX}$  = 40°C** (As seen on Slope 1 of Figure 10)

In this case, since the Minimum Duty Cycle is the default 33%, the equation for  $T_{MAX}$  reduces to:

$$T_{MAX} = T_{MIN} + ((Max\ DC - Min\ DC) \times T_{RANGE}/10)$$

$$T_{MAX} = T_{MIN} + ((15 - 5) \times T_{RANGE}/10)$$

$$T_{MAX} = T_{MIN} + (10 \times T_{RANGE}/10)$$

$$\mathbf{T_{MAX} = T_{MIN} + T_{RANGE}}$$

## RELEVANT REGISTERS FOR AUTOMATIC FAN SPEED CONTROL MODE

### Register 0x00 Configuration Register 1

- <7> Logic 1 selects Automatic Fan Speed Control, Logic 0 selects software control (Default = 1).
- <6:5> 00 = Remote Temp 1 controls Fan 1, Remote Temp 2 controls Fan 2.  
 01 = Remote Temp 1 controls Fans 1 and 2  
 10 = Remote Temp 2 controls Fans 1 and 2  
 11 = Fastest Calculated Speed controls Fans 1 and 2

### Register 0x20, 0x21 Fan Characteristics Registers 1, 2

- <2:0> Fan X Spin-Up Time  
 000 = 200 ms  
 001 = 400 ms  
 010 = 600 ms  
 011 = 800 ms  
 100 = 1 sec  
 101 = 2 secs (Default)  
 110 = 4 secs  
 111 = 8 secs
- <5:3> PWM Frequency Driving the Fan  
 000 = 11.7 Hz  
 001 = 15.6 Hz  
 010 = 23.4 Hz  
 011 = 31.25 Hz (Default)  
 100 = 37.5 Hz  
 101 = 46.9 Hz  
 110 = 62.5 Hz  
 111 = 93.5 Hz
- <7:6> Speed Range N; defines the lowest fan speed that can be measured by the device.  
 00 = 1: Lowest Speed = 2647 RPM  
 01 = 2: Lowest Speed = 1324 RPM  
 10 = 4: Lowest Speed = 662 RPM  
 11 = 8: Lowest Speed = 331 RPM

### Register 0x22 Fan Speed Configuration Register

- <3:0> Min Speed: This nibble contains the speed at which the fan will run when the temperature is at  $T_{MIN}$ . The default is 0x05, meaning that the fan will run at 33% duty cycle when the temperature is at  $T_{MIN}$ .
- <7:4> Min Speed: Determines the minimum PWM cycle for Fan 2 in Automatic Fan Speed Control Mode.

### Register 0x24 Local Temperature $T_{MIN}/T_{RANGE}$

- <7:3> Local Temperature  $T_{MIN}$ . These bits set the temperature at which the fan will turn on when under Auto Fan Speed Control.  $T_{MIN}$  can be programmed in 4°C increments.

00000 = 0°C  
 00001 = 4°C  
 00010 = 8°C  
 00011 = 12°C

01000 = 32°C (Default)

11110 = 120°C  
 11111 = 124°C

- <2:0> Local Temperature  $T_{RANGE}$ . This nibble sets the temperature range over which Automatic Fan Speed Control takes place.

000 = 5°C  
 001 = 10°C  
 010 = 20°C  
 011 = 40°C  
 100 = 80°C

### Register 0x25, 0x26 Remote 1, 2 Temperature $T_{MIN}/T_{RANGE}$

- <7:3> Remote Temperature  $T_{MIN}$ . Sets the temperature at which the fan will switch on based on Remote X Temperature Readings.

00000 = 0°C  
 00001 = 4°C  
 00010 = 8°C  
 00011 = 12°C

01100 = 48°C

11110 = 120°C  
 11111 = 124°C

- <2:0> Remote Temperature  $T_{RANGE}$ . This nibble sets the temperature range over which the fan will be controlled based on Remote Temperature readings.

000 = 5°C  
 001 = 10°C  
 010 = 20°C  
 011 = 40°C  
 100 = 80°C

# ADM1031

## FILTERED CONTROL MODE

The Automatic Fan Speed Control Loop reacts instantaneously to changes in temperature, i.e., the PWM duty cycle will respond immediately to temperature change. In certain circumstances, we may not want the PWM output to react instantaneously to temperature changes. If significant variations in temperature were found in a system, this would have the effect of changing the fan speed, which could be obvious to someone in close proximity. One way to improve the system's acoustics would be to slow down the loop so that the fan ramps slowly to its newly calculated fan speed. This also ensures that temperature transients will effectively be ignored, and the fan's operation will be smooth.

There are two means by which to apply filtering to the Automatic Fan Speed Control Loop. The first method is to ramp the fan speed at a predetermined rate, to its newly calculated value instead of jumping directly to the new fan speed. The second approach involves changing the on-chip ADC sample rate, to change the number of temperature readings taken per second.

The filtered mode on the ADM1031 is invoked by setting Bit 0 of the Fan Filter Register (Register 0x23) for Fan 1 and Bit 1 for Fan 2. Once the Fan Filter Register has been written to, and all other control loop parameters ( $T_{MIN}$ ,  $T_{RANGE}$ , etc.) have been programmed, the device may be placed into Automatic Fan Speed Control Mode by setting Bit 7 of Configuration Register 1 (Register 0x00) to 1.

### Effect of Ramp Rate on Filtered Mode

Bits <6:5> of the Fan Filter Register determine the ramp rate in Filtered Mode. The PWM\_OUT signal driving the fan will have a period,  $T$ , given by the PWM\_OUT drive frequency,  $f$ , since  $T = 1/f$ . For a given PWM period,  $T$ , the PWM period is subdivided in to 240 equal time slots. One time slot corresponds to the smallest possible increment in PWM duty cycle. A PWM signal of 33% duty cycle will thus be high for  $1/3 \times 240$  time slots and low for  $2/3 \times 240$  time slots. Therefore, 33% PWM duty cycle corresponds to a signal which is high for 80 time slots and low for 160 time slots.




Figure 11. 33% PWM Duty Cycle Represented in Time Slots

The ramp rates in Filtered Mode are selectable between 1, 2, 4, and 8. The ramp rates are actually discrete time slots. For example, if the ramp rate = 8, then eight time slots will be added to the PWM\_OUT high duty cycle each time the PWM\_OUT duty cycle needs to be increased. Figure 12 shows how the Filtered Mode algorithm operates.




Figure 12. Filtered Mode Algorithm

The Filtered Mode algorithm calculates a new PWM duty cycle based on the temperature measured. If the new PWM duty cycle value is greater than the previous PWM value, the previous PWM duty cycle value is incremented by either 1, 2, 4, or 8 time slots (depending on the setting of bits <6:5> of the Fan Filter Register). If the new PWM duty cycle value is less than the previous PWM value, the previous PWM duty cycle is decremented by 1, 2, 4, or 8 time slots. Each time the PWM duty cycle is incremented or decremented, it is stored as the previous PWM duty cycle for the next comparison.

So what does an increase of 1, 2, 4, or 8 time slots actually mean in terms of PWM duty cycle?

A Ramp Rate of 1 corresponds to one time slot, which is  $1/240$  of the PWM period. In Filtered Auto Fan Speed Control Mode, incrementing or decrementing by 1 changes the PWM output duty cycle by 0.416%.

Table VIII. Effect of Ramp Rates on PWM\_OUT

| Ramp Rate | PWM Duty Cycle Change |
|-----------|-----------------------|
| 1         | 0.416%                |
| 2         | 0.833%                |
| 4         | 1.66%                 |
| 8         | 3.33%                 |

So programming a ramp rate of 1, 2, 4, or 8 simply increases or decreases the PWM duty cycle by the amounts shown in Table VIII, depending on whether the temperature is increasing or decreasing.

Figure 13 shows remote temperature plotted against PWM duty cycle for Filtered Mode. The ADC sample rate is the highest sample rate; 11.25 kHz. The ramp rate is set to 8 which would correspond to the fastest ramp rate. With these settings it took approximately 12 seconds to go from 0% duty cycle to 100% duty cycle (full-speed). The  $T_{MIN}$  value =  $32^{\circ}\text{C}$  and the  $T_{RANGE}$  =  $80^{\circ}\text{C}$ . It can be seen that even though the temperature increased very rapidly, the fan gradually ramps up to full speed.




Figure 13. Filtered Mode with Ramp Rate = 8

Figure 14 shows how changing the ramp rate from 8 to 4 affects the control loop. The overall response of the fan is slower. Since the ramp rate is reduced, it takes longer for the fan to achieve full running speed. In this case, it took approximately 22 seconds for the fan to reach full speed.




Figure 14. Filtered Mode with Ramp Rate = 4

Figure 15 shows the PWM output response for a ramp rate of 2. In this instance the fan took about 54 seconds to reach full running speed.




Figure 15. Filtered Mode with Ramp Rate = 2

Finally, Figure 16 shows how the control loop reacts to temperature with the slowest ramp rate. The ramp rate is set to 1, while all other control parameters remain the same. With the slowest ramp rate selected it took 112 seconds for the fan to reach full speed.




Figure 16. Filtered Mode with Ramp Rate = 1

As can be seen from Figures 13 through 16, the rate at which the fan will react to temperature change is dependent on the ramp rate selected in the Fan Filter Register. The higher the ramp rate, the faster the fan will reach the newly calculated fan speed.

Figure 17 shows the behavior of the PWM output as temperature varies. As the temperature is rising, the fan speed will ramp up. Small drops in temperature will not affect the ramp-up function since the newly calculated fan speed will still be higher than the previous PWM value. The Filtered Mode allows the PWM output to be made less sensitive to temperature variations. This will be dependent on the ramp rate selected and the ADC sample rate programmed into the Fan Filter Register.




Figure 17. How Fan Reacts to Temperature Variation in Filtered Mode

# ADM1031

## Effect of ADC Sample Rate on Filtered Mode

The second means by which to change the Filtered Mode characteristics is to adjust the ADC sample rate. The faster the ADC sample rate, the more temperature samples are obtained per second. One way to apply filtering to the control loop is to slow down the ADC sampling rate. This means that the number of iterations of the Filtered Mode algorithm per second is effectively reduced. If the number of temperature measurements per second is reduced, how often the PWM\_OUT signal controlling the fan is updated is also reduced.

Bits <4:2> of the Fan Filter Register (Reg 0x23) set the ADC sample rate. The default ADC sample rate is 1.4 kHz. The ADC sample rate is selectable from 87.5 Hz to 11.2 kHz. Table IX shows how many temperature samples are obtained per second, for each of the ADC sample rates.

**Table IX. Temperature Updates per Second**

| ADC Sample Rate | Temperature Updates/Sec |
|-----------------|-------------------------|
| 87.5 Hz         | 0.0625                  |
| 175 Hz          | 0.125                   |
| 350 Hz          | 0.25                    |
| 700 Hz          | 0.5                     |
| 1.4 kHz         | 1 (Default)             |
| 2.8 kHz         | 2                       |
| 5.6 kHz         | 4                       |
| 11.2 kHz        | 8                       |

## RELEVANT REGISTERS FOR FILTERED AUTOMATIC FAN SPEED CONTROL MODE

In addition to the registers used to program the normal Automatic Fan Speed Control Mode, the following register needs to be programmed.

### Register 0x23 Fan Filter Register

- <7> Spin-up Disable :- when this bit is set to 1, fan spin-up is disabled. (Default = 0)
- <6:5> Ramp Rate: these bits set the ramp rate for filtered mode.
  - 00 = 1 (0.416% Duty Cycle Change)
  - 01 = 2 (0.833% Duty Cycle Change)
  - 10 = 4 (1.66% Duty Cycle Change)
  - 11 = 8 (3.33% Duty Cycle Change)
- <4:2> ADC Sample Rate
  - 000 = 87.5 Hz
  - 001 = 175 Hz
  - 010 = 350 Hz
  - 011 = 700 Hz
  - 100 = 1.4 kHz (Default)
  - 101 = 2.8 kHz
  - 110 = 5.6 kHz
  - 111 = 11.2 kHz
- <1> Fan 2 Filter Enable: when this bit is set to 1, it enables filtering on Fan 2. Default = 0.
- <0> Fan 1 Filter Enable: when this bit is set to 1, it enables filtering on Fan 1. Default = 0.

## PROGRAMMING THE FILTERED AUTOMATIC FAN SPEED CONTROL LOOP

1. Program a value for  $T_{MIN}$ .
2. Program a value for the slope  $T_{RANGE}$ .
3.  $T_{MAX} = T_{MIN} + T_{RANGE}$ .
4. Program a value for Fan Spin-up Time.
5. Program the desired Automatic Fan Speed Control Mode Behavior, i.e., which temperature channel controls the fan.
6. Program a ramp rate for the filtered mode.
7. Program the ADC sample rate in the Fan Filter Register.
8. Set Bit 0 to enable fan filtered mode for Fan 1.
9. Set Bit 1 to enable the fan filtered mode for Fan 2.
10. Select Automatic Fan Speed Control Mode by setting Bit 7 of Configuration Register 1.

## PWM DUTY CYCLE SELECT MODE

The ADM1031 may be operated under software control by clearing Bit 7 of Configuration Register 1 (Register 0x00). This allows the user to directly control PWM duty cycle for each fan.

Clearing Bits 5, 6 of Configuration Register 1 allows fan control by varying PWM duty cycle. Values of duty cycle between 0% to 100% may be written to the Fan Speed Config Register (0x22) to control the speed of each fan. Table X shows the relationship between hex values written to the Fan Speed Configuration Register and PWM duty cycle obtained.

**Table X. PWM Duty Cycle Select Mode**

| Hex Value | PWM Duty Cycle |
|-----------|----------------|
| 00        | 0%             |
| 01        | 7%             |
| 02        | 14%            |
| 03        | 20%            |
| 04        | 27%            |
| 05        | 33%            |
| 06        | 40%            |
| 07        | 47%            |
| 08        | 53%            |
| 09        | 60%            |
| 0A        | 67%            |
| 0B        | 73%            |
| 0C        | 80%            |
| 0D        | 87%            |
| 0E        | 93%            |
| 0F        | 100%           |

Bits <3:0> set the PWM duty cycle for Fan 1; Bits <7:4> set the PWM duty cycle for Fan 2.

## RPM FEEDBACK MODE

The second method of fan speed control under software is RPM Feedback Mode. This involves programming the desired fan RPM value to the device to set fan speed. The advantages include a very tightly maintained fan RPM over the fan's life, and virtually no acoustic pollution due to fan speed variation.

Fans typically have manufacturing tolerances of  $\pm 20\%$ , meaning a wide variation in speed for a typical batch of identical fan models. If it is required that all fans run at exactly 5000 RPM, it may be necessary to specify fans with a nominal fan speed of 6250 RPM. However, many of these fans will run too fast and make excess noise. A fan with nominal speed of 6250 RPM could run as fast as 7000 RPM at 100% PWM duty cycle. RPM Mode will allow all of these fans to be programmed to run at the desired RPM value.

Clearing Bit 7 of Configuration Register 1 (Reg 0x00) to 0 places the ADM1031 under software control. Once under software control, the device may be placed in to RPM Feedback Mode by writing to Bits 5, 6 of Configuration Register 1. Writing a 1 to Bits 5, 6 selects RPM Feedback Mode for each fan. Once RPM Feedback Mode has been selected, the required fan RPM may be written to the Fan Tach High Limit Registers (0x10, 0x11). The RPM Feedback Mode function allows a fan RPM value to be programmed into the device, and the ADM1031 will maintain the selected RPM value by monitoring the fan tach and speeding up the fan as necessary, should the fan start to slow down. Conversely, should the fan start to speed up due to aging, the RPM feedback will slow the fan down to maintain the correct RPM speed. The value to be programmed into each Fan Tach High Limit Register is given by:

$$\text{Count} = (f \times 60) / R \times N$$

where:

$$f = 11.25 \text{ kHz}$$

$R$  = desired RPM value

$N$  = Speed Range; MUST be set to 2

The speed range,  $N$ , really determines what the slowest fan speed measured can be before generating an interrupt. The slowest fan speed will be measured when the Count value reaches 255.

Since speed range,  $N$ , = 2,

$$\text{Count} = (f \times 60) / R \times N$$

$$R = (f \times 60) / \text{Count} \times N$$

$$R = (11250 \times 60) / 255 \times 2$$

$$R = (675000) / 510$$

$$R = 1324 \text{ RPM, fan fail detect speed.}$$

### Programming RPM Values in RPM Feedback Mode

Rather than writing a value such as 5000 to a 16-bit register, an 8-bit count value is programmed instead. The count to be programmed is given by:

$$\text{Count} = (f \times 60) / R \times N$$

where:

$$f = 11.25 \text{ kHz}$$

$R$  = desired RPM value

$N$  = Speed Range = 2

### Example 1:

If the desired value for RPM Feedback Mode is 5000 RPM, what value needs to be programmed for Count?

$$\text{Count} = (f \times 60) / R \times N$$

Since the desired RPM value,  $R$ , is 5000 RPM, the value for Count is:

$$N = 2:$$

$$\text{Count} = (11250 \times 60) / 5000 \times 2$$

$$\text{Count} = 675000 / 10000$$

$$\text{Count} = 67 \text{ (assumes 2 tach pulses/rev).}$$

### Example 2:

If the desired value for RPM Feedback Mode is 3650 RPM, what value needs to be programmed for Count?

$$\text{Count} = (f \times 60) / R \times N$$

Since the desired RPM value,  $R$ , is 3650 RPM, the value for Count is:

$$N = 2:$$

$$\text{Count} = (11250 \times 60) / 3650 \times 2$$

$$\text{Count} = 675000 / 7300$$

$$\text{Count} = 92 \text{ (assumes 2 tach pulses/rev).}$$

Once the count value has been calculated, it should be written to the Fan Tach High Limit Register. It should be noted that in RPM Feedback Mode, there is no high limit register for under-speed detection that can be programmed as there are in the other fan speed control modes. The only time each fan will indicate a fan failure condition is whenever the count reaches 255. Since the speed range,  $N$ , = 2, the fan will fail if its speed drops below 1324 RPM.

### Programming RPM Values

1. Choose the RPM value to be programmed.
2. Set speed range value,  $N$ , = 2.
3. Calculate count value based on RPM and speed range values chosen. Use Count Equation to calculate Count Value.
4. Clear Bit 7 of Configuration Register 1 (Reg. 0x00) to place the ADM1031 under software control.
5. Write a 1 to Bit 5 of Configuration Register 1 to place the device in RPM Feedback Mode.
6. Write the calculated Count value to the Fan Tach High Limit Register (Reg. 0x10). The fan speed will now go to the desired RPM value and maintain that fan speed.

### RPM Feedback Mode Limitations

RPM feedback mode only controls Fan RPM over a limited fan speed range of about 75% to 100%. However, this should be enough range to overcome fan manufacturing tolerance. In practice, however, the program must not function at too low an RPM value for the fan to run at, or the RPM Mode will not operate.

To find the lowest RPM value allowed for a given fan, do the following:

# ADM1031

1. Run the fan at 53% PWM duty cycle in Software Mode. Clear Bits 5 and 7 of Configuration Register 1 (Reg 0x00) to enter PWM duty cycle mode. Write 0x08 to the Fan Speed Config Register (Reg 0x22) to set the PWM output to 53% duty cycle.
2. Measure the fan RPM. This represents the fan RPM below which the RPM mode will fail to operate. Do NOT program a lower RPM than this value when using RPM Feedback mode.
3. Ensure that Speed Range,  $N_s = 2$  when using RPM Feedback mode.

Fans come in a variety of different options. One distinguishing feature of fans is the number of poles that a fan has internally. The most common fans available have four, six, or eight poles. The number of poles the fan has generally affects the number of pulses per revolution the fan outputs.

If the ADM1031 is used to drive fans other than 4-pole fans that output 2 tach pulses/revolution, then the fan speed measurement equation needs to be adjusted to calculate and display the correct fan speed, and also to program the correct count value in RPM Feedback Mode.

## FAN SPEED MEASUREMENT EQUATIONS

For a 4-pole fan (2 tach pulses/rev):

$$\text{Fan RPM} = (f \times 60) / \text{Count} \times N$$

For a 6-pole fan (3 tach pulses/rev):

$$\text{Fan RPM} = (f \times 60) / (\text{Count} \times N \times 1.5)$$

For an 8-pole fan (4 tach pulses/rev):

$$\text{Fan RPM} = (f \times 60) / (\text{Count} \times N \times 2)$$

If in doubt as to the number of poles the fans used have, or the number of tach output pulses/rev, consult the fan manufacturer's data sheet, or contact the fan vendor for more information.

## FAN DRIVE USING PWM CONTROL

The external circuitry required to drive a fan using PWM control is extremely simple. A single NMOS FET is the only drive transistor required. The specifications of the MOSFET depend on the maximum current required by the fan being driven. Typical notebook fans draw a nominal 170 mA, and so SOT devices can be used where board space is a constraint. If driving several fans in parallel from a single PWM output, or driving larger server fans, the MOSFET will need to handle the higher current requirements. The only other stipulation is that the MOSFET should have a gate voltage drive,  $V_{GS} < 3.3 \text{ V}$ , for direct interfacing to the PWM\_OUT pin. The MOSFET should also have a low on-resistance to ensure that there is not significant voltage drop across the FET. This would reduce the maximum operating speed of the fan.

Figure 18 shows how a 3-wire fan may be driven using PWM control.




Figure 18. Interfacing the ADM1031 to a 3-Wire Fan

The NDT3055L n-type MOSFET was chosen since it has 3.3 V gate drive, low on-resistance, and can handle 3.5 A of current. Other MOSFETs may be substituted based on the system's fan drive requirements.




Figure 19. Interfacing the ADM1031 to a 2-Wire Fan

Figure 19 shows how a 2-wire fan may be connected to the ADM1031. This circuit allows the speed of the 2-wire fan to be measured even though the fan has no dedicated Tach signal. A series  $R_{SENSE}$  resistor in the fan circuit converts the fan commutation pulses into a voltage. This is ac-coupled into the ADM1031 through the  $0.01 \mu\text{F}$  capacitor. On-chip signal conditioning allows accurate monitoring of fan speed. For typical notebook fans drawing approximately 170 mA, a  $2 \Omega$   $R_{SENSE}$  value is suitable. For fans such as desktop or server fans that draw more current,  $R_{SENSE}$  may be reduced. The smaller  $R_{SENSE}$  is, the better, since more voltage will be developed across the fan, and the fan will spin faster. Figure 20 shows a typical plot of the sensing waveform at the TACH/AIN pin. The most important thing is that the negative-going spikes are more than 250 mV in amplitude. This will be the case for most fans when  $R_{SENSE} = 2 \Omega$ . The value of  $R_{SENSE}$  can be reduced as long as the voltage spikes at the TACH/AIN pin are greater than 250 mV. This allows fan speed to be reliably determined.




Figure 20. Fan Speed Sensing Waveform at TACH/AIN Pin

### FAN SPEED MEASUREMENT

The fan counter does not count the fan tach output pulses directly, because the fan speed may be less than 1000 RPM and it would take several seconds to accumulate a reasonably large and accurate count. Instead, the period of the fan revolution is measured by gating an on-chip 11.25 kHz oscillator into the input of an 8-bit counter. The fan speed measuring circuit is initialized on the rising edge of a PWM high output if fan speed measurement is enabled (Bit 2, 3 of Configuration Register 2 = 1). It then starts counting on the rising edge of the second tach pulse and counts for two fan tach periods, until the rising edge of the fourth tach pulse, or until the counter overranges if the fan tach period is too long. The measurement cycle will repeat until monitoring is disabled. The fan speed measurement is stored in the Fan Speed Reading register at address 0x08, 0x09.

The fan speed count is given by:

$$\text{Count} = (f \times 60) / R \times N$$

where:

$f$  = 11.25 kHz

$R$  = Fan Speed in RPM.

$N$  = Speed Range (Either 1, 2, 4, or 8)

The frequency of the oscillator can be adjusted to suit the expected running speed of the fan by varying  $N$ , the Speed Range. The oscillator frequency is set by Bits 7 and 6 of Fan Characteristics Registers 1, 2 (0x20, 0x21) as shown in Table XI. Figure 21 shows how the fan measurements relate to the PWM\_OUT pulse trains.

Table XI. Oscillator Frequencies

| Bit 7 | Bit 6 | N | Oscillator Frequency (kHz) |
|-------|-------|---|----------------------------|
| 0     | 0     | 1 | 11.25                      |
| 0     | 1     | 2 | 5.625                      |
| 1     | 0     | 4 | 2.812                      |
| 1     | 1     | 8 | 1.406                      |




Figure 21. Fan Speed Measurement

In situations where different output drive circuits are used for fan drive, it may be desirable to invert the PWM drive signal. Setting Bit 3 of Configuration Register 1 (0x00) to 1, inverts the PWM\_OUT signal. This makes the PWM\_OUT pin high for 100% duty cycle. Bit 3 of Configuration Register 1 should generally be set to 1, when using an n-MOS device to drive the fan. If using a p-MOS device, Bit 3 of Configuration Register 1 should be cleared to 0.

### FAN FAULTS

The  $\overline{\text{FAN\_FAULT}}$  output (Pin 8) is an active-low, open-drain output used to signal fan failure to the system processor. Writing a Logic 1 to Bit 4 of Configuration Register 1 (0x00) enables the  $\overline{\text{FAN\_FAULT}}$  output pin. The  $\overline{\text{FAN\_FAULT}}$  output is enabled by default. The  $\overline{\text{FAN\_FAULT}}$  output asserts low only when five consecutive interrupts are generated by the ADM1031 device due to the fan running underspeed, or if the fan is completely stalled. Note that the Fan Tach High Limit must be exceeded by at least one before a  $\overline{\text{FAN\_FAULT}}$  can be generated. For example, if we are only interested in getting a  $\overline{\text{FAN\_FAULT}}$  if the fan stalls, then the fan speed value will be 0xFF for a failed fan. Therefore, we should make the Fan Tach High Limit = 0xFE to allow  $\overline{\text{FAN\_FAULT}}$  to be asserted after five consecutive fan tach failures.

Figure 22 shows the relationship between  $\overline{\text{INT}}$ ,  $\overline{\text{FAN\_FAULT}}$ , and the PWM drive channel. The PWM\_OUT channel is driving a fan at some PWM duty cycle, say 50%, and the fan's tach signal (or fan current for a 2-wire fan) is being monitored at the TACH/AIN pin. Tach pulses are being generated by the fan, during the high time of the PWM duty cycle train. The tach is pulled high during the off time of the PWM train because the fan is connected high-side to the n-MOS device.

Suppose the fan has twice previously failed its fan speed measurement. Looking at Figure 22, PWM\_OUT is brought high for two seconds, to restart the fan if it has stalled. Sometime later a third tach failure occurs. This is evident by the tach signal being low during the high time of the PWM pulse, causing the Fan Speed Reading register to reach its maximum count of 255. Since the tach limit has been exceeded, an interrupt is generated on the  $\overline{\text{INT}}$  pin. The Fan Fault bit (Bit 1) of Interrupt Status Register 1 (Register 0x02) will also be asserted. Once the processor has acknowledged the  $\overline{\text{INT}}$  by reading the status register, the  $\overline{\text{INT}}$  is cleared. PWM\_OUT is then brought high for another two seconds to restart the fan. Subsequent fan failures cause  $\overline{\text{INT}}$  to be reasserted and the PWM\_OUT signal is brought high for two seconds (fan spin-up default) each time to restart the fan. Once the fifth tach failure occurs, the failure is deemed to be catastrophic and the  $\overline{\text{FAN\_FAULT}}$  pin is asserted low. PWM\_OUT is brought high to attempt to restart the fan.

# ADM1031

The  $\overline{\text{INT}}$  pin will continue to generate interrupts after the assertion of  $\text{FAN\_FAULT}$  since tach measurement continues even after fan failure. Should the fan recover from its failure condition, the  $\text{FAN\_FAULT}$  signal will be negated, and the fan will return to its normal operating speed.

Figure 23 shows a typical application circuit for the ADM1031. Temperature monitoring can be based around a CPU diode or discrete transistor measuring thermal hotspots. Either 2- or 3-wire fans may be monitored by the ADM1031, as shown.





Figure 22. Operation of  $\text{FAN\_FAULT}$  and Interrupt Pins



\*IN ACTUAL APPLICATION, BOTH FANS MUST BE 2-WIRE OR 3-WIRE TYPE. A SINGLE BIT CONTROLS WHETHER TACH1/AIN1 AND TACH2/AIN2 ARE ANALOG OR DIGITAL INPUTS.

Figure 23. Typical Application Circuit

Table XII. Registers

| Register Name                            | Address A7–A0 in Hex | Comments                                                                                                                                                                                     |
|------------------------------------------|----------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Value Registers                          | 0x08–0x1E            | See Table XIII.                                                                                                                                                                              |
| Device ID Register                       | 0x3D                 | This location contains the device identification number. Since this device is the ADM1031, this register contains 0x31. This register is read only.                                          |
| Company ID                               | 0x3E                 | This location contains the company identification number (0x41). This register is read only.                                                                                                 |
| <u>THERM</u> Behavior/Revision           | 0x3F                 | This location contains the revision number of the device. The lower four bits reflect device revisions [3:0]. Bit 7 of this register is the <u>THERM</u> -to-fan enable bit. See Table XXII. |
| Configuration Register 1                 | 0x00                 | See Table XIV. Power-on value = 1001 0000.                                                                                                                                                   |
| Configuration Register 2                 | 0x01                 | See Table XV. Power-on value = 0111 1111.                                                                                                                                                    |
| Status Register 1                        | 0x02                 | See Table XVI. Power-on value = 0000 0000.                                                                                                                                                   |
| Status Register 2                        | 0x03                 | See Table XVII. Power-on value = 0000 0000.                                                                                                                                                  |
| Manufacturer's Test Register             | 0x07                 | This register is used by the manufacturer for test purposes only. This register should not be read from or written to in normal operation.                                                   |
| Fan Characteristics Register 1           | 0x20                 | See Table XIX. Power-on value = 0101 1101.                                                                                                                                                   |
| Fan Characteristics Register 2           | 0x21                 | See Table XX. Power-on value = 0101 1101.                                                                                                                                                    |
| Fan Speed Configuration Register         | 0x22                 | See Table XXI. Power-on value = 0101 0101.                                                                                                                                                   |
| Fan Filter Register                      | 0x23                 | See Table XXII. Power-on value = 0101 0000.                                                                                                                                                  |
| Local Temperature $T_{MIN}/T_{RANGE}$    | 0x24                 | See Table XXIII. Power-on value = 0100 0001.                                                                                                                                                 |
| Remote 1 Temperature $T_{MIN}/T_{RANGE}$ | 0x25                 | See Table XXIV. Power-on value = 0110 0001.                                                                                                                                                  |
| Remote 2 Temperature $T_{MIN}/T_{RANGE}$ | 0x26                 | See Table XXV. Power-on value = 0110 0001.                                                                                                                                                   |

Table XIII. Value Registers

| Address | Read/Write | Description                                                                                                                                                                                                                                                                         |
|---------|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 0x06    | Read/Only  | Extended Temperature Resolution (see Table XVIII).                                                                                                                                                                                                                                  |
| 0x08    | Read/Write | Fan 1 Speed—this register contains the value of the Fan 1 tach measurement.                                                                                                                                                                                                         |
| 0x09    | Read/Write | Fan 2 Speed—this register contains the value of the Fan 2 tach measurement.                                                                                                                                                                                                         |
| 0x0A    | Read/Only  | Local Temperature Value—this register contains the 8 MSBs of the local temperature measurement.                                                                                                                                                                                     |
| 0x0B    | Read/Only  | Remote 1 Temperature Value—this register contains the 8 MSBs of the Remote 1 temperature reading.                                                                                                                                                                                   |
| 0x0C    | Read/Only  | Remote 2 Temperature Value—this register contains the 8 MSBs of the Remote 2 temperature reading.                                                                                                                                                                                   |
| 0x0D    | Read/Write | Local Temperature Offset—See Table XXVII. (Power-On Default = 00h.)                                                                                                                                                                                                                 |
| 0x0E    | Read/Write | Remote 1 Temperature Offset—See Table XXVIII. (Power-On Default = 00h.)                                                                                                                                                                                                             |
| 0x0F    | Read/Write | Remote 2 Temperature Offset—See Table XXIX. (Power-On Default = 00h.)                                                                                                                                                                                                               |
| 0x10    | Read/Write | Fan 1 Tach High Limit—this register contains the limit for the Fan 1 tach measurement. Since the tach circuit counts between pulses, a slow fan will result in a large measured value, so exceeding the limit is the way to detect a slow or stalled fan. (Power-On Default = FFh.) |
| 0x11    | Read/Write | Fan 2 Tach High Limit—this register contains the limit for the Fan 2 tach measurement. Since the tach circuit counts between pulses, a slow fan will result in a large measured value, so exceeding the limit is the way to detect a slow or stalled fan. (Power-On Default = FFh.) |
| 0x14    | Read/Write | Local Temperature High Limit (Power-On Default 60°C).                                                                                                                                                                                                                               |
| 0x15    | Read/Write | Local Temperature Low Limit (Power-On Default 0°C).                                                                                                                                                                                                                                 |
| 0x16    | Read/Write | Local Temperature Therm Limit (Power-On Default 70°C).                                                                                                                                                                                                                              |
| 0x18    | Read/Write | Remote 1 Temperature High Limit (Power-On Default 80°C).                                                                                                                                                                                                                            |
| 0x19    | Read/Write | Remote 1 Temperature Low Limit (Power-On Default 0°C).                                                                                                                                                                                                                              |
| 0x1A    | Read/Write | Remote 1 Temperature Therm Limit (Power-On Default 100°C).                                                                                                                                                                                                                          |
| 0x1C    | Read/Write | Remote 2 Temperature High Limit (Power-On Default 80°C).                                                                                                                                                                                                                            |
| 0x1D    | Read/Write | Remote 2 Temperature Low Limit (Power-On Default 0°C).                                                                                                                                                                                                                              |
| 0x1E    | Read/Write | Remote 2 Temperature Therm Limit (Power-On Default 100°C).                                                                                                                                                                                                                          |

**Table XIV. Register 0x00 Configuration Register 1 Power-On Default 90h**

| Bit | Name                    | R/ $\overline{W}$ | Description                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
|-----|-------------------------|-------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 0   | MONITOR                 | Read/Write        | Setting this bit to a “1” enables monitoring of temperature and enables measurement of the fan tach signals. (Power-Up Default = 0.)                                                                                                                                                                                                                                                                                                                                                            |
| 1   | $\overline{INT}$ Enable | Read/Write        | Setting this bit to a “1” enables the $\overline{INT}$ output.<br>1 = Enabled 0 = Disabled (Power-Up Default = 0.)                                                                                                                                                                                                                                                                                                                                                                              |
| 2   | TACH/AIN                | Read/Write        | Clearing this bit to “0” selects digital fan speed measurement via the TACH pins. Setting this bit to “1” configures the TACH pins as analog inputs that can measure the speed of 2-wire fans via a sense resistor. (Power-Up Default = 0.)                                                                                                                                                                                                                                                     |
| 3   | PWM Invert              | Read/Write        | Setting this bit to “1” inverts the PWM signal on the output pins. (Power-Up Default = 0.)                                                                                                                                                                                                                                                                                                                                                                                                      |
| 4   | Fan Fault Enable        | Read/Write        | Logic 1 enables $\overline{FAN\_FAULT}$ pin; Logic 0 disables $\overline{FAN\_FAULT}$ output. (Power-Up Default = 1.)                                                                                                                                                                                                                                                                                                                                                                           |
| 6–5 | PWM Mode                | Read/Write        | These two bits control the behavior of the fans in Auto Fan Speed Control Mode.<br>00 = Remote Temp 1 controls Fan 1; Remote Temp 2 controls Fan 2.<br>01 = Remote Temp 1 controls Fan 1 and Fan 2.<br>10 = Remote Temp 2 controls Fan 1 and Fan 2.<br>11 = Max of Local Temp and Remote Temp 1 and 2 drives Fans 1 and 2.<br>These two bits have the following effect in Software Control Mode.<br>00 = Program PWM duty cycles for Fans 1 and 2.<br>11 = Program RPM Speeds for Fans 1 and 2. |
| 7   | Auto/SW Ctrl            | Read/Write        | Logic 1 selects Automatic Fan Speed Control; Logic 0 selects SW control. (Power-Up Default = 1) When under software control, PWM duty cycle or RPM values may be programmed for each fan.                                                                                                                                                                                                                                                                                                       |

**Table XV. Register 0x01 Configuration 2 Power-On Default = 7FH**

| Bit | Name             | R/ $\overline{W}$ | Description                                                                                                                             |
|-----|------------------|-------------------|-----------------------------------------------------------------------------------------------------------------------------------------|
| 0   | PWM 1 En         | Read/Write        | Enables Fan 1 PWM output when this bit is a “1.”                                                                                        |
| 1   | PWM 2 En         | Read/Write        | Enables Fan 2 PWM output when this bit is a “1.”                                                                                        |
| 2   | TACH 1 En        | Read/Write        | Enables Tach 1 input when set to “1.”                                                                                                   |
| 3   | TACH 2 En        | Read/Write        | Enables Tach 2 input when set to “1.”                                                                                                   |
| 4   | Loc Temp En      | Read/Write        | Enables Interrupts on Local Temperature Channel when set to “1.”                                                                        |
| 5   | Remote 1 Temp En | Read/Write        | Enables Interrupts on Remote 1 Channel when set to “1.” Default is normally enabled, except when a diode fault is detected on power-up. |
| 6   | Remote 2 Temp En | Read/Write        | Enables Interrupts on Remote 2 Channel when set to “1.” Default is normally enabled, except when a diode fault is detected on power-up. |
| 7   | SW Reset         | Read/Write        | When set to “1,” resets the device. Self-clears. Power-Up Default = 0.                                                                  |

Table XVI. Register 0x02 Status Register 1 Power-On Default = 00H

| Bit | Name                 | R/ $\overline{W}$ | Description                                                                                                                                                                                        |
|-----|----------------------|-------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 0   | Alarm 1 Speed        | Read Only         | This bit is set to “1” when fan is running at alarm speed. Once read, this bit will not reassert on next monitoring cycle, even if the fan is still running at alarm speed.                        |
| 1   | Fan 1 Fault          | Read Only         | This bit is set to “1” if Fan 1 becomes stuck or is running under speed.                                                                                                                           |
| 2   | Remote 1 High        | Read Only         | “1” indicates Remote 1 high temperature limit has been exceeded. If the temperature is still outside the Remote 1 Temp High Limit, this bit will reassert on next monitoring cycle.                |
| 3   | Remote 1 Low         | Read Only         | “1” indicates Remote 1 low temperature limit exceeded (below). If the temperature is still outside the Remote 1 Temp Low Limit, this bit will reassert on next monitoring cycle.                   |
| 4   | Remote 1 Therm       | Read Only         | “1” indicates Remote 1 temperature Therm limit has been exceeded. This bit is cleared on a read of Status Register 1.                                                                              |
| 5   | Remote Diode 1 Error | Read Only         | This bit is set to “1” if a short or open is detected on the Remote 1 temperature channel. This test is only done on power-up, and if set to 1 cannot be cleared by reading the Status Register 1. |
| 6   | Local Temp High      | Read Only         | “1” indicates Local Temp High Limit has been exceeded. If the temperature is still outside the Local Temp High Limit, this bit will reassert on next monitoring cycle.                             |
| 7   | Local Temp Low       | Read Only         | “1” indicates Local Temp Low Limit has been exceeded (below). If the temperature is still outside the Local Temp Low Limit, this bit will reassert on next monitoring cycle.                       |

Table XVII. Register 0x03 Status Register 2 Power-Up Default = 00H

| Bit | Name                 | R/ $\overline{W}$ | Description                                                                                                                                                                                    |
|-----|----------------------|-------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 0   | Alarm 2 Speed        | Read Only         | This bit is set to “1” when Fan 2 is running at alarm speed. Once read, this bit will not reassert on next monitoring cycle, even if the fan is still running at alarm speed.                  |
| 1   | Fan 2 Fault          | Read Only         | This bit is set to “1” if Fan 2 becomes stuck or is running under speed.                                                                                                                       |
| 2   | Remote 2 High        | Read Only         | “1” indicates Remote 2 high temperature limit has been exceeded. If the temperature is still outside the Remote 2 Temp High Limit, this bit will reassert on the next monitoring cycle.        |
| 3   | Remote 2 Low         | Read Only         | “1” indicates Remote 2 low temperature limit exceeded (below). If the temperature is still outside the Remote 2 Temp Low Limit, this bit will reassert on the next monitoring cycle.           |
| 4   | Remote 2 Therm       | Read Only         | “1” indicates Remote 2 temperature Therm limit has been exceeded. This bit is cleared on reading Status Register 2.                                                                            |
| 5   | Remote Diode 2 Error | Read Only         | This bit is set to “1” if a short or open is detected on the Remote 2 temperature channel. This test is only done on power-up, and if set to 1 cannot be cleared by reading Status Register 2. |
| 6   | Local Therm          | Read Only         | “1” indicates Local temperature Therm limit has been exceeded. This bit clears on a read of Status Register 2.                                                                                 |
| 7   | THERM                | Read Only         | Set to “1” when THERM is pulled low as an input. This bit clears on a read of Status Register 2.                                                                                               |

Table XVIII. Register 0x06 Extended Temperature Resolution Power-On Default = 00H

| Bit   | Name          | R/ $\overline{W}$ | Description                                                               |
|-------|---------------|-------------------|---------------------------------------------------------------------------|
| <2:0> | Remote Temp 1 | Read Only         | Holds extended temperature resolution bits for Remote 1 channel.          |
| <5:3> | Remote Temp 2 | Read Only         | Holds extended temperature resolution bits for Remote 2 channel.          |
| <7:6> | Local Temp    | Read Only         | Holds extended temperature resolution bits for Local Temperature channel. |

**Table XIX. Register 0x20 Fan Characteristics Register 1 Power-On Default = 5DH**

| Bit   | Name            | R/W        | Description                                                                                                                                                                                                                                                 |
|-------|-----------------|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <2:0> | Fan 1 Spin-up   | Read/Write | These bits contain the Fan Spin-up time to allow Fan 1 to overcome its own inertia.<br>000 = 200 ms<br>001 = 400 ms<br>010 = 600 ms<br>011 = 800 ms<br>100 = 1 sec<br>101 = 2 secs (Default)<br>110 = 4 secs<br>111 = 8 secs                                |
| <5:3> | PWM 1 Frequency | Read/Write | These bits allow programmability of the nominal PWM 1 output frequency driving Fan 1. (Default = 31 Hz.)<br>000 = 11.7 Hz<br>001 = 15.6 Hz<br>010 = 23.4 Hz<br>011 = 31.25 Hz (Default)<br>100 = 37.5 Hz<br>101 = 46.9 Hz<br>110 = 62.5 Hz<br>111 = 93.5 Hz |
| <7:6> | Speed Range, N  | Read/Write | Speed Range<br>00 = 1<br>01 = 2<br>10 = 4<br>11 = 8                                                                                                                                                                                                         |

**Table XX. Register 0x21 Fan Characteristics Register 2 Power-On Default = 5DH**

| Bit   | Name            | R/W        | Description                                                                                                                                                                                                                                                 |
|-------|-----------------|------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <2:0> | Fan 2 Spin-up   | Read/Write | These bits contain the Fan Spin-up time to allow Fan 2 to overcome its own inertia.<br>000 = 200 ms<br>001 = 400 ms<br>010 = 600 ms<br>011 = 800 ms<br>100 = 1 sec<br>101 = 2 secs (Default)<br>110 = 4 secs<br>111 = 8 secs                                |
| <5:3> | PWM 2 Frequency | Read/Write | These bits allow programmability of the nominal PWM 2 output frequency driving Fan 2. (Default = 31 Hz.)<br>000 = 11.7 Hz<br>001 = 15.6 Hz<br>010 = 23.4 Hz<br>011 = 31.25 Hz (Default)<br>100 = 37.5 Hz<br>101 = 46.9 Hz<br>110 = 62.5 Hz<br>111 = 93.5 Hz |
| <7:6> | Speed Range, N  | Read/Write | Speed Range<br>00 = 1<br>01 = 2<br>10 = 4<br>11 = 8                                                                                                                                                                                                         |

Table XXI. Register 0x22 Fan Speed Config Register Power-On Default = 55H

| Bit   | Name             | R/ $\overline{W}$ | Description                                                                                                                                                                                              |
|-------|------------------|-------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <3:0> | Normal/Min Spd 1 | Read/Write        | This nibble contains the normal speed value for Fan 1. When in Automatic Fan Speed Control Mode, this nibble contains the minimum speed at which Fan 1 will run. Default is 0x05 for 33% PWM duty cycle. |
| <7:4> | Normal/Min Spd 2 | Read/Write        | This nibble contains the normal speed value for Fan 2. When in Automatic Fan Speed Control Mode, this nibble contains the minimum speed at which Fan 2 will run. Default is 0x05 for 33% PWM duty cycle. |

Table XXII. Register 0x23 Fan Filter Register Power-On Default = 50H

| Bit          | Name                              | R/ $\overline{W}$        | Description                                                                                                                                                                                   |
|--------------|-----------------------------------|--------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <7><br><6:5> | Spin-Up Disable<br>Ramp Rate      | Read/Write<br>Read/Write | When set to 1, disables fan spin-up.<br>These bits set the ramp rate.<br>00 = 1<br>01 = 2<br>10 = 4 (Default)<br>11 = 8                                                                       |
| <4:2>        | ADC Sample Rate                   | Read/Write               | These bits set the sampling rate for the ADC.<br>000 = 87.5 Hz<br>001 = 175 Hz<br>010 = 350 Hz<br>011 = 700 Hz<br>100 = 1.4 kHz (Default)<br>101 = 2.8 kHz<br>110 = 5.6 kHz<br>111 = 11.2 kHz |
| <1><br><0>   | Fan 2 Filter En<br>Fan1 Filter En | Read/Write<br>Read/Write | This bit enables fan filtering for Fan 2.<br>This bit enables fan filtering for Fan 1.                                                                                                        |

Table XXIII. Register 0x24 Local Temp  $T_{MIN}/T_{RANGE}$  Power-On Default = 41H

| Bit   | Name                   | R/ $\overline{W}$ | Description                                                                                                                                                                                                                                                                                                                            |
|-------|------------------------|-------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <7:3> | Local Temp $T_{MIN}$   | Read/Write        | Contains the minimum temperature value for Automatic Fan Speed Control based on Local Temperature Readings. $T_{MIN}$ can be programmed to positive values only in 4°C increments. Default is 32°C.<br>00000 = 0°C<br>00001 = 4°C<br>00010 = 8°C<br>00011 = 12°C<br> <br>01000 = 32°C (Default)<br> <br>11110 = 120°C<br>11111 = 124°C |
| <2:0> | Local Temp $T_{RANGE}$ | Read/Write        | This nibble contains the temperature range value for Automatic Fan Speed Control based on the Local Temp Readings.<br>000 = 5°C<br>001 = 10°C (Default)<br>010 = 20°C<br>011 = 40°C<br>100 = 80°C                                                                                                                                      |

**Table XXIV. Register 0x25 Remote 1 Temp T<sub>MIN</sub>/T<sub>RANGE</sub> Power-On Default = 61H**

| Bit   | Name                             | R/ $\overline{W}$ | Description                                                                                                                                                                                                                                                                                                                                      |
|-------|----------------------------------|-------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <7:3> | Remote 1 Temp T <sub>MIN</sub>   | Read/Write        | Contains the minimum temperature value for Automatic Fan Speed Control based on Remote 1 Temperature Readings. T <sub>MIN</sub> can be programmed to positive values only in 4°C increments. Default is 48°C.<br>00000 = 0°C<br>00001 = 4°C<br>00010 = 8°C<br>00011 = 12°C<br> <br>01100 = 48°C (Default)<br> <br>11110 = 120°C<br>11111 = 124°C |
| <2:0> | Remote 1 Temp T <sub>RANGE</sub> | Read/Write        | This nibble contains the temperature range value for Automatic Fan Speed Control based on the Remote 1 Temp Readings.<br>000 = 5°C<br>001 = 10°C (Default)<br>010 = 20°C<br>011 = 40°C<br>100 = 80°C                                                                                                                                             |

**Table XXV. Register 0x26 Remote 2 Temp T<sub>MIN</sub>/T<sub>RANGE</sub> Power-On Default = 61H**

| Bit   | Name                             | R/ $\overline{W}$ | Description                                                                                                                                                                                                                                                                                                                                      |
|-------|----------------------------------|-------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <7:3> | Remote 2 Temp T <sub>MIN</sub>   | Read/Write        | Contains the minimum temperature value for Automatic Fan Speed Control based on Remote 2 Temperature Readings. T <sub>MIN</sub> can be programmed to positive values only in 4°C increments. Default is 48°C.<br>00000 = 0°C<br>00001 = 4°C<br>00010 = 8°C<br>00011 = 12°C<br> <br>01100 = 48°C (Default)<br> <br>11110 = 120°C<br>11111 = 124°C |
| <2:0> | Remote 2 Temp T <sub>RANGE</sub> | Read/Write        | This nibble contains the temperature range value for Automatic Fan Speed Control based on the Remote 2 Temp Readings.<br>000 = 5°C<br>001 = 10°C (Default)<br>010 = 20°C<br>011 = 40°C<br>100 = 80°C                                                                                                                                             |

**Table XXVI. Register 0x3F Therm Behavior/Revision Power-On Default = 80H**

| Bit   | Name            | R/ $\overline{W}$ | Description                                                                                                                                                                                                                                                                                                                                |
|-------|-----------------|-------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <7>   | Therm-to-Fan En | Read/Write        | Setting this bit to 1, enables the fan to run full-speed when $\overline{THERM}$ is asserted low. This allows the system to be run in performance mode. Clearing this bit to 0 disables the fan from running full-speed whenever $\overline{THERM}$ is asserted low. This allows the system to run in silent mode. (Power-On Default = 1). |
| <3:0> | Revision        | Read Only         | This nibble contains the revision number for the ADM1031.                                                                                                                                                                                                                                                                                  |

**Table XXVII. Register 0x0D Local Temp Offset Power-On Default = 00H**

| Bit   | Name         | R/ $\overline{W}$ | Description                                                                                                                                                                                               |
|-------|--------------|-------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <7>   | Sign         | Read/Write        | When this bit is 0, the local offset will be added to the Local Temp Reading. When this bit is set to 1, the local offset will be subtracted from the Local Temp Reading.                                 |
| <3:0> | Local Offset | Read/Write        | These four bits are used to add an offset to the Local Temperature Reading. These bits allow an offset value of up to $\pm 15^{\circ}\text{C}$ to be added to or subtracted from the temperature reading. |

**Table XXVIII. Register 0x0E Remote 1 Temp Offset Power-On Default = 00H**

| Bit   | Name            | R/ $\overline{W}$ | Description                                                                                                                                                                                                                             |
|-------|-----------------|-------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <7>   | Sign            | Read/Write        | When this bit is 0, the remote offset will be added to the Remote 1 Temp Reading. When this bit is set to 1, the remote offset will be subtracted from the Remote 1 Temp Reading.                                                       |
| <6.4> | Unused          | Read/Write        | Unused. Read back 0.                                                                                                                                                                                                                    |
| <3:0> | Remote 1 Offset | Read/Write        | These four bits are used to add an offset to the Remote 1 Temperature Reading. These bits allow an offset value of up to $\pm 15^{\circ}\text{C}$ to be added to or subtracted from the temperature reading, depending on the sign bit. |


**Table XXIX. Register 0x0F Remote 2 Temp Offset Power-On Default = 00H**

| Bit   | Name            | R/ $\overline{W}$ | Description                                                                                                                                                                                                                             |
|-------|-----------------|-------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <7>   | Sign            | Read/Write        | When this bit is 0, the remote offset will be added to the Remote 2 Temp Reading. When this bit is set to 1, the remote offset will be subtracted from the Remote 2 Temp Reading.                                                       |
| <6.4> | Unused          | Read/Write        | Unused. Read back 0.                                                                                                                                                                                                                    |
| <3:0> | Remote 2 Offset | Read/Write        | These four bits are used to add an offset to the Remote 2 Temperature Reading. These bits allow an offset value of up to $\pm 15^{\circ}\text{C}$ to be added to or subtracted from the temperature reading, depending on the sign bit. |

OUTLINE DIMENSIONS

16-Lead Shrink Small Outline Package [QSOP]  
(RQ-16)

Dimensions shown in inches



# Revision History

| Location                                       | Page |
|------------------------------------------------|------|
| 4/03—Data Sheet changed from REV. 0 to REV. A. |      |
| Added ESD Caution .....                        | 3    |
| Updated OUTLINE DIMENSIONS .....               | 30   |

