


## SPECIFICATION CONTROL DRAWING



Product Revision		Ball Color	Product Dimensions			Copper Cross Section		Bundle ø	
Product Name			L±3.5 (L±0.140)	øA	øB	Min. mm <sup>2</sup> (CMA)	Max. mm <sup>2</sup> (CMA)	øD max	M±1 (M±0.04)
SGRP-1	C	Green	38.3 (1.510)	3.1±0.2 (0.125±0.008)	26.0±2 (1.025±0.079)	0.7 (1400)	2.4 (4800)	4.0 (0.160)	15 (0.590)
SGRP-2	C	Red	37.7 (1.485)	3.9±0.2 (0.155±0.008)	23.5±2 (0.925±0.079)	2.0 (4000)	4.0(8000)	6.0 (0.235)	15 (0.590)
SGRP-3	D	Blue	44.5 (1.750)	5.35±0.3 (0.210±0.012)	25.5±3 (1.00±0.118)	3.5 (7000)	9.0(18000)	8.5 (0.335)	15 (0.590)
SGRP-4	D	Yellow	45.5 (1.790)	7.15±0.3 (0.280±0.012)	25.0±3 (0.985±0.118)	7.5 (15000)	15.0(30000)	10.5 (0.410)	15 (0.590)

These products are tested to RB109.


### MATERIALS

1. INSULATION SLEEVE: Heat-shrinkable, transparent blue, radiation cross-linked modified polyvinylidene fluoride.
2. SOLDER PREFORM WITH FLUX:  
SOLDER: TYPE Sn60 per ANSI-J-STD-006.  
FLUX: TYPE ROM1 per ANSI-J-STD-004.
3. CONICAL SPRING: Square copper wire.
4. END CLOSURE BALL: Tinted glass. Color: see table.


### APPLICATION

1. These controlled soldering devices are designed stub splicing of stranded wires with bare copper conductor having an insulation rated for 85°C minimum.
2. Temperature range: class 3A, -40°C to +125°C.  
Vibration range: class 1 (body).  
Seal range: class 0 (seal porous or no seal).
3. For installation procedure and application equipment consult, RPIP-820-00.

For best results, prepare the cable as shown:



\* A trademark of TE Connectivity

		TE Connectivity 300 Constitutional Drive Menlo Park, CA 94025 USA		<b>Raychem</b>		TITLE:  <b>SOLDERGRIP* STUB SPLICE</b>									
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN MILLIMETERS. INCHES DIMENSIONS ARE BETWEEN BRACKETS.						DOCUMENT NO.: <b>SGRP-X</b>									
TOLERANCES: 0.00 N/A 0.0 N/A 0 N/A		ANGLES: N/A  ROUGHNESS IN MICRON		TE Connectivity reserves the right to amend this drawing at any time. Users should evaluate the suitability of the product for their application.		DATE:  15-Apr-11		DOC ISSUE:  6							
DRAWN BY: M. FORONDA		CAGE CODE: 06090		REPLACES: D981339		DCR NUMBER: D020135		PROD. REV.: SEE TABLE		SCALE: None		SIZE: A		SHEET: 1 of 1	

Print Date: 9-May-11 If this document is printed it becomes uncontrolled. Check for the latest revision.